

FILED

JUN 26 2015


HEARING BOARD  
BAY AREA AIR QUALITY  
MANAGEMENT DISTRICT

BEFORE THE HEARING BOARD  
OF THE  
BAY AREA AIR QUALITY MANAGEMENT DISTRICT  
STATE OF CALIFORNIA

In the Matter of the Application of	)	Docket No.: 3673
MILLS-PENINSULA MEDICAL CENTER,	)	ORDER DENYING EMERGENCY
For Emergency Variance from Permit	)	VARIANCE
Condition #42449 (Site #A2227).	)	

The above-entitled matter, being an Application for Emergency Variance (EV) from the provisions of Permit Condition #42449, was filed on June 10, 2015 after initial contact by telephone at 12:54 p.m. on the same date, and having been considered by the Hearing Board,  
THE HEARING BOARD ORDERS:

An EV from the provisions of Permit Condition #42449 is hereby denied based on the finding that the problem with the particulate filters did not develop suddenly and the problem should not be considered as a breakdown or an unforeseen failure and, therefore, does not qualify as an emergency situation.

  
\_\_\_\_\_  
Peter Y. Chiu, M.D., P.E.  
Hearing Board Member

June 26, 2015  
Date

