



BAY AREA  
AIR QUALITY  
MANAGEMENT  
DISTRICT

# PUBLIC NOTICE

August 30, 2022

TO: All residential and business neighbors located within 1,000 feet of the proposed new or modified source(s) of air pollution listed below.

FROM: Bay Area Air Quality Management District

RE: Permit Application #663096 for the following source(s) of air pollution:

**Three (3) Temporary Prime Generators  
Candlestick Point/Bayview Vehicle Triage Center  
500 Hunters Point Expressway, San Francisco, CA 94124**

---

The Bay Area Air Quality Management District (the “District”) is a local agency that regulates stationary sources of air pollution such as factories, industrial sites, and gasoline stations.

Whenever we receive a permit application for a new or modified source(s) of toxic air contaminants located within 1,000 feet of a school site or within a community that is overburdened by air pollution, we notify the public about the proposed project. To comply with Air District requirements, we distribute or mail a Public Notice to the parents or guardians of students enrolled at schools located within ¼ mile, and all residents and businesses located within 1,000 feet, of the proposed source(s).

You are receiving this Public Notice because a permit application has been filed with the District for the above referenced source(s) of air pollution. A description of the proposed project follows:

*San Francisco Department of Public Works & Department of Homelessness and Supportive Housing* has applied for an Authority to Construct and Permit to Operate for two (2) diesel-fueled prime generators and one (1) liquefied petroleum gas (LPG) fired prime generator to provide temporary power to a temporary housing site while waiting on Pacific Gas & Electric (PG&E) to provide permanent power to the site.

***PRELIMINARY EVALUATION***

The District has evaluated the permit application for the proposed project and has made a preliminary determination that the project is expected to comply with all applicable District, state, and federal air quality-related regulations, including the health risks resulting from toxic air contaminant emissions. The preliminary recommendation is to issue a permit for this project. After considering all comments received, the District will make a final determination.

***ADDITIONAL INFORMATION***

The Air District's Community Health Protection Program is focused on reducing air pollution disparities in overburdened communities. For more information on Air District activities in your community, consult the Air District's website at:

<https://www.baaqmd.gov/community-health>

If you are interested in getting more information about this project, you may obtain a copy of the District's evaluation report from the Air District's website at:

<http://www.baaqmd.gov/permits/public-notice>

***PUBLIC COMMENT PERIOD***

**There is a 30-day period for public response to this proposal. If you wish to comment on the proposed project, you may do so in writing or by e-mail. Alternatively, you may call and leave a telephone message up to one minute in length. Please leave your name and telephone number so that a District staff member may respond to your message.**

Please use the following contact information if you would like to comment on the proposed project:

Mailing address: Candlestick Point/Bayview Vehicle Triage Center  
(A#663096)  
Public Notice Response  
BAAQMD - Engineering Division  
375 Beale Street, Suite 600  
San Francisco, CA 94105  
Attn: Cameron Fee

E-mail address: [cfee@baaqmd.gov](mailto:cfee@baaqmd.gov)

Telephone Number: (415) 749-5122 Box #5

The public comment period for this project ends on **September 29, 2022.**