

BAAQMD Title V Permit
6 Month Monitoring Report

From 7/1/2013 to 12/31/2013

A0011 Shell Oil Products US Martinez Refinery

Facility Address:

3485 Pacheco Blvd

Mailing Address:

PO Box 711

City: Martinez

State: CA

Zip Code: 94553-0071

City: Martinez

State: CA

Zip Code: 94553-0071

Contact: Liz Rosales Title: Environmental Specialist Phone: (925) 313-3857

Inoperable monitors as defined by BAAQMD Regulations 1-522 and 1-523 for the reporting period are summarized below:

Started	Stopped	Source (SF)	Abatement Device (AD)	Emission Point (EP)	Fuel	CEM	GLM	Gas	Parameter	NOx	SO2	CO	HBS	TRB	NH3	O2	CO2	H2O	LTA	Lead	Steam	Flow	Wind Dir.	Wind Speed	pH	Temp	YOC	Gauge	Press			
7/22/2013 1:50 PM	8/1/2013 4:10 PM	4180	A1180																													
Event Description: SRU4 TRS Analyzer 18A234 out of service for annual rebuild as part of its preventative maintenance program.																																
8/21/2013 2:00 PM	8/29/2013 1:50 PM	1759	A751																													
Event Description: Analyzer 14A1251, H2S in Flexigas, out of service for an annual rebuild as part of preventative maintenance program.																																
10/8/2013 4:10 AM	10/10/2013 2:00 PM	1431	A1431																													
Event Description: SRU 1&2 O2 analyzer 8A850 out of service for greater than 24 hours due to sample system pump failure.																																
10/8/2013 4:10 AM	10/10/2013 2:00 PM	1431	A52																													
Event Description: SRU 1&2 SO2 analyzer 8A849 out of service for greater than 24 hours due to sample system pump failure.																																
10/31/2013 8:40 AM	11/1/2013 2:00 PM	1778																														
Event Description: DCU Cooling water tower Hydrocarbon analyzer 40A1708 out of service more than 24 hours due to calibration errors.																																

Certification Statement

I certify under penalty of law that based on the information and belief formed after reasonable inquiry, the statements and information in this document and in all attachments and other materials are true, accurate, and complete.

x Paul Gaillard Paul Gaillard Green Manager 1/22/14
Signature of Responsible Official Print Name Title Date