BAAQMD Title V Permit
6 Month Monitoring Report

From 1/1/2014 to 6/30/2014

				Facility Ac 348 City: <u>Mar</u> State: <u>CA</u> Zip Code: <u>945</u>	5 Pacheco Blvd tinez 53-0071 Ĉontac	t: Liz Rosales		- Title		State	PO Box 7 Martinez CA: 94553-00)71	(9 25) 31	3-3857					,				
Inoperable monitors as defined by BAAQMD Regulations 1-522 and 1-523 for the reporting period are summarized below: Abatement Emission Fuel Opacity Wind Gauge Stand Stanged Source (Sif) Device (Aif) Point (P#) CEM GLM Gas Parametri NOx SO2 CO H2S TRS NH3 Q2 CO2 H2O LTA Lead Steam Flow Wind Dir, Speed pH Temp. VOC. Press.														iauge									
Started	Stopped			Source (S#)	Device (A#)	Point (P#)	CEM	GLM G	s Parametr	NOx SO2	CO H2S	TRS	NH3 <u>O2</u>	CO2 H20		Steam	Flow V	Vind Dir.	Speed	pH T	emp. V	OC. P	ress.
1/7/2014 4:50 PM Event Description: COB	1/9/2014	10:45 AM	2	1509	A13	of converter and	₩er s	□ □		vated and ret	urned to se	Tvice.											
	1/22/2014	10:30 AM	₽	4201										00	 _		Ø				O	D	
2/5/2014 11:55 AM Event Description: F-63	2/6/2014 NOx analyze	5:00 PM r 06A2276 out of co	ntrol. The a	analyzer did not cali	brate within 24 hour	rs because the au	:o-calibr	ation was			ation and r		l to servic			0	0						۵
3/7/2014 12:12 PM Event Description: CF R	3/8/2014 FG H2\$ anal	4:57 PM yzer 09Al2831 out	☑ of service f	or greater than 24 he	ours due to plugging	3 .	Ø	00	ı o	0 0				00									
3/7/2014 12:12 PM Event Description: CF R	3/8/2014 FG TRS ana	4:57 PM yzer 09A2825 out o	√ f service gre	eater than 24 hours	due to plugging.		- 27		ı D		00	Ø							<u> </u>				_
4/18/2014 9:10 AM Event Description: Utilit	4/19/2014 es Cogen #2	10:35 AM O2 analyzer 66AI61	✓ 6 out of sc	rvice over 24 hours	- out of control.		2				00							<u> </u>		0			
4/18/2014 9:10 AM Event Description: Utilit	4/19/2014 ies Cogen #2	10:35 AM NOx analyzer 66A	⊠ 617 out of	4193 scrvice over 24 hou	rs - out of control.		☑	0 0		8 0		0		00				0		0	0		
4/21/2014 9:10 AM Event Description: Utilit	4/22/2014 es Cogen #2	10:50 AM NOx and O2 analyz	☑ ers 66∧I 61	4192 6 and 66AI617 out	A4192 of service over 24 h	ours due to bad r	☑ egulator	. .	ı 🖸	Ø O					 							O -	_
5/5/2014 2:00 PM Event Description: LOP	5/8/2014 RFG H2S A	7:10 PM nalyzer 9A11610 out	of service p	greater than 24 hour	s for annual rebuild		Ø	0 0					00							0			
Thursday, July 03, 2014																						Page 1	of 2

Started	Stopped	Source (S#)	Abatement Device (A#)	Emission Point (P#)	Fuel CEM GLM Gas Parametri NO	Ox SO2 CO H2S	Opacity/ LTA Lead Steam Flow	Wind Dir. Speed pH	Temp. VOC. Pres
Certification S	<u>Statement</u>								
reasonable inqui	enalty of law that based on the infe iry, the statements and information other materials are true, accurate,	in this document and in all and complete.	Gen. Ma	·	7/24/4				
Signature of Res	sponsible Official	Print Name	Title		Date				