### **Bay Area Air Quality Management District**

939 Ellis Street San Francisco, CA 94109 (415) 771-6000

### **Final**

### MAJOR FACILITY REVIEW PERMIT

### **Issued To:**

Mirant Delta, L.L.C., Contra Costa Power Plant Facility #A0018

**Facility Address:** 

3201 Wilbur Avenue Antioch, CA 94509

**Mailing Address:** 

P.O. Box 249 Antioch, CA 94509

**Primary Responsible Official** 

Jim Garlick, Vice President Operations, Mirant California

(678) 579-5040

**Secondary Responsible Official** 

Robert E. Driscoll
Senior Vice President
and Head of Asset Management
Mirant U.S. Region

(678) 579-5744 (925) 427-3503

Type of Facility: Electric Generation BAAQMD Engineering

Division Contact: Craig Ullery

**Facility Contact** 

Tom Bertolini

Sr. Environmental Engineer

**Primary SIC:** 4911 Craig Uller

**Product:** Electricity

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Signed by Jeff McKay for Jack P. Broadbent September 15, 2010

Jack P. Broadbent, Executive Officer/Air Pollution Control Officer

Date

### TABLE OF CONTENTS

I.	STANDARD CONDITIONS	3
II.	EQUIPMENT LIST	8
III.	GENERALLY APPLICABLE REQUIREMENTS	9
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS	11
V.	SCHEDULE OF COMPLIANCE	25
VI.	PERMIT CONDITIONS	26
VII.	APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS	31
VIII.	TEST METHODS	40
IX.	REVISION HISTORY	43
X.	ACID RAIN PERMIT	44
XI.	GLOSSARY	47
XII.	ACID RAIN PERMIT APPLICATION	52

Facility Name: Mirant Delta, L.L.C., Contra Costa Power Plant Permit for Facility #: A0018

### I. STANDARD CONDITIONS

#### A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

BAAQMD Regulation 1 - General Provisions and Definitions

(as amended by the District Board on 5/2/01);

SIP Regulation 1 - General Provisions and Definitions

(as approved by EPA through 6/28/99);

BAAQMD Regulation 2, Rule 1 - Permits, General Requirements

(as amended by the District Board on 6/15/05);

SIP Regulation 2, Rule 1 - Permits, General Requirements

(as approved by EPA through 1/26/99);

BAAQMD Regulation 2, Rule 2 - Permits, New Source Review

(as amended by the District Board on 6/15/05);

SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration

(as approved by EPA through 1/26/99);

BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking

(as amended by the District Board on 12/21/04);

SIP Regulation 2, Rule 4 - Permits, Emissions Banking

(as approved by EPA through 1/26/99); and

BAAQMD Regulation 2, Rule 6 - Permits, Major Facility Review

(as amended by the District Board on 4/16/03).

#### B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

- 1. This Major Facility Review Permit was issued on August 19, 2005 and expires on August 18, 2010. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than February 18, 2010 and no earlier than August 18, 2009. **If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after August 18, 2010.** If the permit renewal has not been issued by August 18, 2010, but a complete application for renewal has been submitted in accordance with the above deadlines, the existing permit will continue in force until the District takes final action on the renewal application. (Regulation 2-6-307, 404.2, 407, & 409.6; MOP Volume II, Part 3, §4.2)
- 2. The permit holder shall comply with all Conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and Conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)
- 3. In the event any enforcement action is brought as a result of a violation of any term or Condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or Condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)

- 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
- 5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit Condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 6. This permit does not convey any property rights of any sort, or any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
- 8. Any records required to be maintained pursuant to this permit that the permittee considers proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
- 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B Public Information, Confidentiality of Business Information. (40 CFR Part 2)
- 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
- 11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (MOP Volume II, Part 3, §4.11)
- 12. The permit holder is responsible for compliance, and certification of compliance, with all conditions of the permit, regardless whether it acts through employees, agents, contractors, or subcontractors. (Regulation 2-6-307)

#### C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

#### **D.** Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

#### E. Records

- 1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
- 2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501, MOP Volume II, Part 3, §4.7)

### F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. Reports shall be submitted for the following periods: September 1st through February 28<sup>th</sup> or 29<sup>th</sup> and March 1st through August 31st, and are due 30 days after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement Bay Area Air Quality Management District 939 Ellis Street San Francisco, CA 94109 Attn: Title V Reports

(Regulation 2-6-502, MOP Volume II, Part 3, §4.7)

#### **G.** Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be September 1st to August 31<sup>st</sup> of each year. The certification shall be submitted by September 30<sup>th</sup> of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance,

and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent to the Environmental Protection Agency at the following address:

Director of the Air Division U.S. EPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

#### **H.** Emergency Provisions

- 1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
- 2. The permit holder may seek relief from enforcement action for a violation of any of the terms and Conditions of this permit by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. (MOP Volume II, Part 3, §4.8)
- 3. The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

#### I. Severability

1. In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

#### J. Miscellaneous Conditions

1. The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

#### K. Accidental Release

This facility is subject to 40 CFR Part 68, Chemical Accident Prevention Provisions. The permit holder shall submit a risk management plan (RMP) by the date specified in \$68.10. The permit holder shall also certify compliance with the requirements of Part 68 as part of the annual compliance certification, as required by Regulation 2, Rule 6. (40 CFR Part 68, Regulation 2, Rule 6)

#### L. Conditions to Implement Regulation 2, Rule 7, Acid Rain

- 1. The permit holder shall hold one sulfur dioxide allowance for each ton of sulfur dioxide emitted during the calendar year on March 1st of the following year (or February 29 in any leap year or if such day is not a business day, the first business day thereafter). (MOP Volume II, Part 3, §4.9; 40 CFR 72.2, Allowance Transfer Deadline)
- 2. The equipment installed for the continuous monitoring of CO2 or O2 and NOx shall be maintained and operated in accordance with 40 CFR Parts 72 and 75. (Regulation 2-7, Acid Rain)
- 3. A written Quality Assurance program must be established in accordance with 40 CFR Part 75, Appendix B for NOx which includes, but is not limited to: procedures for daily calibration testing, quarterly linearity testing, recordkeeping and reporting implementation, and relative accuracy testing. (Regulation 2-7, Acid Rain)
- 4. The permit shall monitor SO2 emissions in accordance with 40 CFR Part 72 and 75. (Regulation 2-7, Acid Rain)
- 5. The permit holder shall submit quarterly Electronic Data Reports (EDR) to EPA for Boilers S-9 and S-10. These reports must be submitted within 30 days following the end of each calendar quarter and shall include all information required in § 75.64. (40 CFR Part 75)

Facility Name: Mirant Delta, L.L.C., Contra Costa Power Plant Permit for Facility #: A0018

### II. EQUIPMENT LIST

### Table II-A, Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-#	Description	Make or Type	Model	<b>Design Capacity</b>
S-9	Boiler No. 9, Electric	Babcock & Wilcox		3,400 MMBTU/hr
	Generation and Gas Fired			
S-10	Boiler No. 10, Electric	Babcock & Wilcox		3,400 MMBTU/hr
	Generation and Gas Fired			
S-20	Service Station, G# 6557		1 nozzle	1,000 gallon tank
S-33	Maintenance Coating Operation			
S-34	Fixed Roof Oil Water Surge	Pitt Des Moines		56,000 gallons
	Tank			
S-35	API Separator	Wemco	Model	1000 gallons
			CFA-4	
S-37	Dissolved Air Flotation (DAF)			1000 gal/min
S-40	Wipe Cleaning, Facility-Wide	Custom Design		
S-100	Sand Blast Facility	Zero Manufacturing		

Table II-B
Abatement Devices

<b>A-</b> #	Description	Source(s)	Applicable	Operating	Limit or
		Controlled	Requirement	Parameters	Efficiency
A-10	Selective Catalytic	S-10	BAAQMD		*
	Reduction (SCR)		9-11-309		
A-100	Baghouse	S-100	BAAQMD		0.15 gr/dscf
			6-301		for <3
					min/hr

<sup>\*</sup>S-9 and S-10 boilers are subject to the Advanced Technology Alternative Emission Control Plan (ATAECP "system-wide emissions bubble") of Regulation 9-11, Section 309. Under the ATAECP, the individual boilers are not required to comply with a specific emission limit, but their emissions and fuel use contribute to a system-wide average. The current system-wide average NO<sub>x</sub> limit (2005) is 0.018 lb/MMbtu.

8

### III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit. This section also contains provisions that may apply to temporary sources.

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

- BAAQMD regulation(s):
   The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
- Any federal requirement, including a version of a District regulation that has been approved into the SIP:
   The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on EPA Region 9's website included in Appendix A of this permit if the SIP requirement is different from the current BAAQMD requirement. The address is:

http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions

#### **NOTE:**

There are differences between current BAAQMD rules and versions of the rules in the SIP. All sources must comply with both versions of a rule until the U.S. EPA has reviewed and approved by the District's revision of the regulation.

Table III
Generally Applicable Requirements

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (5/2/01)	N
SIP Regulation 1	General Provisions and Definitions (6/28/99)	Y
BAAQMD Regulation 2, Rule 1	General Requirements (12/21/04)	N
BAAQMD 2-1-429	Federal Emissions Statement (6/7/95)	Y

9

# III. Generally Applicable Emission Requirements

# Table III Generally Applicable Requirements

Applicable	Regulation Title or	Federally Enforceable
Requirement	Description of Requirement	(Y/N)
SIP Regulation 2, Rule 1	General Requirements (1/26/99)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning (3/6/02)	Y
SIP Regulation 5	Open Burning (3/6/02)	N
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (11/21/01)	N
BAAQMD Regulation 8, Rule 40	Organic Compounds - Aeration of Contaminated Soil and Removal of Underground Storage Tanks (12/15/99)	Y
BAAQMD Regulation 8, Rule 47	Organic Compounds - Air Stripping and Soil Vapor Extraction Operations (6/15/94)	Y
BAAQMD Regulation 8, Rule 49	Organic Compounds – Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds – Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds – Adhesive and Sealant Products (7/17/02)	N
SIP Regulation 8, Rule 51	Organic Compounds – Adhesive and Sealant Products (2/26/02)	Y
BAAQMD Regulation 9, Rule 1	Sulfur Dioxide	Y
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (10/7/98)	Y
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y
California Health and Safety Code Section 41750 et seq.	Portable Equipment	N
California Health and Safety Code Section 44300 et seq.	Air Toxics "Hot Spot" Information and Assessment Act of 1987	N
40 CFR Part 61, Subpart M	National Emission Standards Hazardous Air Pollutants, Asbestos	Y

Facility Name: Mirant Delta, L.L.C., Contra Costa Power Plant Permit for Facility #: A0018

### IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

- BAAQMD regulation(s):
   The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:

The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit Condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website. The address is:

http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions

All other text may be found in the regulations themselves.

Table IV-A S-9, Utility Boiler No. 9

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	General Provisions and Definitions (5/17/00)		
Regulation 1			
1-520	Continuous Emission Monitoring		
1-520.1	Steam Generators Rated 250 MMBTU or More Per Hour	Y	
1-522	Continuous Emission Monitoring and Record Keeping Procedures	Y	
1-522.1	Plans and Specifications	Y	
1-522.2	Installation Scheduling	Y	
1-522.3	Performance Testing	Y	
1-522.4	Periods of Inoperation Greater Than 24 Hours	Y	
1-522.5	Calibration	Y	
1-522.6	Accuracy	Y	
1-522.7	Excesses	Y	
1-522.8	Monthly Reports	Y	
1-522.9	Records	Y	
1-522.10	Monitors Required by Sections 1-521 or 2-1-403	Y	

### Table IV-A S-9, Utility Boiler No. 9

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
SIP	General Provisions and Definitions (6/28/99)		
Regulation 1			
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
1-522.7	Monitor Excesses	Y	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann No. 1 Limitation	Y	
6-304	Tube Cleaning	Y	
6-305	Visible Particulates	Y	
6-310	Particulate Weight Limitation	Y	
6-310.3	Particulate Weight Limitation, Heat Transfer Operation	Y	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation 9,			
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission limitations	Y	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides From Heat		
Regulation 9,	Transfer Operations (3/17/82)		
Rule 3			
9-3-301	Existing Heat Transfer Operation Limits	N	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide From Utility Electric Power Generating Boilers		
Rule 11	(5/17/00)		
9-11-111	Exemption, Startup or Shutdown	Y	
9-11-302	Interim Compliance NOx Emission Limits for Boilers with a Rated	Y	
	Heat Input Capacity Greater Than or Equal to 1.75 billion BTU/hour		
9-11-302.1.1	NOX limits, limitation on gaseous fuel firing	Y	
9-11-308	System-wide NOx Emission Rate Limit: 0.28 lb/MM Btu	Y	
9-11-309	Advanced Technology Alternative Emission Control Plan	N	
9-11-309.1	System-wide NOx Emission Rate Limits: 0.018 lb/MMBTU	N	
9-11-309.2	Boilers in Startup or Shutdown; Boilers Taken Out of Service;	N	
0.44.00	Boilers on Force Majeure Natural Gas Curtailment; and Oil Testing	3-	
9-11-309.3	Election of Systemwide NOx Emission Rate Limits	N	
9-11-309.4	Eligible Boilers	N	

Table IV-A S-9, Utility Boiler No. 9

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
9-11-311	Ammonia Emission Limit for Boilers with a Rated Heat Input	Y	Upon
	Capacity Greater than or equal to 250 million BTU/hour		installment of
			an applicable
			control
			device
9-11-310	CO Emission Limits for Boilers with a Rated Heat Input Capacity	Y	
	Greater Than or Equal to 250 million BTU/hour		
9-11-401	Compliance Schedule - Emissions Limits	Y	
9-11-402	Initial and Annual Demonstration of Compliance	Y	
9-11-501	Fuels Monitoring	Y	
9-11-502	Modified Maximum Heat Input Capacity	Y	Upon
			physical
			modification
			affecting
			maximum
0.11.502			heat input
9-11-503	Emissions Monitoring	Y	
9-11-504	Records	Y	
9-11-505	Reporting Requirements	Y	
9-11-604	Compliance Determination	Y	
9-11-605	Determination of a Higher Heating Value	Y	
BAAQMD	Hazardous Pollutants, Lead (3/17/82)		
Regulation 11, Rule 1			
11-1-301	Daily Limitation	Y	
11-1-302	Ground level Concentration Limit Without Background	Y	
BAAQMD	Continuous Emission Monitoring Policy and Procedures	Y	
Manual of	(1/20/82)		
Procedures,			
Volume V			
40 CFR	Title IV – Acid Rain Program	Y	
Part 72			
40 CFR	Code of Federal Regulations, Continuous Emissions Monitoring	Y	
Part 75			

### Table IV-A S-9, Utility Boiler No. 9

Applicable Requirement BAAQMD Condition #672	Regulation Title or  Description of Requirement  Permit Conditions	Federally Enforceable (Y/N)	Future Effective Date
Part 6	Natural Gas Firing (Basis: Regulation 2-1-301)	Y	
Part 7	Shut down Condition (Basis: Voluntary)	N	

This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Table IV-B S-10, Utility Boiler No. 10

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	General Provisions and Definitions (5/17/00)		
Regulation 1			
1-520	Continuous Emission Monitoring		
1-520.1	Steam Generators Rated 250 MMBTU or More Per Hour	Y	
1-522	Continuous Emission Monitoring and Record Keeping Procedures	Y	
1-522.1	Plans and Specifications	Y	
1-522.2	Installation Scheduling	Y	
1-522.3	Performance Testing	Y	
1-522.4	Periods of Inoperation Greater Than 24 Hours	Y	
1-522.5	Calibration	Y	
1-522.6	Accuracy	Y	
1-522.7	Excesses	Y	
1-522.8	Monthly Reports	Y	
1-522.9	Records	Y	
1-522.10	Monitors Required by Sections 1-521 or 2-1-403	Y	
SIP	General Provisions and Definitions (6/28/99)		
Regulation 1			
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
1-522.7	Monitor Excesses	Y	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann No. 1 Limitation	Y	
6-304	Tube Cleaning	Y	
6-305	Visible Particulates	Y	
6-310	Particulate Weight Limitation	Y	
6-310.3	Particulate Weight Limitation, Heat Transfer Operation	Y	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation 9,			
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission limitations	Y	

Table IV-B S-10, Utility Boiler No. 10

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides From Heat	<u> </u>	
Regulation 9,	Transfer Operations (3/17/82)		
Rule 3	•		
9-3-301	Existing Heat Transfer Operation Limits	N	
BAAQMD	Inorganic Gaseous Pollutants, Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide From Utility Electric Power Generating Boilers		
Rule 11	(5/17/00)		
9-11-111	Exemption, Startup or Shutdown	Y	
9-11-302	Interim Compliance NOx Emission Limits for Boilers with a Rated	Y	
	Heat Input Capacity Greater Than or Equal to 1.75 billion BTU/hour		
9-11-302.1.1	NOX limits, limitation on gaseous fuel firing	Y	
9-11-308	System-wide NOx Emission Rate Limit: 0.28 lb/MM Btu	Y	
9-11-309	Advanced Technology Alternative Emission Control Plan	N	
9-11-309.1	System-wide NOx Emission Rate Limits: 0.018 lb/MMBTU	N	1/1/05
9-11-309.2	Boilers in Startup or Shutdown; Boilers Taken Out of Service;	N	
	Boilers on Force Majeure Natural Gas Curtailment; and Oil Testing		
9-11-309.3	Election of Systemwide NOx Emission Rate Limits	N	
9-11-309.4	Eligible Boilers	N	
9-11-310	CO Emission Limits for Boilers with a Rated Heat Input Capacity	Y	
	Greater Than or Equal to 250 million BTU/hour		
9-11-311	Ammonia Emission Limit for Boilers with a Rated Heat Input	Y	
	Capacity Greater Than or Equal to 250 million BTU/hour		
9-11-401	Compliance Schedule - Emissions Limits	Y	
9-11-402	Initial and Annual Demonstration of Compliance	Y	
9-11-501	Fuels Monitoring	Y	
9-11-502	Modified Maximum Heat Input Capacity	Y	Upon
			physical
			modification
			affecting
			max. heat
			input
9-11-503	Emissions Monitoring	Y	
9-11-504	Records	Y	
9-11-505	Reporting Requirements	Y	
9-11-604	Compliance Determination	Y	

Table IV-B S-10, Utility Boiler No. 10

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
9-11-605	Determination of a Higher Heating Value	Y	
BAAQMD	Hazardous Pollutants, Lead (3/17/82)		
Regulation 11,			
Rule 1			
11-1-301	Daily Limitation	Y	
11-1-302	Ground level Concentration Limit Without Background	Y	
BAAQMD	Continuous Emission Monitoring Policy and Procedures	Y	
Manual of	(1/20/82)		
Procedures,			
Volume V			
40 CFR	Title IV – Acid Rain Program	Y	
Part 72			
40 CFR	<b>Code of Federal Regulations, Continuous Emissions Monitoring</b>	Y	
Part 75			
BAAQMD	Permit Conditions		
Condition #672			
Part 6	Natural Gas Firing (Basis: Regulation 2-1-301)	Y	
Part 7	Shut down Condition (Basis: Voluntary)	N	

<sup>1.</sup> This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Table IV C S-20, Service Station G#6557

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds, Gasoline Dispensing Facilities	(1/14)	Date
Regulation 8,	(11/6/02)		
Rule 7	(110,02)		
8-7-113	Exemption, Tank Gauging and Inspection	Y	
8-7-301	Phase I Requirements	Y	
8-7-301.1	Requirement for CARB Phase I System	Y	
8-7-301.2	Installation of Phase I Equipment per CARB Requirements	Y	
8-7-301.3	Submerged Fill Pipes	Y	
8-7-301.5	Maintenance of Phase I Equipment per Manufacturers	Y	
	Guidelines or CARB Executive Order		
8-7-301.6	Leak-Free, Vapor-Tight	Y	
8-7-301.7	Poppetted Drybreaks	Y	
8-7-301.8	No Coaxial Phase I Systems on New and Modified Tanks	Y	
8-7-301.9	CARB-Certified Anti-Rotational Coupler or Swivel Adapter	Y	
8-7-301.10	System Vapor Recovery Rate	Y	
8-7-301.11	CARB-Certified Spill Box	Y	
8-7-301.12	Drain Valve Permanently Plugged	Y	
8-7-301.13	Conditionuct and Passing Test Once per 12-Month Period	Y	
8-7-302	Phase II Requirements	Y	
8-7-302.1	Requirement for CARB Phase II System	Y	
8-7-302.2	Maintenance of Phase II Equipment per CARB Requirements	Y	
8-7-302.3	Maintenance of All Equipment as Specified By Manufacturer	Y	
8-7-302.4	Repair of Defective Parts Within 7 Days	Y	
8-7-302.5	Leak-Free, Vapor-Tight	Y	
8-7-302.6	Insertion Interlocks	Y	
8-7-302.7	Built-In Vapor Check Valve	Y	
8-7-302.8	Minimum Liquid Removal Rate	Y	October 2008
8-7-302.9	Coaxial Hose	Y	2006
8-7-302.10	Galvanized Piping or Flexible Tubing	Y	
8-7-302.11	ORVR Compatible	Y	
8-7-302.12	Liquid Retainment Limit	Y	October 2008

Table IV C S-20, Service Station G#6557

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
8-7-302.13	Spitting Limit	Y	October
			2008
8-7-302.14	Conditionuct and Passing Test Once per 12-Month Period	Y	
8-7-303	Topping Off	Y	
8-7-304	Certification Requirements	Y	
8-7-306	Prohibition of Use	Y	
8-7-307	Posting of Operating Instructions	Y	
8-7-308	Operating Practices	Y	
8-7-309	Phase I Requirements	Y	
8-7-310	Phase II Requirements	Y	
8-7-311	Exempt Tanks Requirements	Y	
8-7-313	New and Modified Phase II Installations	Y	
8-7-314	Hold Open Latch Requirement	Y	
8-7-315	Pressure Vacuum Valve Requirement, Underground Storage	Y	
	Tank		
8-7-401	Permit Requirements, New and Modified Installations	Y	
8-7-406	Testing Requirements, New and Modified Installations	Y	
8-7-407	Periods Testing Requirements	Y	
8-7-408	Periods Testing Notification & Submission Requirements	Y	
8-7-501	Burden of Proof	Y	
8-7-502	Right of Access	Y	
8-7-503	Recordkeeping Requirements	Y	
8-7-503.1	Gasoline Dispensed Records	Y	
8-7-503.2	Dispensing Facility Maintenance Records	Y	
8-7-503.3	Dispensing Records Retention	Y	
BAAQMD	Permit Condition		
Condition #21996			
Part 1	Fuel throughput limitation (basis: toxic risk policy)	Y	

Table IV-C S-33, Maintenance Coating Operation

		Federally	Future	
Applicable	Regulation Title or	Enforceable	Effective	
Requirement	Description of Requirement	(Y/N)	Date	
BAAQMD	Organic Compounds, Architectural Coatings (11/21/01)			
Regulation 8,				
Rule 3				
8-3-301	VOC content Limits	Y		
8-3-303	Sell-Through of Coatings	Y		
8-3-304	Painting Practices	Y		
8-3-305	Prohibition of Excess Thinning	Y		
8-3-306	Rust Preventative Coatings	Y		
8-3-307	Coatings Not Listed In Section 8-3-301	Y		
8-3-309	Limited Allowance, Industrial Maintenance Coatings	Y		
8-3-401	Container Labeling Requirements	Y		
8-3-402	Petition, Limited Allowance for Industrial Maintenance Coatings	Y		
BAAQMD	Organic Compounds - Surface Coating of Miscellaneous Metal			
Regulation 8,	Parts and Products (10/16/02)			
Rule 19				
8-19-110	Exemption - Low Usage Coatings	Y		
8-19-112	Exemption - Touch Up	Y		
8-19-113	Exemption - Specific Operations	Y		
8-19-117	Exemption - Stencil Coating	Y		
8-19-123	Exemption, Solid Film Lubricant	Y		
8-19-133	Exemption - Spray Application Equipment	Y		
8-19-136	Limited Exemption - Specialty Coatings	Y		
8-19-302	VOC Limits	Y		
8-19-307	Prohibition of Specification	Y		
8-19-312	Specialty Coating Limitations	Y		
8-19-313	Spray Application Equipment Limitations	Y		
8-19-320	Solvent Evaporative Loss Minimization	Y		
8-19-321	Surface Preparation Standards	Y		
8-19-405	Low Usage Coating Petition	Y		
8-19-407	Specialty Coating Petition	Y		
8-19-408	Emission Reduction Credits	Y		
8-19-501	Records	Y		

Table IV-C S-33, Maintenance Coating Operation

		Federally	Future	
Applicable	Regulation Title or	Enforceable	Effective	
Requirement	Description of Requirement	(Y/N)	Date	
BAAQMD	Permit Conditions			
Condition #8854				
Part 1	Net Annual Coating Usage Limit (basis: cumulative increase)	Y		
Part 2	Net Annual General Solvent Limit (basis: cumulative increase)	Y		
Part 3	Record Keeping Provisions for Adding Components To Coatings	Y		
	(basis: BAAQMD Regulation 8-19-501.2)			

Table IV-D S-34, Fixed Roof Oil Water Surge Tank

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Organic Compounds – Wastewater (Oil-Water) Separators		
Regulation 8,	(6/15/94)		
Rule 8			
8-8-112	Exemption, Wastewater Critical OC Concentration And/Or Temperature	Y	
8-8-113	Exemption, SeConditionary Wastewater Treatment Processes and Stormwater Sewer Systems	Y	
8-8-305	Oil-Water Separator And/Or Air Flotation Unit Slop Oil Vessels	Y	
8-8-502	Wastewater Critical Organic Compound Concentration And/Or Temperature Records		
8-8-503	Inspection and Repair Records	Y	
BAAQMD Condition #7938	Permit Conditions		
Part 1	Wastewater Throughput Limit (basis: cumulative increase)	N	
Part 2	Combined Wastewater and Storm Water Limit (basis: cumulative increase)	N	
Part 3	Record Keeping Requirements (basis: Regulation 8-8-501)	Y	

Table IV-E S-35, API Separator

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Organic Compounds – Wastewater (Oil-Water) Separators		
Regulation 8,	(6/15/94)		
Rule 8			
8-8-112	Exemption, Wastewater Critical OC Concentration And/Or	Y	
	Temperature		
8-8-113	Exemption, SeConditionary Wastewater Treatment Processes and	Y	
	Stormwater Sewer Systems		
8-8-305	Oil-Water Separator and/or Air Flotation Unit Slop Oil Vessels	Y	
8-8-501	API Separator or Air Flotation Bypassed Wastewater Records	Y	
8-8-503	Inspection and Repair Records	Y	
Part 1	Wastewater Throughput Limit (basis: cumulative increase)	N	
Part 2	Combined Wastewater and Storm Water Throughput Limit (basis: cumulative increase)	N	
Part 3	Record Keeping Requirements (basis: Regulation 8-8-501)	Y	

Table IV-F S-37, Dissolved Air Flotation

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Organic Compounds – Wastewater (Oil-Water) Separators		
Regulation 8, Rule 8	(6/15/94)		
8-8-112	Exemption, Wastewater Critical OC Concentration and/or	Y	
	Temperature		
8-8-113	Exemption, SeConditionary Wastewater Treatment Processes and	Y	
	Stormwater Sewer Systems		
8-8-303	Gauging and Sampling Devices	Y	
8-8-305	Oil-Water Separator and/or Air Flotation Unit Slop Oil Vessels	Y	
8-8-501	API Separator or Air Flotation Bypassed Wastewater Records	Y	
8-8-502	Wastewater Critical Organic Compound Concentration and/or	Y	
	Temperature Records		
8-8-503	Inspection and Repair Records	Y	

Table IV-F S-37, Dissolved Air Flotation

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Permit Conditions		
Condition #7938			
Part 1	Wastewater Throughput Limit (basis: cumulative increase)	N	
Part 2	Combined Wastewater and Storm Water Throughput Limit (basis:	N	
	cumulative increase)		
Part 3	Record Keeping Requirements	Y	
	(basis: Regulation 8-8-501)		

Table IV-G S-40, Wipe Cleaning, Facility-Wide

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds - Solvent Cleaning Operations (9/16/98)		
Regulation 8,			
Rule 16			
8-16-111	Exemption, Wipe Cleaning	Y	
8-16-304	Trichloroethylene Limitation	Y	
8-16-501	Solvent Records	Y	
8-16-501.1	Trichloroethylene Records	Y	
8-16-501.2	All Other Solvents Records	Y	
8-16-501.3	Annual Records of Type and Amount of Solvent Used for Wipe	Y	
	Cleaning		
BAAQMD Condition #8855	Permit Conditions		
Part 1	Net Annual General Solvent Usage Limit (basis: cumulative increase)	Y	
Part 2	Net Annual 1,1,1-Trichloroethane Usage Limit (basis: cumulative increase)	N	
Part 3	Record Keeping Requirements (basis: Regulation 8-16-501)	Y	

Table IV-H S-100, Sand Blast Facility

Applicable Requirement	Regulation Title or  Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
CA Title 17	State Provisions for Sandblasting	N	2400
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann No. 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
BAAQMD Condition #15870			
Part 1	Requirement for Baghouse (basis: Regulations 6-301 and 6-310)	Y	
Part 2	Baghouse Inspections (basis: Regulation 2-6-501)	Y	
Part 3	Recordkeeping (basis: Regulation 2-6-501)	Y	

### V. SCHEDULE OF COMPLIANCE

The permit holder shall continue to comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

### VI. PERMIT CONDITIONS

Any Condition that is preceded by an asterisk is not federally enforceable.

#### Condition #672

For S-9, S-10, Boilers Nos. 9 & 10

- 1a. Deleted Application 7180
- 1b. Deleted Application 7180
- 2. Deleted Application 7180
- 3. Deleted Application 7180
- 4. Deleted Application 7180
- 5. Deleted Application 7180
- 6. The Owner/Operator shall fire the S-9 and S-10, Boilers, exclusively on PUC quality natural gas. (Basis: District Regulation 2-1-301)
- 7. \*Subject to: (i) receipt of final, non-appealable California Public Utilities Commission approval of the Tolling Agreement for Units 6 and 7 at the Contra Costa Power Plant by and between Mirant Delta, LLC and Pacific Gas and Electric Company and dated as of September 2, 2009, as amended from time to time, without material condition or modification unacceptable to either party thereto in its sole discretion; and (ii) the receipt of all other approvals and consents from the relevant local, state and federal governmental agencies (including but not limited to the California Independent System Operator) necessary for the shutdown and permanent retirement from service of Units 6 and 7; Mirant Delta, LLC will shut down and permanently retire Units 6 and 7 from service at 2400 PDT on April 30, 2013. (Basis: Voluntary)

#### Condition #7938

For S-34, S-35, S-37, Oily Water Treatment System

- \*1. The Owner/Operator shall ensure that the total throughput of the wastewater treated at sources S-34, S-35 and S-37 does not exceed 32,000,000 gallons during any consecutive twelve-month period. (Basis: cumulative increase)
- \*2. The Owner/Operator shall ensure that the combined throughput of storm water and wastewater treated at sources S-34, S-35 and S-37 does not exceed

90,000,000 gallons during any consecutive twelve-month period. (Basis: cumulative increase)

- \*3. In order to demonstrate compliance with the Parts 1 and 2 above, the owner/operator of sources S-34, S-35 and S-37 shall maintain the following records in a District-approved log. These records shall be kept on site and made readily available for District inspection upon request. The records shall be kept for a period of at least five (5) years from the date on which a record is made. (Basis: Regulation 8-8-501)
  - a. Daily total throughput of wastewater and storm water, summarized on a monthly basis.
  - b. Daily throughput of wastewater, as calculated using District-approved procedures, and summarized on a monthly basis.
  - c. Daily hours of operation, summarized on a monthly basis.
  - d. Identification of days on which it rains in sufficient quantities so as to contribute storm water to the throughput of these sources.

#### Condition #8854

For S-33, Maintenance Coating Operation

- 1. The Owner/Operator shall not use more than 1100 gallons of coating in any consecutive 12-month period. (Basis: cumulative increase)
- 2. The Owner/Operator shall not use more than 400 gallons of cleanup solvent in any consecutive 12-month period. (Basis: cumulative increase)
- 3. The Owner/Operator shall maintain a log of all materials used in this operation. The log shall contain the following information: (Basis: Regulation 8-19-501)
  - a. quantities of each type of coating used with components and mix ratios listed if applicable,
  - b. substrate that each coating is applied to and the District Regulation that applies,
  - c. VOC content of each coating,
  - d. if a cleaning solvent is used log type and amount.

These records shall be kept on a daily basis in a District-approved log. These records shall be summarized on a monthly basis.

All records shall be retained for a period of at least five (5) years from the date of entry, and be made readily available to District Staff on request.

#### Condition #8855

For S-40, Wipe Cleaning Operation

1. The Owner/Operator shall ensure that the net solvent usage at this source shall not exceed 100 gallons in any consecutive 12-month period. (Basis: cumulative increase)

2\*. The Owner/Operator shall ensure that the net annual 1,1,1 Trichloroethane usage at this source shall not exceed 25 gallons in any consecutive 12-month period. (Basis: cumulative increase)

28

- 3. The Owner/Operator shall maintain a log of all materials used in this operation. The log shall contain the following information: (Basis: Regulation 8-16-501)
  - a. Quantities of each type of solvent used at this source
  - b. Quantities of each type of solvent recovered for disposal or recycling
  - c. Net usage of each type of solvent

These records shall be kept on a monthly basis in a District approved log. These records shall be summarized on a quarterly basis.

All records shall be retained for a period of at least five (5) years from the date of entry, and be made readily available to District Staff on request.

### Condition #15870 S-100, Sand Blast Facility

- 1. The Owner/Operator shall route all particulate matter emissions from S-100, Sand Blast Facility, to the A-100, Baghouse (Basis: Regulations 6-301 and 6-310)
- 2. The Owner/Operator shall inspect the baghouse at a minimum of every five (5) days of operation to ensure proper operation. The following items shall be checked:
  - a. The baghouse exhaust shall be checked for evidence of particulate breakthrough. If breakthrough is evident from plume observations, or dust buildup near the stack outlet, the filter bags shall be checked for any tears, holes, abrasions, and scuffs, and replaced as needed.
  - b. All hoppers shall be discharged in a timely manner.
  - c. The shaker cleaning system shall be maintained and operated at sufficient intervals to ensure proper collection per the manufacturer's instructions. (Basis: Regulation 2-6-501)
- 3. In order to demonstrate compliance with the above permit Conditions, the Owner/Operator shall maintain the following records in a District approved log. These records shall be kept on site and made readily available for District inspection upon request. The records shall be kept for a period of at least five years from the date on which a record is made.
  - a. Records of all inspections and all maintenance work including bag replacement for the baghouse. Records of each inspection shall consist of a log containing the date of inspection and the initials of the personnel that inspects the baghouses. (Basis: Regulation 2-6-501)

29

### **Condition #21996**

For S-20, Service Station

1. Pursuant to BAAQMD Toxic Section policy, this facility's annual throughput shall not exceed 20,000 gallons in any consecutive 12-month period. (Basis: Toxic Risk Policy)

# VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, using the following codes: annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), hourly (H), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

This section is only a summary of the limits and monitoring requirements. In the case of a conflict with any requirement in Sections I-VI, the preceding sections take precedence over Section VII.

Table VII-A S-9, Utility Boiler No. 9

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Opacity	BAAQMD 6-301	Y		Ringelmann No.1 during any 3 min/hr		N	
	BAAQMD 6-304	Y		Ringelmann No. 2 during tube cleaning		N	
FP	BAAQMD 6-310.3	Y		0.15 grains/dscf @ 6% O <sub>2</sub>		N	
PM	40 CFR 75	Y		None	40 CFR 75.14(c)	N	
SO <sub>2</sub>	BAAQMD 9-1-301	N		Ground Level Concentration of 0.5 ppm for 3 minutes or 0.25 ppm for 60 minutes or 0.05 ppm for 24 hours		N	
	BAAQMD 9-1-302	Y		300 ppmvd		N	
$SO_2$	40 CFR 75	Y		None	40 CFR 75	P/Q	Calculations

### Table VII-A S-9, Utility Boiler No. 9

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD 9-3-301	N		175 ppmv @ 3% O <sub>2</sub> (dry basis) for natural gas firing		С	CEM
	BAAQMD 9-11-302.1.1	Y		175 ppmv @ 3% O <sub>2</sub> (dry basis) for natural gas firing based on a clock hour average	BAAQMD 9-11-501, 503	С	CEM
NOx	BAAQMD 9-11-308	Y		0.28 lbs/MMBTU system-wide average over previous 30 days	BAAQMD 9-11-501, 503	С	CEM
	BAAQMD 9-11-309.1	N		0.037 lbs/MMBTU system-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
	BAAQMD 9-11-309.1	N	1/1/05	0.018 lbs/MMBTU System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
NOx	BAAQMD Condition #16327, part 3	N		0.037 lbs/MMBTU system-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
	BAAQMD Condition #16327, part 3	N	1/1/05	0.018 lbs/MMBTU System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
	40 CFR 75	Y		None	40 CFR 75	С	CEM
СО	BAAQMD 9-11-310.1	Y		400 ppmv @ 3% O <sub>2</sub> (dry basis) during steady state compliance tests	BAAQMD 9-11-501, 503	С	CEM
СО	BAAQMD 9-11-310.2	Y		1000 ppmv @ 3% O <sub>2</sub> (dry basis) during normal operation based on a clock hour average	BAAQMD 9-11-501, 503	С	CEM

### Table VII-A S-9, Utility Boiler No. 9

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Ammonia	BAAQMD	Y		10 ppmv	BAAQMD	P/Q	Quarterly
	9-11-311			@ 3% O <sub>2</sub> (dry basis)	9-11-402		Tests
				based on rolling 60			Upon
				minute average upon			Installation
				installation of an			of an
				applicable control			Applicable
				device			Control
							Device
Lead	BAAQMD 11-1-301	Y		6.75 kg/day		N	None
Lead	BAAQMD	Y		1.0 microgram/m <sup>3</sup>		N	None
	11-1-302			averaged over 24			
				hours			
$CO_2$	40 CFR 75	Y		None	40 CFR 75	С	CEM
							$(CO_2 \text{ or } O_2)$

Table VII-B S-10, Utility Boiler No. 10

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Opacity	BAAQMD 6-301	Y		Ringelmann No.1 during any 3 min/hr		N	
	BAAQMD 6-304	Y		Ringelmann No. 2 during tube cleaning		N	
FP	BAAQMD 6-310.3	Y		0.15 grains/dscf @ 6% O <sub>2</sub>		N	
PM	40 CFR 75	Y		None	40 CFR 75.14(c)	N	
$SO_2$	BAAQMD 9-1-301	N		Ground Level Concentration of 0.5 ppm for 3 minutes or 0.25 ppm for 60 minutes or 0.05 ppm for 24 hours		N	
	BAAQMD 9-1-302	Y		300 ppmvd		N	
	40 CFR 75	Y		None	40 CFR 75	P/Q	Calculations
NOx	BAAQMD 9-3-301	N		175 ppmv @ 3% O <sub>2</sub> (dry basis) for natural gas firing		С	CEM
	BAAQMD 9-11-302.1.1	Y		175 ppmv  @ 3% O <sub>2</sub> (dry basis)  for natural gas firing  based on a clock hour  average	BAAQMD 9-11-501, 503	С	CEM
NOx	BAAQMD 9-11-308	Y		0.28 lbs/MMBTU system-wide average over previous 30 days	BAAQMD 9-11-501, 503	С	CEM
	BAAQMD 9-11-309.1	N		0.037 lbs/MMBTU System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	СЕМ
	BAAQMD 9-11-309.1	N	1/1/05	0.018 lbs/MMBTU  System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM

### Table VII-B S-10, Utility Boiler No. 10

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD Condition #16327, part 3	N		0.037 lbs/MMBTU System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
	BAAQMD Condition #16327, part 3	N	1/1/05	0.018 lbs/MMBTU System-wide average on a clock hour basis	BAAQMD 9-11-501, 503	С	CEM
	40 CFR 75	Y		None	40 CFR 75	С	CEM
СО	BAAQMD 9-11-310.1	Y		400 ppmv  @ 3% O <sub>2</sub> (dry basis) during steady state compliance tests	BAAQMD 9-11-501, 503	С	CEM
CO	BAAQMD 9-11-310.2	Y		1000 ppmv  @ 3% O <sub>2</sub> (dry basis) during normal operation based on a clock hour average	BAAQMD 9-11-501, 503	С	CEM
Ammonia	BAAQMD 9-11-311	Y		10 ppmv  @ 3% O <sub>2</sub> (dry basis) based on rolling 60 minute average upon installation of an applicable control device	BAAQMD 9-11-402	P/Q	Source Test
Lead	BAAQMD 11-1-301	Y		6.75 kg/day		N	None
Lead	BAAQMD 11-1-302	Y		1.0 microgram/m <sup>3</sup> averaged over 24 hours		N	None
CO <sub>2</sub>	40 CFR 75	Y		None	40 CFR 75	С	CEM (CO <sub>2</sub> or O <sub>2</sub> )

Table VII-B S-20, Service Station

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD 8-7-301.1	Y		Installed and modified only if the system is 98% controlled or highest vapor recovery rate specified by CARB		Event	CARB Recertification
VOC	BAAQMD 8-7-301.6	Y		Leak Free and Vapor Tight on Phase I Equipment	BAAQMD 8-7-301.13	P/A	Source Test
VOC	BAAQMD 8-7-302.8	Y		Minimum liquid removal of 5ml/gal; 95% recovery of gasoline vapors		N	Pending on CARB Certification in 2008
VOC	BAAQMD 8-7-302.10	Y		Connector between riser and dispenser < 1 inch diameter		N	Visual Check
VOC	BAAQMD 8-7-302.12	Y		Liquid retain in nozzle < 100 ml/1000 gal		N	Pending on CARB Certification in 2008
VOC	BAAQMD 8-7-302.13	Y		Spitting from nozzle < 1 ml/nozzle		N	Pending on CARB Certification in 2008
Fuel Through- put	BAAQMD Condition #21966	N		20,000 gallons in any 12 consecutive months	BAAQMD 8-7-503	P/M	Records
VOC	BAAQMD 8-7-302.14.2	Y		Dynamic back pressure <0.15, 0.45, 0.95 inches of water when measured flow rate of 20, 60, and 100 CFH	BAAQMD 8-7-302.14	P/A	Source Test

# VII. Applicable Emission Limits & Compliance Monitoring Requirements

# Table VII-C S-33, Maintenance Coating Operation

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD	Y		Content of air dried	BAAQMD	P/E	Labeling &
	8-3-302			coating < 250 g/l	8-3-403		Records
	BAAQMD	Y		Content of coatings <	BAAQMD	P/E	Labeling &
	8-3-304			specified VOC content	8-3-403		Records
	BAAQMD	Y		Content of air dried	BAAQMD	P/E	Records
	8-19-302			coating < 2.8 lbs/gal	8-19-501		
	BAAQMD	Y		Content of coatings <	BAAQMD	P/E	Records
	8-19-312			specified VOC content	8-19-501		
Coating	BAAQMD	Y		1100 gallons	BAAQMD	P/E	Records
Usage	Condition			in any 12 consecutive	Condition		
	#8854, part 1			months	#8854, part 3		
Solvent	BAAQMD	Y		400 gallons	BAAQMD	P/E	Records
Usage	Condition			in any 12 consecutive	Condition		
	#8854, part 2			months	#8854, part 3		

# VII. Applicable Emission Limits & Compliance Monitoring Requirements

# Table VII-D S-34, Fixed Roof Oil Water surge Tank S-35, API Separator S-37, Dissolved Air Flotation (DAF)

Type of Limit	Limit Citation	FE Y/N	Future Effectiv e Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD	Y		1.0 ppm critical	N/A	P/	Sampling
	8-8-112			organic compounds		Semi-annual	
				@ 68 °F			
Wastewate	BAAQMD	Y		32,000,000 gallons	BAAQMD	P/E	Records
r	Condition			in any 12 consecutive	Condition		
throughput	#7938, part 1			months	#7938, part 3		
Wastewate	BAAQMD	Y		90,000,000 gallons	BAAQMD	P/E	Records
r	Condition			in any 12 consecutive	Condition		
And	#7938, part 2			months	#7938, part 3		
Stormwater							
throughput							

# VII. Applicable Emission Limits & Compliance Monitoring Requirements

Table VII-E S-40, Wipe Cleaning-Facility Wide

Type of Limit	Limit Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD	Y		Trichloroethylene	BAAQMD	P/E	Records
	8-16-304			usage $\leq$ 3.2 gallons	8-16-501		
				per day			
Solvent	BAAQMD	Y		100 gallons	BAAQMD	P/E	Records
Usage	Condition			in any 12 consecutive	Condition		
	#8855,			months	#8855, part 3		
	part 1						
1,1,1	BAAQMD	N		25 gallons	BAAQMD	P/E	Records
Trichloro-	Condition			in any 12 consecutive	Condition		
ethane	#8855, part			months	#8855, part 3		
	2						

Table VII-F S-100, Sand Blasting Facility

Type of Limit	Limit Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Opacity	BAAQMD	Y		Ringelmann 1 for 3	BAAQMD	P/every 5	Inspection
	6-301			minutes/hr	Condition	events	
					#15870, parts 1		
					and 2		
FP	BAAQMD	Y		No emissions from	BAAQMD	P/every 5	Inspection
	6-310			source > 0.15 grains	Condition	events	
				per dscf of gas	#15870, parts 1		
				volume	and 2		

# VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally referenced in Section 600 et. seq. of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VIII - Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

Table VIII
Test Methods

Applicable		
Requirement	<b>Description of Requirement</b>	Acceptable Test Methods
BAAQMD	Ringelmann No. 1 Limitation	Manual of Procedures, Volume 1, Evaluation of Visible
6-301		Emissions
BAAQMD	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates
6-310		Sampling or EPA Reference Method 5 (40 CFR 60,
		Appendix A), Determination of Particulate Emissions from
		Stationary Sources
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
8-3-302		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or
		Manual of Procedures, Volume III, Method 22,
		Determination of Compliance of Volatile Organic
		Compounds for Solvent Based Coatings
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
8-3-304		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or
		Manual of Procedures, Volume III, Method 22,
		Determination of Compliance of Volatile Organic
		Compounds for Solvent Based Coatings
BAAQMD	Phase II Vapor Recovery	Manual of Procedures, Volume IV, ST-27, Dynamic Back
8-7-302	Requirements	Pressure; ST-30, Vapor Tightness; ST-37, Liquid Removal;
		ST-39, Air to Liquid Volume Ratio; and ST-41, Liquid
		Retain and Spitting from Nozzles
BAAQMD	Gasoline Vapor Recovery	BAAQMD Manual of Procedures, Volume IV, ST-36,
8-7-301.2		Gasoline Dispensing Facility Phase I Volumetric Efficiency
BAAQMD	Wastewater (Oil-Water)	Manual Procedures, Volume III, Lab Method 33,
8-8-112	Separators; Exemption Wastewater	Wastewater Analysis for Critical Organic Compounds
	Critical Organic Compound	
	Concentration And/Or	
	Temperature	

# **VIII. Test Methods**

# Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
8-19-302		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or
		Manual of Procedures, Volume III, Method 22,
		Determination of Compliance of Volatile Organic
		Compounds for Solvent Based Coatings
		Manual of Procedures, Volume IV, ST-7 or EPA Method 25
		or 25A, Determination of Emissions of Volatile Organic
		Compounds.
		If EPA Method 25 or 25A is used, control device
		equivalency (if applicable) is determined as prescribed in 55
		FR 26865.
BAAQMD	VOC Limits	Manual of Procedures, Volume III, Method 21,
8-19-312		Determination of Compliance of Volatile Organic
		Compounds for Water Reducible Coatings or
		Manual of Procedures, Volume III, Method 22,
		Determination of Compliance of Volatile Organic
		Compounds for Solvent Based Coatings
		Manual of Procedures, Volume IV, ST-7 or EPA Method 25
		or 25A, Determination of Emissions of Volatile Organic
		Compounds.
		If EPA Method 25 or 25A is used, control device
		equivalency (if applicable is determined as prescribed in 55
		FR 26865
BAAQMD	General Emission Limitation	Manual of Procedures, Volume IV, ST-19 A or B, Sampling
9-1-302		and Analysis of Gas Streams; Manual of Procedures,
		Volume III, Method 10, Sulfur Content of Fuels
BAAQMD	Fuel Burning (Liquid and Solid	Manual of Procedures, Volume III, Method 10,
9-1-304	Fuels)	Determination of Sulfur in Fuel Oils.
BAAQMD	NOx Emissions for Units Rated at	District Manual of Procedures, Volume IV, ST-13A,
9-3-301	1.75 billion BTU Per Hour or	Determination of Nitrogen Oxides; ST-14, Determination of
	More	Oxygen; ST-5, Determination of Carbon Dioxide, ST-6

# **VIII. Test Methods**

# Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD	NOx Emissions from Utility	District Manual of Procedures, Volume IV, ST-13A,
9-11-302	Electric Power Generating Boilers,	Determination of Nitrogen Oxides; ST-14, Determination of
	Interim Compliance NOx Emission	Oxygen; ST-5, Determination of Carbon Dioxide, ST-6
	Limits for Boilers with a Rated	
	Heat Input Capacity Greater Than	
	or Equal to 1.75 billion BTU/hour	
BAAQMD	NOx Emissions from Utility	District Manual of Procedures, Volume IV, ST-13A,
9-11-302.1.1	Electric Power Generating Boilers,	Determination of Nitrogen Oxides; ST-14, Determination of
	Gaseous Fuel	Oxygen; ST-5, Determination of Carbon Dioxide, ST-6
BAAQMD	NOx Emissions from Utility	District Manual of Procedures, Volume IV, ST-13A,
9-11-302.1.2	Electric Power Generating Boilers,	Determination of Nitrogen Oxides; ST-14, Determination of
	Non-Gaseous Fuel	Oxygen; ST-5, Determination of Carbon Dioxide, ST-6
BAAQMD	NOx Emissions from Utility	District Manual of Procedures, Volume IV, ST-13A,
9-11-302.1.3	Electric Power Generating Boilers,	Determination of Nitrogen Oxides; ST-14, Determination of
	Gaseous Fuel and Non-Gaseous	Oxygen; ST-5, Determination of Carbon Dioxide
	Fuel	
BAAQMD	System-wide NOx Emission Rate	District Manual of Procedures, Volume IV, ST-13A,
9-11-308	Limit	Determination of Nitrogen Oxides; ST-14, Determination of
		Oxygen; ST-5, Determination of Carbon Dioxide
BAAQMD	Advanced Technology Alternative	District Manual of Procedures, Volume IV, ST-13A,
9-11-309	Emission Control Plan	Determination of Nitrogen Oxides; ST-14, Determination of
		Oxygen; ST-5, Determination of Carbon Dioxide
BAAQMD	System-wide NOx Emission Rate	District Manual of Procedures, Volume IV, ST-13A,
9-11-309.1	Limits	Determination of Nitrogen Oxides; ST-14, Determination of
		Oxygen; ST-5, Determination of Carbon Dioxide
BAAQMD	CO Emission Limits During	District Manual of Procedures, Volume IV, ST-6,
9-11-310.1	Steady-State Compliance Tests	Determination of Carbon Monoxide; ST-14, Determination
		of Oxygen; ST-5, Determination of Carbon Dioxide, ST-6,
BAAQMD	CO Emission Limits During	District Manual of Procedures, Volume IV, ST-6,
9-11-310.2	Normal Operations	Determination of Carbon Monoxide; ST-14, Determination
		of Oxygen; ST-5, Determination of Carbon Dioxide
BAAQMD	Ammonia Emission Limit for	District Manual of Procedures, Volume IV, ST-1B, EPA
9-11-311	Boilers with a Rated Heat Input	Method 350.3 and Determination of Ammonia, or
	Capacity Greater Than or Equal to	alternative method approved by the APCO
	250 million BTU/hour	
BAAQMD	Hazardous Pollutants, Lead, Daily	District Manual of Procedures, Volume IV, ST-9,
11-1-301	Emissions	Determination of Daily Emission Limits

# IX. REVISION HISTORY

Initial Issuance (Application 25774) September 14, 1998

Administrative amendments (Application 19626) April 1, 1999

Minor revision and administrative amendments: October 19, 2000

Addition of SCR for S10, Boiler

(Application 1119)

Renewal (Application 7180) August 19, 2005

Administrative amendments (Application 15335)

July 12, 2007

Administrative amendments (Application 22223) September 15, 2010

District added Part 7 to Condition 672 that requires Mirant to shut down Unit 6 and 7 (S-9 and S-10 upon receiving the required regulatory approvals. In addition, the District removed Condition No. 672, Part 2, from Table IV for S-10. This condition part was related to fuel oil combustion and has been deleted from the District permit.

# X. ACID RAIN PERMIT

### **Title IV Acid Rain Permit**

### Effective August 19, 2005 through August 18, 2010

#### **ISSUED TO:**

Mirant Delta, L.L.C. Contra Costa Power Plant P.O. Box 249 Antioch, CA 94509

#### **FACILITY SITE LOCATION:**

3201 Wilbur Avenue Antioch, CA 94509

### **ISSUED BY:**

Signed by Jean Roggenkamp for August 19, 2005

Jack Broadbent, Executive Officer/ Date
Air Pollution Control Officer

### **Nature of Business**

**Type of Facility:** Electric Generation

Primary SIC: 4911

### **DESIGNATED REPRESENTATIVE:**

Name: Ann M. Cleary

Title: President, Mirant California

Phone: (925) 427-3510

### **ALTERNATE DESIGNATED REPRESENTATIVE:**

Name: Lisa D. Johnson

Title: President, Mirant Mid-Atlantic

Phone: (310)-669-8020ACID RAIN PERMIT CONTENTS

# X. Acid Rain Permit

- 1. Statement of Basis
- 2. SO2 allowance allocated under this permit and NOx requirements for each affected unit.
- 3. Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements of Conditions.
- 4. The permit application submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in he application.

### 1. STATEMENT OF BASIS

Statutory and regulatory Authorities: In accordance with District Regulation 2, Rule 7 and Titles IV and V of the Clean Air Act, the Bay Area Air Quality Management District issues this permit pursuant District Rule Regulation 2, Rule 7.

### 2. SO2 ALLOWANCE ALLOCATIONS

	Year	2005	2006	2007	2008	2009
	SO <sub>2</sub> allowances	285*	285*	285*	285*	285*
	under Tables 2, 3, or					
	4 of 40 CFR Part 73					
BOILER 9	NOx Limit	This unit is	not subject t	o the NOx re	equirements	from 40
BAAQMD		CFR Part 7	6 as this unit	is not capab	le of firing o	n coal.
S-9						

	Year	2005	2006	2007	2008	2009
	SO <sub>2</sub> allowances	285*	285*	285*	285*	285*
	under Tables 2, 3, or					
	4 of 40 CFR Part 73					
BOILER 10	NOx Limit	This unit is	s not subject to	o the NOx re	equirements	from 40
BAAQMD		CFR Part 7	6 as this unit	is not capab	le of firing o	n coal.
S-10						

<sup>\*</sup> The number of allowances actually held by an affected source in a unit account may differ from the number allocated by USEPA and would not require a revision to the unit SO<sub>2</sub> allowance allocations identified in this permit.

# X. Acid Rain Permit

3.	COMMENTS.	NOTES AND	<b>JUSTIFICATIONS</b>
J.		HOLED AND	

None

# 4. PERMIT APPLICATION

None

46

### XI. GLOSSARY

#### **ACT**

Federal Clean Air Act

#### **AB 2588**

California Assembly Bill 2588 (Air Toxic "Hot Spots" Program)

#### **APCO**

Air Pollution Control Officer

#### **ASTM**

American Society for Testing and Materials

#### **BAAQMD**

Bay Area Air Quality Management District

#### **BACT**

Best Available Control Technology

### **CAA**

The federal Clean Air Act

### **CAAQS**

California Ambient Air Quality Standards

#### **CEM**

Continuous Emission Monitoring System

### **CEQA**

California Environmental Quality Act

#### CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

#### CMS

Continuous Monitoring System

### CO

Carbon Monoxide

#### COM

Continuous Opacity Monitor

#### **Cumulative Increase**

The sum of permitted emissions from each new or modified source since a specified date. Used to determine whether threshold-based requirements are triggered.

### **District**

The Bay Area Air Quality Management District

#### **EPA**

The federal Environmental Protection Agency.

#### **Excluded**

Not subject to any District Regulations.

#### Federally Enforceable, FE

All limitations and Conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPS), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and Conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

#### FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

#### FR

Federal Register

#### **GDF**

Gasoline Dispensing Facility

#### **GLC**

**Ground Level Concentration** 

#### Grain

1/7000 of a pound

#### **HAP**

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by both 40 CFR Part 63, and District Regulation 2, Rule 5.

### **Major Facility**

A facility with potential emissions of regulated air pollutants greater than or equal to 100 tons per year, greater than or equal to 10 tons per year of any single hazardous air pollutant, and/or greater than or equal to 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined by the EPA administrator.

#### **MFR**

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

#### **MOP**

The District's Manual of Procedures.

#### N/A

Not applicable

#### NAAQS

National Ambient Air Quality Standards

#### NESHAPS

National Emission Standards for Hazardous Air Pollutants. Contained in 40 CFR Part 61.

#### NMHC

Non-methane Hydrocarbon.

#### **NOx**

Oxides of nitrogen.

#### **NSPS**

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

#### **NSR**

New Source Review. A federal program for preconstruction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

#### **Offset Requirement**

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any onsite contemporaneous emission reduction credits. Applies to emissions of POC, NOx, PM10, and SO2.

#### **Phase II Acid Rain Facility**

A facility that generates electricity for sale through fossil-fuel combustion and by virtue of certain other characteristics (defined in Regulation 2, Rule 6) is subject to Titles IV and V of the Clean Air Act.

#### **POC**

**Precursor Organic Compounds** 

49

PM

**Total Particulate Matter** 

#### **PM10**

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

#### **PSD**

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

#### **SCR**

A "selective catalytic reduction" unit is an abatement device that reduces NOx concentrations in the exhaust stream of a combustion device. SCRs utilize a catalyst, which operates at a specific temperature range, and injected ammonia to promote the conversion of NOx compounds to nitrogen gas.

#### SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Ambient Air Quality Standards. Mandated by Title I of the Act.

### **SO2**

Sulfur dioxide

### Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

#### **TRMP**

Toxic Risk Management Plan

### **TSP**

**Total Suspended Particulate** 

#### **VMS**

Branched, cyclic, or linear completely methylated siloxane

### VOC

Volatile Organic Compounds

### **Units of Measure:**

bhp brake-horsepower Btu British thermal unit = g = grain, when referring to particulate; gram when referring to VOC gr = gallon gal horsepower hp = hour hr = lb pound inches in = maximum max  $m^2$ square meter minute min = MM million parts per million, by volume ppmv = parts per million, by weight ppmw pounds per square inch, absolute psia

> pounds per square inch, gauge standard cubic feet per minute

= yr year

=

psig

scfm

# XII. ACID RAIN PERMIT APPLICATION