

BAY AREA

AIR QUALITY

MANAGEMENT

DISTRICT

Mr. Gerardo Rios
Permits Office Chief
United States Environmental Protection Agency Region 9
Air-3-1
75 Hawthorne Street
San Francisco, CA 94105

Dear Mr. Rios:

ALAMEDA COUNTY John J. Bauters Juan González David Haubert Nate Miley

CONTRA COSTA COUNTY

Ken Carlson

John Gioia

David Hudson

Mark Ross

MARIN COUNTY

Katie Rice

NAPA COUNTY Joelle Gallagher

SAN FRANCISCO COUNTY
Tyrone Jue
(SF Mayor's Appointee)
Shamann Walton

SAN MATEO COUNTY Noelia Corzo

Davina Hurt (Chairperson) Ray Mueller

SANTA CLARA COUNTY Margaret Abe-Koga

Otto Lee Sergio Lopez Vicki Veenker

SOLANO COUNTY Erin Hannigan Steve Young

SONOMA COUNTY
Brian Barnacle
Lynda Hopkins
(Vice Chairperson)

Dr. Philip M. Fine

EXECUTIVE OFFICER/APCO
PL:EG:myl

Connect with the Bay Area Air District:







The purpose of this letter is to issue a revision to the synthetic minor permit for Richmond Products Terminal located at 1306 Canal Street, Richmond, CA 94804 (Site ID A0057). As requested by the facility, the Synthetic Minor Permit Condition #19942 has been updated to allow for the storage and transfer of Biodiesel and/or Renewable Diesel, including:

- Convert S-24 (Tank No. 24) & S-25 (Tank No. 25) from permitted floating roof tanks storing gasoline to fixed roof tanks storing renewable diesel and biodiesel fuels only. S-24 and S-25 will change status from permitted tanks to exempt tanks under Regulation 2-1-123.3.2.
- Alter the conditions for S-75 (Tank No. 57) to allow for the storage of Biodiesel and Renewable Diesel in addition to Ethanol/Jet A.
- Alter the Loading Rack 1 (S-1) to reactivate two previously exempt arms for the handling of Biodiesel and Renewable Diesel.

The revision is effective as of the date of this letter. Copies of the permit evaluation (Application #32039) and revised Permit Condition #19942 are enclosed.

The Air District will also notify the California Air Resources Board and the facility in writing of this permit action.

If you have any questions regarding this matter, please call Eric Grulke, Senior Air Quality Engineer, at (415) 749-8672.

Sincerely yours,

Pamela Leong

Digitally signed by Pamela Leong DN: cn=Pamela Leong, o, ou, email=pleong@baaqmd.gov, c=US Date: 2024.03.27 14:38:54 -07'00'

Pamela Leong

Director of Engineering Division

FL.EG.IIIy

Enclosure

Spare the Air