

January 27, 2011

2012 JUN 30 PM 1 17  
RECEIVED  
BAY AREA AIR QUALITY  
MANAGEMENT DISTRICT

Brian Bateman  
Director of Compliance and Enforcement  
Bay Area Air Quality Management District  
939 Ellis Street  
San Francisco, CA 94109

Dear Mr. Bateman:

RE: Semi-Annual Major Facility Review (Title V) Monitoring Report for EBMUD  
Main Wastewater Treatment Plant (Facility #A0591)

Attached is the semiannual monitoring report for East Bay Municipal Utility District's (EBMUD) Main Wastewater Treatment Plant (Facility #A0591) as required under Section I.F of the facilities Major Facility Review Permit issued July 26, 2005 (the renewal application was submitted by EBMUD on December 30, 2010). The report covers the period from July 1 through December 31, 2011.


As indicated by the attached report, the Main Wastewater Treatment Plant was in compliance with all Title V requirements except for the following:

- 1) EBMUD measured hydrogen sulfide (H<sub>2</sub>S) in the digester gas used to fuel S-38 and the other cogeneration engines at a level exceeding the permit limit (condition #18860) on August 8, 2011. The incident resulted in the issuance of Notice of Violations (NOV) A50766.

I certify to the best of my knowledge that the attached report is true, accurate and complete.

If you have any questions, please call Robert Newman at (510) 287-0509.

Sincerely,



DAVID R. WILLIAMS

DRW:RDN:kf

w:\ops\wtid - admin\regulatory compliance\mwwtp\air compliance\2012\wt12\_003.0.doc

**Major Facility Review (Title V)  
Semi-Annual Monitoring Report**

**for**

**East Bay Municipal Utility District's  
Main Wastewater Treatment Plant  
Facility #A0591**

**Reporting Period: July 1, 2011 through December 31, 2011**

Source	Monitoring Requirement	Limit	Monitoring Results
S-55 Boiler	<p><b>Condition # 20651</b></p> <p>2. Shall not operate S-55 hot water boiler simultaneously with more than two of the three cogeneration engines.</p> <p>3. Boiler Gross Heat input shall not exceed 20.41 MMBtu/hr</p> <p>19. Annual performance test for these limits:</p> <p>5. Emissions limits</p> <p>16. Weekly fuel gas monitoring for sulfur content</p> <p>18. Recordkeeping</p>	<p>NOx 30 ppm CO 50 ppm</p> <p>H2S 340 ppm</p>	<p>Boiler was only operated simultaneously with more than two engines a couple of times during short term engine testing (see attachment 2 comments). <b>See Table 2 attached.</b></p> <p>Maximum theoretical input is 20 MMBtu/hr with a high calculated value of 10.8.</p> <p>Boiler was source tested on November 22, 2011. Results were in compliance with permit limits and are included with this report.</p> <p>Daily sampling conducted using Portable Instrument. Exceeded the permit limit on August 8 (444 ppm),</p> <p><b>See ATTACHMENT E.</b></p> <p><b>See Table 2 attached.</b></p>
S-37, S-38, S-39 Cogeneration Engines	<p><b>Condition # 18860</b></p> <p>4. Sulfur content of digester gas</p> <p>Weekly sampling and testing of digester gas for H2S</p>	<p>&lt; 340 ppmv</p>	<p>Daily sampling conducted using Portable Instrument. Exceeded the permit limit on August 8 (444 ppm),</p> <p><b>See ATTACHMENT E.</b></p>

Source	Monitoring Requirement	Limit	Monitoring Results
	<p><b>Condition # 20651</b></p> <p>18. Maintain daily records of hours of engine operation, diesel and gas consumption to verify compliance with:</p> <p>13. Thermal throughput</p> <p>14. Hours of operation</p> <p>15. Diesel consumption</p>	<p>25 MMBtu/hr</p> <p>26,280 hours in 365-day period</p> <p>150,000 gal in 365-day period</p>	<p>Engine operational records are attached as <b>Table 3</b>.</p> <p>The measured volumes based on an estimated HHV digester gas had a maximum of <u>25</u> MMBtu based on revised throughput estimates.</p> <p>Total of 8,653 hours from Jul 1, 2011 to Dec 31, 2011. (17,636 for last 12 months)</p> <p>Total for Jan – June 2011 was <u>12,983</u> gallons. Total for June – Dec 2011 was <u>39,638</u> gallons. 2011 Total: 52,621 gallons</p>
	<p><b>Condition # 20651</b></p> <p>17. Sulfur content of diesel fuel</p> <p>Certification statement by vendor</p>	<p>CARB diesel standards</p>	<p>All diesel fuel met CARB standards. Vendor certifications included as <b>Attachment A</b>.</p>
	<p><b>Condition # 20651</b></p> <p>19. Annual performance test for these limits:</p> <p>10. NOx emissions</p> <p>11. CO emissions</p>	<p>140 ppmv</p> <p>2000 ppmv</p>	<p>S-37: BAAQMD source test on 4/27/11. Blue Sky Environmental on 3/8/11. S-39: BAAQMD source test on 3/16/11 and by Blue Sky Environmental on 3/08/11. S-38: Blue Sky Environmental on 3/8/11.</p> <p>All results were within permit limits.</p>

Source	Monitoring Requirement	Limit	Monitoring Results
S-38 Cogeneration Engine	<b>Condition # 20651</b> 19. Annual performance test for these limits:  6. NOx emissions 7. CO emissions 8. POC emissions 9. PM emissions	1.25 g/bhp-hr 3.0 g/bhp-hr 0.6 g/bhp-hr 0.085 g/bhp-hr	
	<b>Condition # 20651</b> 16. Weekly fuel gas monitoring for sulfur content	340 ppmv	Daily sampling conducted using Portable Instrument. Exceeded the permit limit on August 8 (444 ppm),  <b>See ATTACHMENT E.</b>
S-48 Gasoline Dispensing Facility	<b>Condition # 16516</b> The Static Pressure Performance Test (Leak Test) ST-38 shall be successfully conducted at least once in each twelve consecutive month period.		Source test performed on 9/24/11.
	<b>Condition # 21663</b> Annual gasoline throughput	334,000 gal per year	See Table 8 attached. Throughput limits were met with 28,003 gallons used over the last 12 months.
S-49 Portable Stand-by Generator	<b>Condition #19058</b> 4. Diesel sulfur content	0.5%	All diesel fuel met CARB standards. Vendor certifications included as <b>Attachment A.</b>
	7. Hours of operation logged.	72 hours within 1000 feet of school	See Table 4 attached.
S-50 Stand-by Generator	<b>Condition #22830</b> 1. Hours of operation	30 hours per year reliability-related testing	See Table 4 attached. Limits on hours were met.

Source	Monitoring Requirement	Limit	Monitoring Results
S-51 Stand-by Generator	Condition #22850 1. Hours of operation	50 hours per year reliability- related testing	See Table 4 attached. Limits on hours were met.
S-52 Stationary Stand-by Generator	Condition #19184 4. Diesel sulfur content  8. Hours of operation logged.	0.5%  72 hours within 1000 feet of school	All diesel fuel met CARB standards. Vendor certifications included as Attachment A.  See Table 4 attached.
S-53 Stand-by Generator	Condition #22830 1. Hours of operation	30 hours per year reliability- related testing	See Table 4 attached. Limits on hours were met.
S-54 Stand-by Generator	Condition #22850 1. Hours of operation	50 hours per year reliability- related testing	See Table 4 attached. Limits on hours were met.
S-56 Turbine (Started Operation on Nov 11, 2011)	Condition #24050 2. 389,820 MM Btu yr 3. Annual Testing for NOx 4. Annual Testing for CO 5. Annual Testing for SO2 8. Monthly Monitoring	23 ppm 100 ppm 100 ppmv	S-56 Source tested by Blue Sky Env on 12/15/11.  All results were within permit limits.
S-100 Municipal Wastewater Treatment Plant	Condition #22850 Total wastewater flow	120 MGD monthly avg. (330 MGD in wet weather)	See Annual Summary from Self-Monitoring Reports submitted to Regional Water Board, included as Attachment C. Limits were met with a 69 MGD monthly average.

Source	Monitoring Requirement	Limit	Monitoring Results
<b>S-110 Headworks</b>  <b>A-461 and A-462 Carbon Bed Scrubbers</b>	<b>Condition #17335</b>  3. Inlet and outlet H <sub>2</sub> S concentrations, as well as any other appropriate operating parameters shall be continuously monitored and reviewed on a daily basis to determine when carbon adsorption bed breakthrough is imminent or has been reached.		<b>See Table 5 attached.</b>
<b>S-170 Sludge-handling</b>	<b>Condition #18006</b>  1. Monitor and record on a daily basis the activated sewage sludge throughput through S-170.		<b>See Table 6 attached.</b>
<b>S-180 Anaerobic Digesters</b>	<b>Condition #18860</b>  2. Monthly digester visual inspection   4. Digester Gas sulfide content         5. Hours of flaring per day	340 ppmv	<b>See Table 7 attached.</b>   Daily sampling conducted using Portable Instrument. Exceeded the permit limit on August 8, 2011 (444 ppm), See <b>ATTACHMENT E.</b>         <b>See Attachment D</b>

**TABLE 1 -- Digester Gas H2S Monitoring**

**Digester H2S Readings**

Date	H2S (ppmv)	Date	H2S (ppmv)	Date	H2S (ppmv)	Date	H2S (ppmv)
7/1/2011	226	8/15/2011	95	9/29/2011	152	11/13/2011	0
7/2/2011	204	8/16/2011	106	9/30/2011	164	11/14/2011	0
7/3/2011	160	8/17/2011	99	10/1/2011	170	11/15/2011	0
7/4/2011	216	8/18/2011	100	10/2/2011	146	11/16/2011	0
7/5/2011	214	8/19/2011	108	10/3/2011	154	11/17/2011	0
7/6/2011	266	8/20/2011	112	10/4/2011	161	11/18/2011	0
7/7/2011	171	8/21/2011	110	10/5/2011	152	11/19/2011	0
7/8/2011	161	8/22/2011	115	10/6/2011	141	11/20/2011	0
7/9/2011	168	8/23/2011	62	10/7/2011	114	11/21/2011	0
7/10/2011	169	8/24/2011	74	10/8/2011	177	11/22/2011	0
7/11/2011	157	8/25/2011	54	10/9/2011	137	11/23/2011	0
7/12/2011	161	8/26/2011	76	10/10/2011	191	11/24/2011	0
7/13/2011	99	8/27/2011	88	10/11/2011	155	11/25/2011	0
7/14/2011	147	8/28/2011	88	10/12/2011	139	11/26/2011	0
7/15/2011	200	8/29/2011	112	10/13/2011	191	11/27/2011	0
7/16/2011	159	8/30/2011	129	10/14/2011	266	11/28/2011	0
7/17/2011	284	8/31/2011	124	10/15/2011	200	11/29/2011	0
7/18/2011	125	9/1/2011	131	10/16/2011		11/30/2011	0
7/19/2011	163	9/2/2011		10/17/2011	128	12/1/2011	0
7/20/2011	278	9/3/2011	190	10/18/2011	130	12/2/2011	0
7/21/2011	158	9/4/2011	189	10/19/2011	131	12/3/2011	0
7/22/2011	242	9/5/2011	195	10/20/2011	146	12/4/2011	0
7/23/2011	220	9/6/2011	108	10/21/2011	185	12/5/2011	0
7/24/2011	222	9/7/2011	149	10/22/2011	193	12/6/2011	0
7/25/2011	206	9/8/2011	138	10/23/2011	165	12/7/2011	0
7/26/2011	164	9/9/2011	128	10/24/2011	133	12/8/2011	0
7/27/2011	181	9/10/2011	192	10/25/2011	195	12/9/2011	0
7/28/2011	216	9/11/2011	165	10/26/2011	164	12/10/2011	0
7/29/2011	169	9/12/2011	120	10/27/2011	179	12/11/2011	0
7/30/2011	192	9/13/2011	155	10/28/2011	119	12/12/2011	0
7/31/2011	160	9/14/2011	162	10/29/2011	134	12/13/2011	0
8/1/2011	220	9/15/2011	148	10/30/2011	120	12/14/2011	0
8/2/2011	200	9/16/2011	170	10/31/2011	112	12/15/2011	0
8/3/2011	222	9/17/2011	195	11/1/2011	0	12/16/2011	0
8/4/2011	229	9/18/2011	160	11/2/2011	0	12/17/2011	0
8/5/2011	246	9/19/2011	111	11/3/2011	0	12/18/2011	0
8/6/2011	264	9/20/2011	137	11/4/2011	0	12/19/2011	0
8/7/2011	294	9/21/2011	186	11/5/2011	0	12/20/2011	0
8/8/2011	276	9/22/2011	166	11/6/2011	0	12/21/2011	0
8/9/2011	276	9/23/2011	154	11/7/2011	0	12/22/2011	0
8/10/2011	165	9/24/2011	170	11/8/2011	0	12/23/2011	0
8/11/2011	188	9/25/2011	144	11/9/2011	0	12/24/2011	0
8/12/2011	165	9/26/2011	147	11/10/2011	0	12/25/2011	0
8/13/2011	108	9/27/2011	163	11/11/2011	0	12/26/2011	0
8/14/2011	108	9/28/2011	82	11/12/2011	92	12/27/2011	0
						12/28/2011	0
						12/29/2011	0
						12/30/2011	0
						12/31/2011	0



**TABLE 2**

**ENGINE & BOILER RUN TIMES**



Month: July - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated			Total KWH	Biogas Used			Boiler	Fuel Oil Used			Hours of Operation				Total Hrs	
	Gen. 1	Gen. 2	Gen. 3		Eng. 1	Eng. 2	Eng. 3		Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler		
1	48,927	48,927	48,927	146,780	899,672	899,672	899,672	0	32	29	41	24	24	24	0	72	
2	49,067	49,067	49,067	147,200	917,778	917,778	917,778	0	32	37	37	24	24	24	0	72	
3	46,198	28,874	46,198	121,270	744,315	448,656	744,315	91,181	35	27	37	24	14	24	9	72	
4	28,350	0	48,600	76,950	542,306	0	996,073	259,306	21	0	37	13	0	24	23	60	
5	0	37,996	47,994	85,990	0	731,463	927,207	264,639	5	56	44	0	19	24	24	67	
6	19,233	19,233	19,233	57,700	60,658	64,581	60,054	358,081	49	29	36	10	11	10	14	45	
7	49,047	49,047	49,047	147,140	904,570	904,570	904,570	0	37	34	49	24	24	24	0	72	
8	51,850	51,850	51,850	155,550	916,740	916,740	916,740	0	29	39	50	24	24	24	0	72	
9	49,130	49,130	49,130	147,390	1,130,901	1,130,901	1,130,901	0	39	36	40	24	24	24	0	72	
10	14,831	44,494	44,494	103,820	281,484	914,980	914,980	207,360	16	36	38	7	24	24	17	72	
11	29,670	0	29,670	59,340	726,690	42,627	768,641	230,081	80	12	6	18	1	19	17	55	
12	52,913	55,214	55,214	163,340	841,250	830,142	841,250	4,607	40	41	43	24	24	24	0	72	
13	49,526	49,526	47,463	146,515	779,709	779,709	747,652	3,729	34	34	13	24	24	23	0	71	
14	47,474	49,538	49,538	146,550	773,752	796,131	796,131	0	42	37	50	23	24	24	0	70	
15	51,680	51,680	51,680	155,040	939,779	939,779	939,779	0	30	35	49	24	24	24	0	72	
16	49,359	49,359	39,076	137,795	756,267	756,267	600,287	72,482	35	29	45	24	24	19	5	72	
17	47,725	9,943	9,943	67,610	951,534	215,417	173,787	405,993	36	46	30	24	5	4	19	53	
18	43,791	40,142	10,948	94,880	868,769	816,884	239,515	276,232	31	50	36	24	23	7	17	71	
19	46,123	46,123	46,123	138,370	937,729	937,729	916,239	5,154	35	68	60	24	24	23	0	72	
20	49,018	49,018	49,018	147,055	903,257	903,257	903,257	0	30	49	51	24	24	24	0	72	
21	46,232	46,232	46,232	138,695	1,162,133	1,162,133	1,162,133	0	35	37	52	24	24	24	0	72	
22	49,020	49,020	49,020	147,060	1,186,315	1,186,315	1,186,315	0	32	34	46	24	24	24	0	72	
23	49,013	49,013	49,013	147,040	986,628	986,628	986,628	0	32	31	43	24	24	24	0	72	
24	3,959	7,917	47,504	59,380	76,536	202,986	958,361	359,846	2	29	40	2	5	24	21	52	
25	14,850	0	44,550	59,400	333,175	0	971,197	383,879	27	2	41	8	0	24	24	56	
26	50,573	18,965	50,573	120,110	844,855	305,673	844,855	206,869	28	46	42	24	9	24	15	72	
27	49,518	47,455	49,518	146,490	737,500	704,210	735,452	4,838	38	48	60	24	23	24	0	71	
28	35,245	46,993	46,993	129,230	518,598	702,522	702,522	80,014	36	31	44	18	24	24	6	71	
29	2,096	50,297	50,297	102,690	35,522	930,020	930,020	283,588	24	35	41	1	24	24	23	72	
30	0	47,120	47,120	94,240	0	929,276	929,276	299,210	0	35	37	0	24	24	24	72	
31	9,361	22,466	44,933	76,760	184,885	440,591	902,491	356,213	21	22	42	5	12	24	24	65	
Totals	1,133,778	1,164,638	1,368,964	3,667,380	20,943,304	21,497,638	25,648,077	4,153,302	962	1,077	1,277	561	577	681	283	2,102	
	Sum of Engines			3,667,380	Sum of Engines			68,089,019	Sum of Engines			3,316	Sum of Engines				1,819



Month: August - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated				Biogas Used				Fuel Oil Used			Hours of Operation				
	Gen. 1	Gen. 2	Gen. 3	Total KWh	Eng. 1	Eng. 2	Eng. 3	Boiler	Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler	Total Hrs
1	31,042	0	51,422	82,464	569,134	0	903,586	365,664	71	3	39	15	0	24	24	63
2	37,551	0	38,624	76,175	644,691	0	641,803	361,322	37	0	37	19	0	19	23	60
3	46,694	20,514	49,775	116,983	782,704	379,750	803,078	215,246	46	69	68	23	11	24	13	71
4	43,300	40,985	45,544	129,830	728,150	714,960	737,492	17,232	45	71	63	22	22	22	1	67
5	49,648	47,011	51,444	148,103	833,981	833,981	833,981	0	30	38	50	24	24	24	0	72
6	48,810	46,594	50,501	145,905	821,000	821,000	821,000	0	36	37	52	24	24	24	0	72
7	33,777	301	48,822	82,899	619,888	7,545	835,804	373,658	30	5	49	18	0	24	24	66
8	19,567	25,686	49,423	94,676	386,537	489,302	840,806	248,637	46	50	45	11	14	24	13	62
9	47,316	47,094	48,998	143,398	808,294	808,294	808,294	0	38	30	38	24	24	24	0	72
10	50,596	47,647	52,256	150,499	847,601	847,601	847,601	0	34	38	40	24	24	24	0	72
11	51,023	47,739	52,801	151,562	853,740	853,740	853,740	0	34	38	41	24	24	24	0	72
12	51,179	47,829	52,837	151,845	855,375	855,375	855,375	0	35	35	39	24	24	24	0	72
13	51,193	47,872	25,942	125,007	799,298	799,298	391,323	134,031	30	32	33	24	24	12	9	69
14	48,855	46,052	624	95,531	689,050	680,437	13,877	309,499	39	41	16	24	24	0	24	72
15	47,885	4,153	49,117	101,156	813,738	76,288	813,738	271,761	34	29	53	24	2	24	21	72
16	49,012	37,980	49,163	136,155	818,120	654,837	818,120	6,422	32	46	45	24	19	24	0	68
17	48,399	47,381	47,908	143,688	806,251	806,251	806,251	0	38	33	41	24	24	24	0	71
18	48,557	47,774	48,335	144,666	812,588	812,588	812,588	0	28	40	39	24	24	24	0	72
19	48,588	47,899	48,477	144,964	812,497	812,497	812,497	0	52	37	44	24	24	24	0	72
20	41,851	47,186	47,685	136,721	717,899	808,901	808,901	45,025	31	32	20	21	24	24	3	72
21	0	14,815	46,931	61,747	0	333,712	911,851	440,995	0	59	37	0	9	24	24	57
22	27,285	140	47,789	75,214	487,616	7,674	850,081	394,942	74	23	42	14	0	24	23	61
23	48,554	17,280	47,659	113,493	800,398	306,263	800,398	216,566	32	36	35	24	9	24	15	72
24	47,443	47,873	49,382	144,697	815,944	815,944	815,944	0	39	35	32	24	24	24	0	72
25	47,692	47,353	48,979	144,024	811,810	811,810	811,810	0	32	27	39	24	24	24	0	72
26	47,151	47,739	48,170	143,061	804,718	804,718	804,718	0	38	36	42	24	24	24	0	72
27	46,268	35,463	47,843	129,574	795,441	599,895	795,441	72,736	30	30	43	24	18	24	4	70
28	45,869	0	47,665	93,553	793,020	0	793,020	338,646	38	0	41	24	0	24	23	71
29	47,779	17,626	23,570	88,975	721,756	293,135	361,634	261,804	35	40	54	24	10	12	16	62
30	47,480	47,848	47,505	142,832	809,373	809,373	782,394	0	34	38	63	24	24	23	0	71
31	46,077	46,184	49,575	141,837	800,087	799,520	815,375	0	3	20	43	24	24	24	0	71
<b>Totals</b>	<b>1,346,441</b>	<b>1,020,008</b>	<b>1,414,787</b>	<b>3,781,235</b>	<b>22,660,701</b>	<b>17,644,693</b>	<b>23,602,521</b>	<b>4,074,165</b>	<b>1,122</b>	<b>1,049</b>	<b>1,325</b>	<b>670</b>	<b>521</b>	<b>688</b>	<b>262</b>	<b>2,141</b>
	<b>Sum of Engines</b>	<b>3,781,236</b>			<b>Sum of Engines</b>	<b>63,907,915</b>			<b>Sum of Engines</b>	<b>3,496</b>		<b>Sum of Engines</b>	<b>1,879</b>			



Month: September - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated				Biogas Used				Fuel Oil Used			Hours of Operation				
	Gen. 1	Gen. 2	Gen. 3	Total KWh	Eng. 1	Eng. 2	Eng. 3	Boiler	Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler	Total Hrs
1	48,570	47,776	48,982	145,328	670,643	670,643	657,137	0	410	336	596	24	24	24	0	72
2	48,638	47,842	50,504	146,984	703,789	703,789	703,789	0	167	380	392	24	24	24	0	72
3	48,566	47,828	50,518	146,912	703,807	703,807	703,807	0	323	172	441	24	24	24	0	72
4	32,304	43,424	44,401	120,129	461,497	617,617	614,614	99,561	356	325	476	18	24	24	6	72
5	0	46,719	2,788	49,507	589,768	42,185	451,939	0	397	349	349	0	24	24	2	50
6	0	46,719	30,663	77,383	709,355	442,851	305,989	0	453	431	389	0	24	24	15	63
7	0	47,604	50,450	98,053	795,593	795,593	736,784	357,399	0	580	621	0	24	24	24	72
8	0	46,969	49,577	96,546	733,710	733,710	736,784	357,399	0	296	516	0	24	24	24	72
9	0	47,652	50,447	98,099	788,344	788,344	786,428	383,642	0	375	386	0	24	24	24	72
10	0	47,362	50,074	97,436	786,428	786,428	714,020	398,701	12	375	386	0	24	24	24	72
11	0	32,470	46,449	78,919	529,069	529,069	415,250	415,250	0	444	467	0	18	24	22	64
12	0	4,599	49,249	53,847	84,360	820,803	483,747	483,747	0	175	529	0	2	24	22	48
13	0	42,647	48,062	90,709	653,871	697,862	373,771	373,771	0	595	713	0	22	23	22	67
14	0	47,577	50,471	98,048	787,421	787,421	432,072	432,072	0	346	471	0	24	24	24	72
15	0	45,754	49,930	95,684	750,138	768,824	390,205	390,205	0	464	438	0	23	24	23	70
16	0	47,419	50,273	97,691	785,415	785,415	398,364	398,364	0	365	441	0	24	24	24	72
17	0	46,240	47,111	93,351	670,646	671,594	397,399	397,399	0	665	875	0	24	24	24	71
18	0	47,135	48,679	95,814	789,583	789,583	360,743	360,743	0	226	364	0	24	24	24	72
19	0	43,787	45,035	88,822	721,744	721,744	343,665	343,665	0	549	104	0	24	24	24	72
20	0	44,940	45,501	90,441	673,964	673,964	352,898	352,898	24	409	824	0	23	23	24	71
21	0	30,605	36,818	67,423	458,880	548,134	398,512	398,512	24	431	532	0	16	19	24	58
22	0	28,889	47,040	75,929	455,208	729,955	378,621	378,621	19	483	476	0	15	24	23	62
23	0	43,507	47,714	91,221	695,036	742,472	377,298	377,298	0	597	322	0	22	24	24	70
24	0	46,971	47,782	94,753	773,881	773,881	365,045	365,045	0	257	390	0	24	24	24	72
25	0	44,734	47,309	92,044	720,482	746,936	284,848	284,848	0	375	451	0	23	23	24	71
26	0	30,967	48,718	79,685	520,990	789,711	443,704	443,704	0	366	311	0	16	24	24	64
27	0	44,627	47,815	92,442	705,438	739,862	331,915	331,915	0	498	479	0	23	24	21	68
28	0	46,949	47,883	94,832	785,822	785,822	354,682	354,682	0	223	313	0	24	24	24	72
29	0	47,046	47,920	94,966	789,989	789,989	325,969	325,969	0	213	293	0	24	24	24	72
30	0	46,980	47,886	94,836	769,310	769,310	280,578	280,578	0	216	483	0	24	24	24	72
<b>Totals</b>	<b>178,078</b>	<b>1,283,740</b>	<b>1,376,017</b>	<b>2,837,835</b>	<b>2,539,736</b>	<b>20,220,297</b>	<b>21,118,831</b>	<b>9,789,832</b>	<b>1,354</b>	<b>11,559</b>	<b>13,874</b>	<b>90</b>	<b>639</b>	<b>681</b>	<b>619</b>	<b>2,049</b>
	Sum of Engines 2,837,835				Sum of Engines 43,878,864				Sum of Engines 26,787			Sum of Engines 1,430				



Month: October - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated				Biogas Used				Fuel Oil Used			Hours of Operation				
	Gen. 1	Gen 2	Gen 3	Total KWh	Eng. 1	Eng. 2	Eng. 3	Boiler	Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler	Total Hrs
1	0	47,005	47,005	94,010	0	897,504	897,504	268,248	0	32	26	0	24	24	24	72
2	0	53,287	49,188	102,475	0	885,589	885,589	288,683	0	19	21	0	24	24	24	72
3	0	40,903	44,622	85,525	0	845,273	886,581	277,598	0	52	34	0	23	24	24	71
4	0	46,000	48,000	94,000	0	855,999	899,736	292,648	0	21	25	0	23	24	24	71
5	0	47,050	47,050	94,100	0	897,307	897,307	352,700	0	19	21	0	24	24	24	72
6	20,868	45,531	45,531	111,930	351,114	816,808	816,808	235,549	61	33	36	10	24	24	14	72
7	46,170	46,170	46,170	138,510	776,837	776,837	776,837	0	24	21	27	24	24	24	0	72
8	46,173	46,173	46,173	138,520	771,652	771,652	771,652	0	24	18	23	24	24	24	0	72
9	47,940	15,980	47,940	111,860	743,134	257,516	743,134	206,574	35	24	37	24	8	24	16	72
10	46,626	27,198	46,626	120,450	782,033	456,729	782,033	125,175	25	37	30	24	14	24	10	72
11	46,053	46,053	46,053	138,160	781,212	781,212	781,212	0	25	18	25	24	24	24	0	72
12	45,952	45,952	45,952	137,855	775,334	775,334	775,334	0	30	26	33	24	24	24	0	72
13	43,087	41,128	45,045	129,260	679,570	699,267	704,969	57,600	32	179	155	22	22	23	4	71
14	46,067	46,067	46,067	138,200	759,263	759,263	759,263	0	74	89	66	24	24	24	0	72
15	45,568	45,568	37,974	129,110	754,602	754,602	616,782	53,747	28	28	41	24	24	20	4	72
16	47,360	47,360	0	94,720	657,713	657,713	0	272,384	32	27	0	24	24	0	24	72
17	45,443	45,443	20,828	111,715	696,481	696,481	322,326	136,453	28	27	0	24	24	11	13	71
18	46,013	46,013	46,013	138,040	765,151	765,151	765,151	0	27	28	45	24	24	24	0	72
19	46,577	46,577	44,636	137,790	756,186	756,186	703,074	0	33	26	28	24	24	22	0	70
20	45,572	37,976	45,572	129,120	718,003	575,031	718,003	44,010	45	28	23	23	18	23	3	67
21	47,242	43,305	47,242	137,790	795,830	725,642	795,830	28,269	31	35	28	24	22	24	2	72
22	35,257	47,009	47,009	129,275	619,524	811,014	811,014	70,415	22	28	4	18	24	24	6	72
23	0	47,193	47,193	94,385	0	863,649	863,649	283,063	0	29	18	0	24	24	24	72
24	17,857	42,857	42,857	103,570	307,089	804,708	804,708	182,742	22	27	22	9	24	24	15	72
25	46,177	46,177	46,177	138,530	766,304	766,304	766,304	0	24	19	23	24	24	24	0	72
26	46,190	46,190	46,190	138,570	753,005	753,005	753,005	0	38	93	84	24	24	24	0	72
27	48,176	36,132	36,132	120,440	729,984	555,092	556,106	0	35	13	36	24	18	24	0	61
28	44,169	44,169	14,723	103,060	677,489	677,489	230,064	0	28	29	31	24	24	8	0	56
29	30,270	45,405	45,405	121,080	529,668	778,288	778,288	101,137	26	31	40	16	24	24	8	72
30	0	44,057	33,043	77,100	0	784,350	604,363	343,805	0	42	34	0	24	24	18	66
31	15,645	46,935	31,290	93,870	278,324	793,638	508,700	251,768	16	29	38	8	24	15	16	64
Totals	996,452	1,352,864	1,283,704	3,633,020	16,225,501	22,994,631	21,975,324	3,872,568	765	1,130	1,089	515	700	662	302	2,179
	Sum of Engines				Sum of Engines				Sum of Engines			Sum of Engines				
	3,633,020				61,195,456				2,984			1,877				



Month: November - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated				Biogas Used				Fuel Oil Used			Hours of Operation							
	Gen 1	Gen 2	Gen 3	Total KWh	Eng. 1	Eng. 2	Eng. 3	Boiler	Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler	Total Hrs			
1	39,453	37,084	37,227	113,763	685,777	637,969	628,938	112,165	53	17	28	22	20	20	6	68			
2	43,329	44,489	45,179	132,998	765,990	765,990	765,990	0	42	42	55	24	24	24	0	72			
3	44,290	45,365	46,144	135,799	782,200	782,200	782,200	0	36	40	63	24	24	24	0	72			
4	44,677	45,993	46,734	137,404	794,347	794,347	794,347	0	52	40	12	24	24	24	0	72			
5	42,618	45,394	46,114	134,126	774,911	774,911	774,911	0	45	39	56	24	24	24	0	72			
6	13,861	43,917	44,797	102,576	280,480	815,374	815,374	221,565	18	42	44	8	24	24	15	72			
7	20,937	44,227	45,084	110,248	407,392	800,333	800,333	164,818	44	41	42	12	24	24	12	72			
8	44,915	45,240	44,865	135,020	775,281	775,281	775,281	0	45	42	45	24	24	24	0	72			
9	47,324	46,801	45,603	139,728	798,715	798,715	798,715	0	56	40	52	24	24	24	0	72			
10	42,631	43,726	24,761	111,118	719,126	719,126	388,028	0	39	39	47	24	24	13	0	61			
11	43,914	30,407	0	74,321	638,496	431,872	0	124,462	51	37	0	24	16	0	7	48			
12	44,785	0	0	44,785	560,902	0	0	223,342	52	0	0	23	0	0	13	36			
13	43,802	0	0	43,802	549,684	0	0	0	46	0	0	24	0	0	0	24			
14	46,427	0	0	46,427	585,014	0	0	0	38	0	0	24	0	0	0	24			
15	41,960	38,663	437	81,060	608,369	558,137	25,760	0	33	23	63	24	22	1	0	46			
16	47,104	45,605	13,653	106,362	722,670	722,670	231,857	52,753	42	43	8	24	24	8	4	60			
17	42,668	42,310	15,108	100,085	695,580	655,487	223,165	127,770	94	50	40	24	23	8	7	61			
18	42,079	43,203	0	85,282	634,995	634,995	0	0	44	43	0	24	24	0	0	48			
19	40,786	17,291	0	58,077	568,419	239,027	0	8,941	45	20	0	23	10	0	0	33			
20	0	12,234	0	12,234	0	200,393	0	165,805	4	52	0	0	7	0	12	20			
21	27,009	42,603	0	69,612	424,454	635,512	0	229,622	82	34	0	15	23	0	17	55			
22	40,367	12,602	0	52,969	543,301	177,386	0	203,803	52	12	0	20	7	0	12	38			
23	46,830	24,717	0	71,547	649,912	364,222	0	0	42	22	0	24	13	0	0	37			
24	43,177	7,129	0	50,305	569,605	89,001	0	24,018	68	9	0	24	4	0	2	29			
25	41,039	0	0	41,039	516,073	0	0	30,639	38	0	0	24	0	0	1	25			
26	49,318	45,252	0	94,570	708,274	691,550	0	345,768	47	31	0	24	23	0	24	71			
27	46,572	42,086	0	88,658	673,531	635,844	0	314,351	57	22	0	23	22	0	23	68			
28	44,003	42,756	0	86,759	644,600	642,681	0	309,571	61	22	0	22	22	0	23	67			
29	45,148	27,355	0	72,503	642,405	397,042	0	186,767	53	7	0	24	15	0	12	51			
30	42,492	35,207	0	77,698	618,731	519,906	0	32,324	42	36	0	24	20	0	2	46			
Totals	1,203,513	961,655	455,708	2,610,876	18,339,233	15,259,970	7,804,900	2,878,484	1,419	846	554	649	510	241	192	1,592			
Sum of Engines				2,610,876	Sum of Engines				41,404,103	Sum of Engines			2,819	Sum of Engines					1,400



Month: December - 2011

# Daily Data for Air Permit

Elmer E. Ross Power Station

Date	Watt Hours Generated				Biogas Used				Fuel Oil Used			Hours of Operation				
	Gen. 1	Gen 2	Gen 3	Total KWh	Eng. 1	Eng. 2	Eng. 3	Boiler	Eng. 1	Eng. 2	Eng. 3	Eng. 1	Eng. 2	Eng. 3	Boiler	Total Hrs
1	44,733	12,072	0	56,805	609,179	181,485	0	0	20	5	0	24	7	0	0	31
2	42,277	24,769	0	67,046	612,168	368,576	0	0	24	14	0	24	14	0	0	38
3	43,931	16,177	0	60,108	615,122	236,224	0	0	22	9	0	24	9	0	0	33
4	5,658	0	0	5,658	72,220	0	0	345,135	6	0	0	3	0	0	21	24
5	13,857	0	0	13,857	175,495	0	0	252,196	21	0	0	8	0	0	17	24
6	15,409	0	0	15,409	197,637	0	0	336,204	13	0	0	8	0	0	14	21
7	0	0	0	0	0	0	0	579,594	1	0	0	0	0	0	24	24
8	0	0	0	0	0	0	0	363,309	0	0	0	0	0	0	24	24
9	0	24,730	0	24,730	0	435,092	0	287,763	0	12	0	0	13	0	23	36
10	0	46,073	0	46,073	0	813,504	0	0	0	9	0	0	24	0	3	27
11	0	41,499	0	41,499	0	733,557	0	0	0	9	0	0	24	0	0	24
12	0	41,352	0	41,352	0	731,203	0	0	0	8	0	0	24	0	0	24
13	0	18,072	44,775	62,847	0	411,077	907,795	44,268	0	14	36	0	10	23	3	36
14	0	0	14,754	14,754	0	0	329,461	212,987	0	3	10	0	0	7	14	21
15	0	0	0	0	0	0	0	346,254	0	0	0	0	0	0	23	23
16	0	0	0	0	0	0	0	356,569	0	0	0	0	0	0	24	24
17	0	0	0	0	0	0	0	348,414	0	0	0	0	0	0	24	24
18	0	0	0	0	0	0	0	334,013	0	0	0	0	0	0	24	24
19	0	0	0	0	0	0	0	315,713	0	0	0	0	0	0	24	24
20	0	0	0	0	0	0	0	319,120	0	0	0	0	0	0	24	24
21	0	0	0	0	0	0	0	453,071	0	0	0	0	0	0	21	21
22	0	0	0	0	0	0	0	359,148	0	0	0	0	0	0	24	24
23	0	0	0	0	0	0	0	367,314	0	0	0	0	0	0	24	24
24	0	0	0	0	0	0	0	341,731	0	0	0	0	0	0	24	24
25	0	0	0	0	0	0	0	309,229	0	0	0	0	0	0	24	24
26	0	0	0	0	0	0	0	294,462	0	0	0	0	0	0	24	24
27	0	0	0	0	0	0	0	299,075	0	0	0	0	0	0	24	24
28	0	0	0	0	0	0	0	330,893	0	0	0	0	0	0	20	20
29	0	0	0	0	0	0	0	315,677	0	0	0	0	0	0	24	24
30	0	0	0	0	0	0	0	306,951	0	0	0	0	0	0	24	24
31	0	0	0	0	0	0	0	319,829	0	0	0	0	0	0	24	24
Totals	165,864	224,744	59,529	450,136	2,281,821	3,910,718	1,237,256	8,138,919	107	83	46	91	126	30	541	788
	Sum of Engines				Sum of Engines				Sum of Engines			Sum of Engines				
	450,137				7,429,795				236			248				

EBMUD Main Wastewater Plant

Table 3 - Cogeneration Engine Usage Summary

July 1 - December 31, 2011

Usage	Ref.	Jul-11	Aug-11	Sep-11	Oct-11	Nov-11	Dec-11	Semi-annual Totals	
Run Time	Eng #1	561	670	90	515	649	91	2,575	
	Eng #2	577	521	659	700	511	126	3,095	
	Eng #3	681	688	681	662	242	30	2,984	
	Total	1,819	1,879	1,430	1,877	1,93	248	7,445	
Diesel Fuel	Eng #1	9621	1,122	1,354	765	1,419	223	5,845	
	Eng #2	1,077	1,049	1,559	1,130	846	174	5,835	
	Eng #3	1,277	1,325	1,387	1,089	554	97	4,820	
	Total	3,316	3,496	2,677	2,984	2,819	494	13,961	
	Average	gal/hr	118	119	187	16	146	20	118
	Average	gal/day	438	447	449.5	382	351.3	47.9	1,315
Gas/Heat Value	Average	btu/cf	676	630	687	639	615	604	639
	Eng #1	cf	16,738,616	22,660,701	2,539,736	16,225,501	18,329,442	2,254,960	78,748,956
	Eng #2	cf	17,643,582	17,644,693	20,220,297	22,994,631	15,264,865	3,889,834	97,657,902
	Eng #3	cf	21,183,930	23,602,521	21,118,831	21,975,324	7,809,795	1,225,302	96,915,703
	Eng #1	cf/hr	29,836	33,826	28,240	31,527	28,251	24,784	24,784
	Eng #2	cf/hr	30,588	33,837	30,672	32,848	29,848	30,758	30,758
Digester Gas	Eng #3	cf/hr	31,111	34,323	31,007	33,183	32,265	40,685	40,685
	Eng #1	mmBTU/hr	20.4	21.5	21.5	20.4	17.7	15.3	15.3
	Eng #2	mmBTU/hr	20.9	21.6	23.5	21.2	18.6	18.8	18.8
	Eng #3	mmBTU/hr	21.3	21.9	24.1	21.4	20.2	25.0	25.0
	Total	cf	55,566,128	63,907,915	43,878,864	61,195,456	41,404,102	7,370,096	273,322,561
	Total	meter							
Natural Gas	Total	cf							
Power Output	Total	kWh	3,650,053	3,781,236	2,837,835	3,597,886	2,614,657	450,137	16,931,804

- (1) Calculated value: Monthly Total Engine Operation (hours) = sum of individual engine run times (hours)
- (2) Calculated value: Monthly Engine usage = Sum of total daily fuel consumed x (daily individual engine usage (gal)/ day total of all usage (gal))
- (3) Calculated value: Average GPH = Monthly Total fuel consumed (gal) / Monthly Total Engine Operation (hours)
- (4) Calculated value: Average GPD = Average GPH x 24 hours/day
- (5) Calculated value: Digester gas volume (cf) = (individual engine daily power produced x engine specific btu-KWh power curve - diesel btu) / (monthly gas btu/cf)
- (6) Calculated value: Digester gas thruput (cf/hr) = (Digester gal volume, cf) / (Engine Runtime, hr)
- (7) Calculated value: Digester gas thruput (MMBTU/hr) = Digester gas thruput (cf/hr) x monthly gas sample (Btu/cf) / 1,000,000 + diesel thruput (gal/hr) x 138,690 Btu/gal / 1,000,000



**TABLE 4****Hours of Operation for Stand-By Emergency Generators****July 1, 2011 – December, 31, 2011**

Source	Location	Hours of Operation during reporting period		Limit on reliability-related hours
		Emergency Use	Maintenance and Testing	
S-49	Portable, S. of Maint.	0	1	NA
S-50	N. of PGS	0	0	30
S-51	Dechlorination	0.7	1.4	50
S-52	N. of Maint.	0	0	20
S-53	W. of Administration	1.8	0	30
S-54	East Bayshore RWF	4	2	50

Item E2.

IPS Odor Scrubbers (ppm)

		Table 5 -- IPS scrubber inlet and outlet H2S conc.									
Jul. 1, 2011 to Sep. 30, 2011	Coarse Bar Screens Room Scrubber Inlet	Coarse Bar Screens Room Scrubber Outlet	Fine Bar Screens Room Scrubber Inlet	Fine Bar Screens Room Scrubber Outlet	Jul. 1, 2011 to Sep. 30, 2011	Coarse Bar Screens Room Scrubber Inlet	Coarse Bar Screens Room Scrubber Outlet	Fine Bar Screens Room Scrubber Inlet	Fine Bar Screens Room Scrubber Outlet		
	Average	Average	Average	Average		Max	Max	Max	Max		
	3 Month Average	4.5	0.1	0.0		0.0	3 Month Maximum	49.5	4.8	13.5	2.3
01-Jul-11	0.3	0.0	0.0	0.0	01-Jul-11	7.4	0.1	1.6	0.2		
02-Jul-11	0.4	0.0	0.0	0.0	02-Jul-11	2.5	0.8	2.5	0.0		
03-Jul-11	0.5	0.0	0.0	0.0	03-Jul-11	1.8	1.0	1.1	0.6		
04-Jul-11	0.9	0.0	0.1	0.0	04-Jul-11	6.9	0.8	2.4	0.0		
05-Jul-11	1.0	0.0	0.0	0.0	05-Jul-11	5.5	0.0	1.9	0.4		
06-Jul-11	4.2	0.0	0.0	0.0	06-Jul-11	16.2	0.0	1.1	0.3		
07-Jul-11	3.1	0.0	0.0	0.0	07-Jul-11	14.1	0.3	1.4	0.0		
08-Jul-11	3.2	0.0	0.6	0.0	08-Jul-11	23.1	0.0	0.6	0.0		
09-Jul-11	5.0	0.0	0.0	0.0	09-Jul-11	24.3	0.0	3.5	0.0		
10-Jul-11	8.8	0.0	0.0	0.0	10-Jul-11	29.9	0.1	3.0	0.0		
11-Jul-11	5.0	0.0	0.1	0.0	11-Jul-11	36.3	0.4	3.4	0.0		
12-Jul-11	5.3	0.0	0.1	0.0	12-Jul-11	14.9	0.1	3.7	0.0		
13-Jul-11	6.0	0.0	0.0	0.0	13-Jul-11	14.3	0.0	0.8	0.3		
14-Jul-11	6.1	0.0	0.0	0.0	14-Jul-11	22.0	0.4	2.2	0.0		
15-Jul-11	6.6	0.0	0.0	0.0	15-Jul-11	25.4	0.1	1.3	0.0		
16-Jul-11	3.9	0.0	0.0	0.0	16-Jul-11	15.7	0.0	1.3	0.0		
17-Jul-11	2.0	0.0	0.0	0.0	17-Jul-11	8.5	0.0	1.2	0.0		
18-Jul-11	2.6	0.0	0.0	0.0	18-Jul-11	12.0	0.0	1.4	0.0		
19-Jul-11	4.6	0.0	0.0	0.0	19-Jul-11	13.8	0.7	0.4	0.0		
20-Jul-11	2.3	0.0	0.0	0.0	20-Jul-11	10.7	0.0	0.0	0.4		
21-Jul-11	4.3	0.0	0.0	0.0	21-Jul-11	15.6	0.0	1.0	2.3		
22-Jul-11	5.9	0.0	0.0	0.0	22-Jul-11	37.1	0.2	1.5	0.0		
23-Jul-11	3.0	0.0	0.0	0.0	23-Jul-11	12.6	0.0	1.5	0.0		
24-Jul-11	4.4	0.0	0.0	0.0	24-Jul-11	9.2	0.0	1.5	0.0		
25-Jul-11	4.4	0.0	0.0	0.0	25-Jul-11	12.1	0.1	0.3	0.3		
26-Jul-11	6.4	0.1	0.0	0.0	26-Jul-11	22.0	0.2	0.0	0.0		
27-Jul-11	4.6	0.0	0.0	0.0	27-Jul-11	13.9	0.4	0.8	0.0		
28-Jul-11	2.6	0.0	0.0	0.0	28-Jul-11	17.3	0.0	0.7	0.5		
29-Jul-11	3.4	0.0	0.0	0.0	29-Jul-11	21.4	0.1	0.8	0.5		
30-Jul-11	3.5	0.0	0.0	0.0	30-Jul-11	16.0	0.0	0.3	0.3		
31-Jul-11	6.0	0.0	0.0	0.0	31-Jul-11	18.9	0.2	0.0	0.4		
01-Aug-11	8.2	0.1	0.0	0.0	01-Aug-11	36.6	0.2	0.0	0.0		
02-Aug-11	9.3	0.1	0.0	0.0	02-Aug-11	45.4	1.1	0.0	0.3		
03-Aug-11	7.4	0.1	0.0	0.0	03-Aug-11	49.5	1.6	0.0	0.0		
04-Aug-11	5.3	0.2	0.0	0.0	04-Aug-11	27.8	1.0	0.9	0.3		
05-Aug-11	5.8	0.2	0.0	0.0	05-Aug-11	31.3	0.7	0.9	0.0		
06-Aug-11	3.3	0.1	0.0	0.0	06-Aug-11	13.3	0.7	0.0	0.3		
07-Aug-11	7.1	0.1	0.0	0.0	07-Aug-11	21.6	0.3	0.0	0.0		
08-Aug-11	3.0	0.0	0.0	0.0	08-Aug-11	13.4	0.1	0.0	0.0		
09-Aug-11	4.8	0.0	0.0	0.0	09-Aug-11	17.5	0.2	0.3	0.0		
10-Aug-11	8.5	0.1	0.0	0.0	10-Aug-11	19.6	0.2	1.9	0.6		
11-Aug-11	12.0	0.4	0.0	0.0	11-Aug-11	31.9	1.3	0.0	0.0		
12-Aug-11	15.6	1.2	0.0	0.0	12-Aug-11	34.4	4.8	0.8	0.6		
13-Aug-11	4.1	0.2	0.0	0.0	13-Aug-11	13.6	0.9	0.5	0.2		
14-Aug-11	9.2	0.3	0.0	0.0	14-Aug-11	27.8	1.1	0.0	0.3		
15-Aug-11	11.1	0.5	0.0	0.0	15-Aug-11	25.7	1.4	0.0	0.0		
16-Aug-11	6.7	0.3	0.0	0.0	16-Aug-11	24.7	1.6	0.0	0.0		
17-Aug-11	3.0	0.1	0.0	0.0	17-Aug-11	14.1	0.3	0.0	0.2		
18-Aug-11	4.2	0.1	0.0	0.0	18-Aug-11	16.9	0.2	0.0	0.4		
19-Aug-11	4.5	0.2	0.0	0.0	19-Aug-11	15.8	0.6	0.3	0.0		
20-Aug-11	4.2	0.2	0.0	0.0	20-Aug-11	15.7	0.4	0.9	0.0		
21-Aug-11	5.1	0.2	0.0	0.0	21-Aug-11	14.2	0.8	0.5	0.0		
22-Aug-11	3.8	0.1	0.0	0.0	22-Aug-11	19.4	0.2	0.0	0.0		
23-Aug-11	4.7	0.1	0.0	0.0	23-Aug-11	15.1	0.2	0.9	0.0		
24-Aug-11	4.8	0.1	0.0	0.0	24-Aug-11	16.9	0.3	0.9	0.4		
25-Aug-11	2.6	0.1	0.0	0.0	25-Aug-11	21.5	0.3	0.0	0.0		
26-Aug-11	3.9	0.1	0.0	0.0	26-Aug-11	16.9	0.4	0.3	0.4		
27-Aug-11	3.0	0.1	0.0	0.0	27-Aug-11	14.5	0.3	0.6	0.0		
28-Aug-11	2.4	0.0	0.0	0.0	28-Aug-11	7.3	0.3	0.4	0.0		
29-Aug-11	4.0	0.1	0.0	0.0	29-Aug-11	11.7	0.6	0.6	0.5		
30-Aug-11	6.8	0.2	0.0	0.0	30-Aug-11	41.3	1.6	0.3	0.3		
31-Aug-11	5.7	0.2	0.0	0.0	31-Aug-11	27.0	0.9	0.6	0.5		
01-Sep-11	6.7	0.2	0.0	0.0	01-Sep-11	18.8	0.5	0.0	0.4		
02-Sep-11	8.2	0.2	0.0	0.0	02-Sep-11	22.3	0.8	0.0	0.0		
03-Sep-11	5.1	0.1	0.0	0.0	03-Sep-11	17.9	0.7	0.5	0.6		
04-Sep-11	2.6	0.0	0.0	0.0	04-Sep-11	6.2	0.1	0.0	0.0		
05-Sep-11	2.8	0.1	0.0	0.0	05-Sep-11	38.0	0.9	0.0	0.0		
06-Sep-11	2.2	0.1	0.0	0.0	06-Sep-11	14.8	0.4	0.3	0.4		
07-Sep-11	3.7	0.2	0.0	0.0	07-Sep-11	12.8	0.8	1.2	0.0		
08-Sep-11	4.8	0.1	0.0	0.0	08-Sep-11	17.4	0.5	0.6	0.0		
09-Sep-11	2.7	0.0	0.0	0.0	09-Sep-11	14.0	0.1	0.0	0.0		
10-Sep-11	2.2	0.0	0.0	0.0	10-Sep-11	12.3	0.2	0.8	0.0		
11-Sep-11	2.4	0.0	0.0	0.0	11-Sep-11	9.3	0.0	13.5	0.0		
12-Sep-11	5.7	0.1	0.0	0.0	12-Sep-11	28.9	1.2	2.0	0.3		
13-Sep-11	4.5	0.1	0.0	0.0	13-Sep-11	17.3	0.8	2.9	0.0		
14-Sep-11	3.6	0.2	0.0	0.0	14-Sep-11	26.2	1.5	0.0	0.2		
15-Sep-11	2.4	0.1	0.0	0.0	15-Sep-11	9.0	0.6	0.0	0.0		
16-Sep-11	3.0	0.1	0.0	0.0	16-Sep-11	17.5	0.4	0.5	0.5		
17-Sep-11	3.4	0.1	0.0	0.0	17-Sep-11	17.5	0.3	2.1	0.0		
18-Sep-11	2.2	0.0	0.0	0.0	18-Sep-11	5.9	0.0	0.0	0.3		
19-Sep-11	2.5	0.0	0.0	0.0	19-Sep-11	7.2	0.1	0.3	0.0		
20-Sep-11	3.2	0.0	0.0	0.0	20-Sep-11	20.2	0.3	0.0	0.0		
21-Sep-11	5.0	0.0	0.0	0.0	21-Sep-11	14.8	0.0	0.0	0.0		
22-Sep-11	5.8	0.0	0.0	0.0	22-Sep-11	31.1	0.0	1.1	0.0		
23-Sep-11	2.8	0.0	0.0	0.0	23-Sep-11	13.7	0.0	0.3	0.0		
24-Sep-11	5.6	0.0	0.0	0.0	24-Sep-11	18.8	0.0	0.6	0.0		
25-Sep-11	5.2	0.0	0.0	0.0	25-Sep-11	19.2	0.0	0.8	0.0		
26-Sep-11	5.0	0.0	0.0	0.0	26-Sep-11	21.6	0.0	3.8	0.0		
27-Sep-11	4.3	0.0	0.0	0.0	27-Sep-11	13.8	0.1	0.3	0.0		
28-Sep-11	3.8	0.0	0.0	0.0	28-Sep-11	15.3	0.0	1.7	0.0		

Item E2.

IPS Odor  
Scrubbers  
(ppm)

29-Sep-11	3.9	0.0	0.0	0.0	29-Sep-11	21.8	0.0	2.0	0.0
30-Sep-11	2.8	0.0	0.0	0.0	30-Sep-11	11.4	0.0	0.0	0.2

**Influent Pump Station Odor Scrubber Outage Table**

Start                      Finish                      Duration                      Reason

Total Down Time 0:00

Item E2.

IPS Odor Scrubbers (ppm)

Table 5 -- IPS scrubber inlet and outlet H2S conc.									
Oct. 1, 2011 to Dec. 31, 2011	Coarse Bar Screens Room Scrubber Inlet	Coarse Bar Screens Room Scrubber Outlet	Fine Bar Screens Room Scrubber Inlet	Fine Bar Screens Room Scrubber Outlet	Oct. 1, 2011 to Dec. 31, 2011	Coarse Bar Screens Room Scrubber Inlet	Coarse Bar Screens Room Scrubber Outlet	Fine Bar Screens Room Scrubber Inlet	Fine Bar Screens Room Scrubber Outlet
	Average	Average	Average	Average		Max	Max	Max	Max
3 Month Average	2.7	0.0	0.0	0.0	3 Month Maximum	41.9	0.6	7.8	0.8
01-Oct-11	2.8	0.0	0.0	0.0	01-Oct-11	11.4	0.0	0.0	0.2
02-Oct-11	3.7	0.0	0.0	0.0	02-Oct-11	15.5	0.0	0.4	0.2
03-Oct-11	1.0	0.0	0.0	0.0	03-Oct-11	4.6	0.0	0.8	0.4
04-Oct-11	1.9	0.0	0.0	0.0	04-Oct-11	10.2	0.0	0.0	0.0
05-Oct-11	4.3	0.0	0.0	0.0	05-Oct-11	11.7	0.3	0.0	0.3
06-Oct-11	1.8	0.0	0.0	0.0	06-Oct-11	10.9	0.0	0.3	0.0
07-Oct-11	1.2	0.0	0.0	0.0	07-Oct-11	3.6	0.0	0.0	0.0
08-Oct-11	0.6	0.0	0.0	0.0	08-Oct-11	3.5	0.0	0.0	0.5
09-Oct-11	1.0	0.0	0.0	0.0	09-Oct-11	4.7	0.0	0.0	0.0
10-Oct-11	1.1	0.0	0.0	0.0	10-Oct-11	3.6	0.0	1.5	0.0
11-Oct-11	1.4	0.0	0.0	0.0	11-Oct-11	12.6	0.0	0.0	0.0
12-Oct-11	0.9	0.0	0.0	0.0	12-Oct-11	2.3	0.0	0.0	0.3
13-Oct-11	3.9	0.0	0.0	0.0	13-Oct-11	41.9	0.0	4.7	0.0
14-Oct-11	1.6	0.0	0.0	0.0	14-Oct-11	6.6	0.0	0.8	0.0
15-Oct-11	1.8	0.0	0.0	0.0	15-Oct-11	11.3	0.4	0.0	0.0
16-Oct-11	0.1	0.0	0.0	0.0	16-Oct-11	1.4	0.0	0.0	0.0
17-Oct-11	0.7	0.0	0.0	0.0	17-Oct-11	2.2	0.0	0.0	0.0
18-Oct-11	2.1	0.0	0.0	0.0	18-Oct-11	14.3	0.5	0.0	0.0
19-Oct-11	1.6	0.0	0.0	0.0	19-Oct-11	9.0	0.8	1.1	0.0
20-Oct-11	4.1	0.0	0.0	0.0	20-Oct-11	13.7	0.2	0.0	0.0
21-Oct-11	5.3	0.0	0.0	0.0	21-Oct-11	24.2	0.3	0.0	0.0
22-Oct-11	4.3	0.0	0.0	0.0	22-Oct-11	14.0	0.0	0.0	0.0
23-Oct-11	2.0	0.0	0.0	0.0	23-Oct-11	8.4	0.0	0.0	0.0
24-Oct-11	1.7	0.0	0.0	0.0	24-Oct-11	7.0	0.0	0.0	0.0
25-Oct-11	2.2	0.0	0.0	0.0	25-Oct-11	6.0	0.0	0.0	0.0
26-Oct-11	2.2	0.0	0.0	0.0	26-Oct-11	20.2	0.0	2.6	0.0
27-Oct-11	3.4	0.0	0.0	0.0	27-Oct-11	11.2	0.0	1.9	0.0
28-Oct-11	1.9	0.0	0.0	0.0	28-Oct-11	10.1	0.0	0.3	0.0
29-Oct-11	2.4	0.0	0.0	0.0	29-Oct-11	10.6	0.3	0.6	0.0
30-Oct-11	2.3	0.0	0.0	0.0	30-Oct-11	11.5	0.0	1.3	0.0
31-Oct-11	3.2	0.0	0.0	0.0	31-Oct-11	7.6	0.0	0.0	0.0
01-Nov-11	3.6	0.0	0.0	0.0	01-Nov-11	8.9	0.0	0.9	0.7
02-Nov-11	3.8	0.0	0.0	0.0	02-Nov-11	9.3	0.0	2.8	0.8
03-Nov-11	6.6	0.0	0.0	0.0	03-Nov-11	13.4	0.0	0.4	0.6
04-Nov-11	6.9	0.0	0.0	0.0	04-Nov-11	19.3	0.0	0.3	0.0
05-Nov-11	4.4	0.0	0.0	0.0	05-Nov-11	16.6	0.0	1.9	0.0
06-Nov-11	6.1	0.0	0.0	0.0	06-Nov-11	16.8	0.0	0.5	0.5
07-Nov-11	0.9	0.0	0.0	0.0	07-Nov-11	3.6	0.0	0.5	0.0
08-Nov-11	1.2	0.0	0.0	0.0	08-Nov-11	6.8	0.0	1.0	0.4
09-Nov-11	1.4	0.0	0.0	0.0	09-Nov-11	8.4	0.0	4.1	0.0
10-Nov-11	2.4	0.0	0.1	0.0	10-Nov-11	10.1	0.0	5.8	0.0
11-Nov-11	3.7	0.0	0.0	0.0	11-Nov-11	18.8	0.0	3.3	0.3
12-Nov-11	4.4	0.0	0.0	0.0	12-Nov-11	12.3	0.2	0.4	0.0
13-Nov-11	3.0	0.0	0.0	0.0	13-Nov-11	10.9	0.0	0.0	0.5
14-Nov-11	1.8	0.0	0.0	0.0	14-Nov-11	8.4	0.6	0.0	0.4
15-Nov-11	2.3	0.0	0.0	0.0	15-Nov-11	8.6	0.4	1.8	0.0
16-Nov-11	5.0	0.0	0.0	0.0	16-Nov-11	34.4	0.1	1.9	0.3
17-Nov-11	3.4	0.0	0.0	0.0	17-Nov-11	17.9	0.0	0.0	0.0
18-Nov-11	6.6	0.0	0.0	0.0	18-Nov-11	11.6	0.0	1.8	0.0
19-Nov-11	7.6	0.0	0.0	0.0	19-Nov-11	12.7	0.0	0.3	0.3
20-Nov-11	6.5	0.0	0.0	0.0	20-Nov-11	12.6	0.0	0.4	0.4
21-Nov-11	2.1	0.0	0.0	0.0	21-Nov-11	8.8	0.0	0.4	0.0
22-Nov-11	2.7	0.0	0.0	0.0	22-Nov-11	27.3	0.0	0.7	0.0
23-Nov-11	3.6	0.0	0.0	0.0	23-Nov-11	17.5	0.0	0.3	0.0
24-Nov-11	4.9	0.0	0.0	0.0	24-Nov-11	7.6	0.0	2.0	0.3
25-Nov-11	7.1	0.0	0.0	0.0	25-Nov-11	15.9	0.0	1.7	0.0
26-Nov-11	3.0	0.0	0.0	0.0	26-Nov-11	8.6	0.0	0.9	0.4
27-Nov-11	1.8	0.0	0.0	0.0	27-Nov-11	5.7	0.0	2.2	0.0
28-Nov-11	3.6	0.0	0.0	0.0	28-Nov-11	6.6	0.0	0.0	0.0
29-Nov-11	4.5	0.0	0.0	0.0	29-Nov-11	14.0	0.0	0.0	0.4
30-Nov-11	6.1	0.0	0.0	0.0	30-Nov-11	13.0	0.0	0.3	0.0
01-Dec-11	3.7	0.0	0.0	0.0	01-Dec-11	6.9	0.0	1.8	0.3
02-Dec-11	4.0	0.0	0.0	0.0	02-Dec-11	21.5	0.0	3.7	0.2
03-Dec-11	3.5	0.0	0.0	0.0	03-Dec-11	8.5	0.0	1.7	0.0
04-Dec-11	4.7	0.0	0.0	0.0	04-Dec-11	15.3	0.2	0.9	0.6
05-Dec-11	2.8	0.0	0.0	0.0	05-Dec-11	6.5	0.0	1.8	0.0
06-Dec-11	3.6	0.0	0.0	0.0	06-Dec-11	7.5	0.0	0.3	0.6
07-Dec-11	4.6	0.0	0.1	0.0	07-Dec-11	12.2	0.2	1.0	0.0
08-Dec-11	4.2	0.0	0.0	0.0	08-Dec-11	8.9	0.0	0.4	0.4
09-Dec-11	1.8	0.0	0.1	0.0	09-Dec-11	4.8	0.0	2.4	0.0
10-Dec-11	4.1	0.0	0.1	0.0	10-Dec-11	24.3	0.0	2.6	0.0
11-Dec-11	1.8	0.0	0.0	0.0	11-Dec-11	2.8	0.0	0.6	0.0
12-Dec-11	1.8	0.0	0.0	0.0	12-Dec-11	6.1	0.0	0.8	0.5
13-Dec-11	2.0	0.0	0.0	0.0	13-Dec-11	3.6	0.0	1.9	0.8
14-Dec-11	1.5	0.0	0.0	0.0	14-Dec-11	4.1	0.0	0.4	0.3
15-Dec-11	2.3	0.0	0.2	0.0	15-Dec-11	20.2	0.0	6.0	0.0
16-Dec-11	1.5	0.0	0.0	0.0	16-Dec-11	3.6	0.0	0.3	0.0
17-Dec-11	0.3	0.0	0.0	0.0	17-Dec-11	0.6	0.0	0.4	0.0
18-Dec-11	0.6	0.0	0.0	0.0	18-Dec-11	0.9	0.0	0.3	0.0
19-Dec-11	0.2	0.0	0.0	0.0	19-Dec-11	0.5	0.0	0.5	0.0
20-Dec-11	0.7	0.0	0.0	0.0	20-Dec-11	14.5	0.0	3.0	0.0
21-Dec-11	0.5	0.0	0.0	0.0	21-Dec-11	1.1	0.0	0.0	0.0
22-Dec-11	1.7	0.0	0.0	0.0	22-Dec-11	13.5	0.0	0.7	0.3
23-Dec-11	1.1	0.0	0.0	0.0	23-Dec-11	1.9	0.0	0.7	0.0
24-Dec-11	1.1	0.0	0.0	0.0	24-Dec-11	2.8	0.0	0.4	0.0
25-Dec-11	0.6	0.0	0.1	0.0	25-Dec-11	1.7	0.0	0.7	0.5
26-Dec-11	1.1	0.0	0.0	0.0	26-Dec-11	2.0	0.0	2.0	0.0
27-Dec-11	1.3	0.0	0.1	0.0	27-Dec-11	6.3	0.0	2.6	0.8
28-Dec-11	0.8	0.0	0.0	0.0	28-Dec-11	1.6	0.0	0.9	0.5
29-Dec-11	2.1	0.0	0.7	0.0	29-Dec-11	16.8	0.0	7.8	0.6

Item E2.

IPS Odor  
Scrubbers  
(ppm)

30-Dec-11	0.5	0.0	0.0	0.5	30-Dec-11	1.6	0.0	1.3	0.8
31-Dec-11	1.0	0.0	0.0	0.3	31-Dec-11	1.8	0.0	0.9	0.8

Table 6 -- S-171, 172, 173 Waste Activated Sludge Throughput

2011 July - December Gravity Belt Thickener Summary Flow Table

	January	February	March	April	May	June	Total
	Kgal	Kgal	Kgal	Kgal	Kgal	Kgal	Kgal
GBT 11	29,125	7,841	26,771	26,233	4,389	4,637	98,996
GBT 12	3,325	20,117	10,485	3,471	21,301	19,865	78,564
GBT 13	29,167	28,089	14,089	20,842	25,885	25,324	143,397
Total by Month	61,618	56,047	51,345	50,546	51,575	49,826	320,957

Gravity Belt Thickener Daily Flow Table

	GBT 11	GBT 12	GBT 13		GBT 11	GBT 12	GBT 13		GBT 11	GBT 12	GBT 13
	Kgal	Kgal	Kgal		Kgal	Kgal	Kgal		Kgal	Kgal	Kgal
1-Jul-11	671	615	683	1-Sep-11	880	818	0	1-Nov-11	964	0	898
2-Jul-11	500	481	612	2-Sep-11	881	822	0	2-Nov-11	935	0	883
3-Jul-11	687	636	708	3-Sep-11	883	819	0	3-Nov-11	929	0	860
4-Jul-11	745	696	770	4-Sep-11	848	790	0	4-Nov-11	923	0	900
5-Jul-11	718	676	743	5-Sep-11	861	889	0	5-Nov-11	638	285	854
6-Jul-11	941	220	901	6-Sep-11	883	482	321	6-Nov-11	0	960	907
7-Jul-11	1042	0	968	7-Sep-11	970	0	806	7-Nov-11	0	870	820
8-Jul-11	1049	0	955	8-Sep-11	1005	0	832	8-Nov-11	0	860	876
9-Jul-11	1064	0	957	9-Sep-11	1011	0	954	9-Nov-11	0	883	884
10-Jul-11	1047	0	953	10-Sep-11	1004	0	823	10-Nov-11	0	661	661
11-Jul-11	755	0	1154	11-Sep-11	929	0	800	11-Nov-11	0	749	744
12-Jul-11	1091	0	1040	12-Sep-11	940	0	798	12-Nov-11	0	825	826
13-Jul-11	1085	0	1056	13-Sep-11	881	0	794	13-Nov-11	0	829	825
14-Jul-11	1056	0	1022	14-Sep-11	790	0	708	14-Nov-11	0	775	790
15-Jul-11	1130	0	1086	15-Sep-11	781	0	701	15-Nov-11	0	872	1031
16-Jul-11	860	0	1163	16-Sep-11	858	0	765	16-Nov-11	0	461	463
17-Jul-11	865	0	842	17-Sep-11	894	0	803	17-Nov-11	0	826	1182
18-Jul-11	1078	0	1064	18-Sep-11	765	0	820	18-Nov-11	0	816	818
19-Jul-11	1080	0	1067	19-Sep-11	859	0	780	19-Nov-11	0	1010	1182
20-Jul-11	1083	0	1063	20-Sep-11	887	0	808	20-Nov-11	0	805	805
21-Jul-11	1051	0	1029	21-Sep-11	809	0	739	21-Nov-11	0	980	950
22-Jul-11	796	0	931	22-Sep-11	800	0	740	22-Nov-11	0	668	669
23-Jul-11	1028	0	988	23-Sep-11	797	0	729	23-Nov-11	0	848	854
24-Jul-11	1018	0	989	24-Sep-11	790	372	369	24-Nov-11	0	805	814
25-Jul-11	937	0	1070	25-Sep-11	792	750	0	25-Nov-11	0	821	832
26-Jul-11	787	0	915	26-Sep-11	897	855	0	26-Nov-11	0	823	834
27-Jul-11	417	0	403	27-Sep-11	901	856	0	27-Nov-11	0	765	781
28-Jul-11	1063	0	1013	28-Sep-11	818	789	0	28-Nov-11	0	800	830
29-Jul-11	1174	0	1005	29-Sep-11	784	752	0	29-Nov-11	0	808	607
30-Jul-11	1152	0	998	30-Sep-11	782	747	0	30-Nov-11	0	769	775
31-Jul-11	1156	0	1022	1-Oct-11	792	744	0	1-Dec-11	0	728	731
1-Aug-11	1273	0	1180	2-Oct-11	767	657	0	2-Dec-11	0	777	795
2-Aug-11	607	0	586	3-Oct-11	820	774	0	3-Dec-11	0	789	802
3-Aug-11	1130	0	1122	4-Oct-11	895	860	0	4-Dec-11	0	825	840
4-Aug-11	1035	0	1029	5-Oct-11	864	845	0	5-Dec-11	0	900	910
5-Aug-11	995	0	1069	6-Oct-11	825	335	435	6-Dec-11	0	782	850
6-Aug-11	1077	0	919	7-Oct-11	834	0	742	7-Dec-11	0	934	940
7-Aug-11	1123	0	1114	8-Oct-11	842	0	748	8-Dec-11	0	719	793
8-Aug-11	601	533	1140	9-Oct-11	795	0	700	9-Dec-11	0	778	895
9-Aug-11	0	1055	1093	10-Oct-11	919	0	820	10-Dec-11	0	808	929
10-Aug-11	0	975	1023	11-Oct-11	984	0	881	11-Dec-11	0	900	800
11-Aug-11	0	1026	1073	12-Oct-11	919	0	824	12-Dec-11	0	1128	994
12-Aug-11	0	1053	1050	13-Oct-11	934	0	841	13-Dec-11	0	907	857
13-Aug-11	0	1027	1120	14-Oct-11	928	0	835	14-Dec-11	0	823	801
14-Aug-11	0	1059	1099	15-Oct-11	860	0	839	15-Dec-11	0	839	899
15-Aug-11	0	1090	1078	16-Oct-11	849	0	852	16-Dec-11	0	890	892
16-Aug-11	0	1007	1005	17-Oct-11	862	0	828	17-Dec-11	0	898	889
17-Aug-11	0	785	873	18-Oct-11	960	0	862	18-Dec-11	0	801	820
18-Aug-11	0	945	932	19-Oct-11	858	0	767	19-Dec-11	0	810	830
19-Aug-11	0	817	808	20-Oct-11	912	0	841	20-Dec-11	0	870	900
20-Aug-11	0	869	859	21-Oct-11	1020	0	970	21-Dec-11	130	225	670
21-Aug-11	0	802	790	22-Oct-11	963	0	912	22-Dec-11	575	0	638
22-Aug-11	0	935	920	23-Oct-11	929	0	892	23-Dec-11	890	0	914
23-Aug-11	0	779	762	24-Oct-11	850	0	812	24-Dec-11	884	0	916
24-Aug-11	0	721	719	25-Oct-11	828	0	768	25-Dec-11	830	0	860
25-Aug-11	0	745	742	26-Oct-11	713	0	658	26-Dec-11	890	0	930
26-Aug-11	0	761	761	27-Oct-11	812	0	751	27-Dec-11	438	508	956
27-Aug-11	0	763	757	28-Oct-11	869	0	811	28-Dec-11	0	492	500
28-Aug-11	0	786	775	29-Oct-11	888	0	803	29-Dec-11	0	835	841
29-Aug-11	0	766	771	30-Oct-11	855	0	800	30-Dec-11	0	819	835
30-Aug-11	0	819	922	31-Oct-11	900	0	850	31-Dec-11	0	809	828
31-Aug-11	535	877	424								

Gravity Belt Thickener and Dewatering Centrifuge Odor Scrubber Outage Table

Start	Finish	Duration	Reason
15-Aug-11 08:45	15-Aug-11 11:30	2:45	Replacement of rotometer #2, leak repair rotometer #1
07-Dec-11 14:35	07-Dec-11 15:02	0:27	Connecting C4 to foul air draw ductwork

Total Down Time 3:12

**Headworks Odor Scrubber Maintenance Work Orders Jan - Jun 2011**

Area	Monum	Description	Assetnum	Dept	Status	Type	Report Date	Reported By
W-12	201103624	exhaust fan D/P transmitter locations. Re-joined some tubing and replaced all 3/4" tubing with 3/8" tubing. Replaced sole OLV. fittings with new. Picked back into service. Ops notified.	W-12-FAN-SF5-00	IN	CLOSE	BD	9/4/2011	HCLCLOUD
W-12	2011129305	Replaced belt.	W-12-FAN-SF1-01	ME	CLOSE	CM	11/16/2011	DRETONDO
W-12	2011103692	fan has loose, cracked belt WORK COMPLETED. Changed and adjusted belt.	W-12-FAN-SF1-01	ME	CLOSE	CM	9/13/2011	HCLCLOUD
W-12	2011141516	DIFFERENTIAL GAUGE IS FLUCTUATING EXCESSIVELY CAUSING RED WARNING LIGHT TO COME ON AT FINE SCREEN ROOM ENTRANCES.	W-12-FAN-SF1-13	IN	APPR	CM	12/11/2011	HCLCLOUD
W-12	2011103691	fan has very loose belt WORK COMPLETED. Inspected and adjust belt.	W-12-FAN-SF2-01	ME	CLOSE	CM	9/13/2011	HCLCLOUD
W-12	2011103693	fan has loose cracked belt WORK COMPLETED. Changed and adjusted belt.	W-12-FAN-SF3-00	ME	CLOSE	CM	9/13/2011	HCLCLOUD
W-12	2011129306	Replaced belt.	W-12-FAN-SF3-01	ME	CLOSE	CM	11/16/2011	DRETONDO
W-12	2011116678	Fans differential is fluctuating excessively causing red lights on fine screen doors to come on. WORK COMPLETED. Tightened belts.	W-12-FAN-SF3-01	ME	CLOSE	CM	10/10/2011	HCLCLOUD
W-12	2011103705	the rubber boot downstream of the fan has detached itself from the shearmetal shroud Maint Note: rubber boot has been sealed up.	W-12-FAN-SF6-00	ME	WMATL	CM	9/14/2011	HCLCLOUD
W-12	2011111016	Fan EF-9 will not start. Pls fix. (no asset #)	W-12-MISC-000-00	EL	APPR	CM	9/29/2011	MFULLER
W-12	2011129167	FLUSH/REGENERATION WATER IS RUNNING CONTINUOUSLY.	W-12-OCU-002	EL	APPR	CM	11/1/2011	HCLCLOUD
W-12	2011090820	Odor control unit #2 not progressing through auto-drain cycles. Suspect logic issue. WORK COMPLETED. Corrected as needed.	W-12-OCU-002	IN	COMP	CM	8/29/2011	MFULLER
W-12	20111076434	FILL cycle does not count down and advance. stuck on "FILL MIN REMAIN 20" please repair WORK COMPLETED.	W-12-OCU-002	IN	CLOSE	CM	7/1/2011	ELARSEN

**Thickening/Dewatering Odor Scrubber Maintenance Work Orders Jul - Dec 2011**

Area	Monum	Description	Assetnum	Dept	Status	Type	Report Date	Reported By
W-30	2011090652	Scrubber #1 Hypro rotameter leaking at inlet connection. Please repair. WORK COMPLETED. Sealed pipes.	W-30-TKS-301-00	ME	CLOSE	CM	8/11/2011	DRETONDO
W-30	2011090657	Scrubber #2 Hypro rotameter leaking internally, corroded. Please repair or replace. WORK COMPLETED. Replaced rotameter.	W-30-TKS-301-00	ME	CLOSE	CM	8/12/2011	DRETONDO
W-30	2011116845	THK cabvent odor scrubber discharges excessive moisture. Please repair or remove the pH metering system. The system discharges acidic mist air. The drainage system does not function properly. Operators manually drain the system at P-Trap when moisture is excessive. The pH metering at the P-Trap has been disabled. Please inspect and determine if the monitoring system is necessary. If so, please repair. If not, please remove. Thank you.	W-30-TKS-301-00	IN	INPRG	CM	10/25/2011	MEULKERS

# Table 7 -- Digester Inspection Report

Daily inspections of digesters were performed. No venting was noted, except for the following instances:

Date	Time	Digester	Cause of venting	Duration	Comments



**Table 8 – S-48 Gasoline Dispensing Facility Throughput**

**SD-1 GASOLINE DISPENSING FACILITY**

Location 20: Maintenance Center (4,000 Gal)

As of December 31, 2011

MONTH	GALLONS RECEIVED	RECEIVED YR-TO-DATE	GALLONS ISSUED	ISSUED YR-TO-DATE	COMMENTS
JAN 11	0	0	1071	1071	Jan & Feb gallons combined
FEB 11	3109	3109	1701	2772	
MAR 11	3002	6111	3634	6406	
APR 11	1975	8086	1413	7819	
MAY 11	2300	10386	3026	10845	
JUN 11	3349	13735	2837	13682	
JUL 11	985	14720	2420	16102	
AUG 11	3279	17999	2153	18255	
SEP 11	2450	20449	2899	21154	
OCT 11	3247	23696	2423	23577	
NOV 11	1000	24696	2256	25833	
DEC 11	2000	26696	2170	28003	
FY2011		26696		28003	

**ATTACHMENT A**  
**Diesel Vendor Certifications**

# Fuel Invoice

NELLA Oil Company, LLC dba Flyers  
 2360 Lindbergh Street  
 Auburn, CA 95602  
 (530)885-0401

Invoice No: 11-629434  
 Invoice Date: Wed 07/20/2011  
 Delivery Date: Wed 07/20/2011  
 Lift Date/Time: Wed 07/20/2011 08:00 AM  
 Account ID: 15812

Remit To: NELLA Oil Company  
 Dept #34516  
 P.O. Box 39000  
 San Francisco, CA 94139-0001  
 (800)995-0401

Original

<b>Bill To:</b>	<b>Ship To:</b>
East Bay Muni Utilities Dist. P.O. Box 24055 MS#402 Attn: Accounts Payable Oakland, CA 94623-1055	ID: 11 Brookside Drive 105 Brookside Drive Richmond, CU 94801

<b>Order No:</b> 11745224	<b>Reference No.:</b>	<b>P.O. No:</b>
<b>Salesperson:</b> Diane Cone		BRD-15308-NWR

For Billing Inquiries Please Call: Jodi Lewis 800-995-0401 Ext. 2205

Description	From Site	BOL No	Gross Units	Net Units	Basis	Unit Price	Discount	Total
-------------	-----------	--------	-------------	-----------	-------	------------	----------	-------

ULSD CARB DYED # 2 DSL	317	213467	190.00	190.00	Net	3.701000		703.19
COMBUSTIBLE LIQUID. THIS PRODUCT IS DYED DIESEL FUEL. NON TAXABLE USE ONLY. PENALTY FOR TAXABLE USE. CALIFORNIA DIESEL FUEL, MAX 15 PPM SULFUR OR LESS. Dyed Motor Vehicle Fuel for use in all nonroad diesel engines. Not for use in highway vehicles or engines except for tax exempt use in accordance with section 4082 of the Internal Revenue Code.								

\*\*\*\*Tax and Other Charges Summary\*\*\*\*

Federal LUST		190.00	Net	0.001000		0.19
Federal Oil Spill Tax DSL		190.00	Net	0.001900		0.36
Ca Env Dsl		190.00	Net	0.001190		0.23
Environmental Surcharge - DSL		190.00	Net	0.001703		0.32
CA Sales Tax (Red)		<del>828.97</del>	Gross	7.2500%		60.10
Alameda County Transit Tax		828.97	Gross	1.5000%		12.43
		703.97			8.25%	58.08

\*\*\*\*Freight Summary\*\*\*\*

Service Charge						35.00
Standard Freight Hourly						90.00
					Misc w/Tax 135.81	

**ENTERED**  
 SEP 12 2011

BY: \_\_\_\_\_

<b>Invoice Total</b>	190.00	190.00	<b>\$901.82</b>
----------------------	--------	--------	-----------------

\*\*\*\*Payment Terms Summary\*\*\*\*

Due by Fri 08/19/2011 (Net 30 Days)	897.68	801.82
-------------------------------------	--------	--------

# Fuel Invoice

NELLA Oil Company, LLC dba Flyers  
 2360 Lindbergh Street  
 Auburn, CA 95602  
 (530)885-0401

Invoice No: 11-638805  
 Invoice Date: Tue 08/16/2011  
 Delivery Date: Tue 08/16/2011  
 Lift Date/Time: Tue 08/16/2011 07:35 AM  
 Account ID: 15812

Remit To: NELLA Oil Company  
 Dept #34516  
 P.O. Box 39000  
 San Francisco, CA 94139-0001  
 (800)995-0401

Original

<b>Bill To:</b>	<b>Ship To:</b>
East Bay Muni Utilities Dist. P.O. Box 24055 MS#402 Attn: Accounts Payable Oakland, CA 94623-1055	ID: 5 East Bay Muni - Wake 2020 Wake Ave. Oakland, CA 94623

<b>Order No:</b> 11756819	<b>Reference No.:</b>	<b>P.O. No:</b> BRD-09611-NPG ✓
<b>Salesperson:</b> Diane Cone		

For Billing Inquiries Please Call: Jodi Lewis 800-995-0401 Ext. 2205

Description	From Site	BOL No	Gross Units	Net Units Basis	Unit Price	Discount	Total
ULSD CARB DYED # 2 DSL	Drop	527183	7,467.00	7,467.00	Net	2.980759	22,257.33
Vendor / Terminal: Conoco Spot Contract / Conoco 78 Richmond							
COMBUSTIBLE LIQUID. THIS PRODUCT IS DYED DIESEL FUEL. NON TAXABLE USE ONLY. PENALTY FOR TAXABLE USE.							
CALIFORNIA DIESEL FUEL. MAX 15 PPM SULFUR OR LESS. Dyed Motor Vehicle Fuel for use in all nonroad diesel engines. Not for use in highway vehicles or engines except for tax exempt use in accordance with section 4082 of the Internal Revenue Code.							

\*\*\*\*Tax and Other Charges Summary\*\*\*\*

Federal LUST	7,467.00	Net	0.001000	7.47
Federal Oil Spill Tax DSL	7,467.00	Net	0.001900	14.19
Ca Env Dsl	7,467.00	Net	0.001190	8.89
Environmental Surcharge - DSL	7,467.00	Net	0.001703	12.72
CA Sales Tax (Red)	\$22,300.60	Gross	7.2500%	1,616.79
Alameda County Transit Tax	\$22,287.88	Gross	1.5000%	334.32
				1951.29

**ENTERED**

SEP 12 2011

BY: \_\_\_\_\_

<b>Invoice Total</b>	7,467.00	7,467.00	<b>\$24,251.71</b>
----------------------	----------	----------	--------------------

<b>****Payment Terms Summary****</b>	
Due by Thu 09/15/2011 (Net 30 Days)	24,251.71

**ATTACHMENT B**  
**Source Test Results**  
**S-55 Boiler, S-56 Turbine & GDF**

TABLE # 1

EBMUD  
DG TURBINE #1 (S-56)  
4000 KW

RUN	1	2	3	AVERAGE	LIMITS
Test Date	12/15/11	12/15/11	12/15/11		
Test Time	0806-0839	0852-0922	0931-1001		
Standard Temp., °F	70	70	70	70	
Turbine Kw	4,000	4,000	4,000	4,000	
Fuel Flow Rate, DSCFM	1,120.0	1,120.0	1,120.0	1,120.0	
Fuel Flow Rate, MMBtu/hr	40.2	40.2	40.2	40.2	
Fuel Flow Rate, MMBtu/365 days	352,186	352,186	352,186	352,186	389,820
Exhaust Flow Rate, DSCFM (Method 19)	29,960	27,512	27,512	28,328	
Oxygen, O <sub>2</sub> , %	16.6	16.2	16.2	16.3	
Carbon Dioxide, CO <sub>2</sub> , %	3.7	3.7	3.7	3.7	
NOx, ppm	6.2	6.1	6.1	6.1	
NOx, ppm @ 15% O <sub>2</sub>	8.5	7.6	7.7	7.9	23
NOx, lbs/hr	1.33	1.19	1.19	1.24	
NOx, lbs/MMBtu	0.033	0.030	0.030	0.031	
CO, ppm	<5.0	<5.0	<5.0	<5.0	
CO, ppm @ 15% O <sub>2</sub>	<6.9	<6.3	<6.3	<6.5	100
CO, lbs/hr	<0.7	<0.6	<0.6	<0.6	
CO, lbs/MMBtu	<0.016	<0.015	<0.015	<0.015	
SO <sub>2</sub> , ppm	<2.0	<2.0	<2.0	<2.0	
SO <sub>2</sub> , ppm @ 15% O <sub>2</sub>	<2.7	<2.5	<2.5	<2.6	150
SO <sub>2</sub> , lbs/hr	<0.6	<0.5	<0.5	<0.6	
SO <sub>2</sub> , lbs/MMBtu	<0.015	<0.014	<0.014	<0.014	
THC, ppm	<2.0	<2.0	<2.0	<2.0	
THC, lbs/hr as CH <sub>4</sub>	<0.1	<0.1	<0.1	<0.1	
CH <sub>4</sub> , ppm	<2.0	<2.0	<2.0	<2.0	
TNMHC, ppm as CH <sub>4</sub>	<2.0	<2.0	<2.0	<2.0	
TNMHC, ppm @ 15% O <sub>2</sub>	<2.7	<2.5	<2.5	<2.6	
TNMHC, lbs/hr as CH <sub>4</sub>	<0.15	<0.14	<0.14	<0.14	
TNMHC, lbs/MMBtu as CH <sub>4</sub>	<0.004	<0.003	<0.003	<0.003	

WHERE,

ppm = Parts Per Million Concentration  
 Lbs/hr = Pound Per Hour Emission Rate  
 Tstd. = Standard Temp. (°R = °F + 460)  
 MW = Molecular Weight  
 DSCFM = Dry Standard Cubic Feet Per Minute  
 NOx = Oxides of Nitrogen as NO<sub>2</sub> (MW = 46)  
 CO = Carbon Monoxide (MW = 28)  
 THC = Total Hydrocarbons as Methane (MW = 16)  
 TNMHC = Total Non-Methane Hydrocarbons as Methane (MW = 16)  
 SO<sub>2</sub> = Sulfur Dioxide (MW=64.1)

CALCULATIONS,

PPM @ 15% O<sub>2</sub> = ppm \* 5.9 / (20.9 - %O<sub>2</sub>)  
 PPM @ 3% O<sub>2</sub> = ppm \* 17.9 / (20.9 - %O<sub>2</sub>)  
 Lbs/hr = ppm x 8.223 E-05 x DSCFM x MW / Tstd. °R  
 Lbs/day = Lbs/hr \* 24  
 Lbs/MMBtu = Lbs-hr / MMBtu-hr  
 MMBtu/yr = Tested Rate MMBtu/hr \* 24hrs \* 365 days

TABLE #1

EBMUD  
Boiler  
Mid Load Setting

TEST	1	2	3	AVERAGE	LIMITS
Test Location	Outlet	Outlet	Outlet		
Test Date	11/22/11	11/22/11	11/22/11		
Test Condition	0840-0909	0918-0947	0959-1030		
Standard Temp., °F	70	70	70		
Boiler Rating, MMBtu/Hr	20.41	20.41	20.41		
Boiler Fire Rate, MMBtu/Hr	17.5	17.4	17.4		
Firing Rate	86%	85%	85%		
Flow Rate, DSCFM (M19)	5,186	5,071	5,082	5,113	
O <sub>2</sub> , %	9.9	9.7	9.7	9.8	
NO <sub>x</sub> , ppm	16.5	16.5	17.6	16.9	
NO <sub>x</sub> , ppm @ 3% O <sub>2</sub>	27.0	26.3	28.2	27.1	30
NO <sub>x</sub> , lbs/MMBtu	0.033	0.032	0.034	0.033	
NO <sub>x</sub> , lbs/hr	0.61	0.60	0.64	0.62	
CO, ppm	<5.0	<5.0	<5.0	<5.0	
CO, ppm @ 3% O <sub>2</sub>	<8.2	<8.0	<8.0	<8.0	50
CO, lbs/MMBtu	<0.006	<0.006	<0.006	<0.006	
CO, lbs/hr	<0.113	<0.110	<0.110	<0.111	

WHERE,

NO<sub>x</sub> = Oxides of Nitrogen as NO<sub>2</sub> (MW = 46)

CO = Carbon Monoxide (MW = 28)

ppm = Parts Per Million Concentration

CALCULATIONS,

$$3\%O_2 \text{ correction} = \text{ppm (NO}_x, \text{CO)} * 17.95 / (20.95 - \%O_2)$$

**SUMMARY OF SOURCE TEST DATA**

SOURCE INFORMATION		FACILITY PARAMETERS	
GDF Name and Address <b>EBMUD</b> <b>2020 Wake Ave.</b> <b>Oakland, CA</b>	GDF Representative and Title <b>Cynthia Adkisson</b>  GDF Phone No. <b>510-287-1627</b>	PHASE II SYSTEM TYPE (Check One)	
Permit Conditions	Source; GDF Vapor Recovery System	Balance	_____
	GDF # _____ A/C # _____	Hirt	_____
		Red Jacket	_____
		Hasstech	_____
		Healy	_____
		Other	<b>x</b>
		Manifolded?	_____ Yes <b>x</b> No
Operating Parameters			
Number of Nozzles Served by Tank #1	<u>2</u>	Number of Nozzles Served by Tank #3	_____
Number of Nozzles Served by Tank #2	_____	Number of Nozzles Served by Tank #4	_____
Applicable Regulations:		VN Recommended	
Source Test Results and Comments			
<b>Tank #:</b>		<b>1</b>	<b>2</b>
		<b>3</b>	<b>4</b>
1. Product Grade		<b>87</b>	_____
2. Actual Tank Capacity, gallons		<b>3,000</b>	_____
3. Gasoline Volume		<b>755</b>	_____
4. Ullage, gallons (#2-#3)		<b>2,245</b>	_____
5. Initial Pressure, inches H2O		<b>2.00</b>	_____
6. Pressure After 1 Minute, inches H2O		<b>1.98</b>	_____
7. Pressure After 2 Minutes, inches H2O		<b>1.95</b>	_____
8. Pressure After 3 Minutes, inches H2O		<b>1.94</b>	_____
9. Pressure After 4 Minutes, inches H2O		<b>1.93</b>	_____
10. Final Pressure After 5 Minutes, inches H2O		<b>1.94</b>	_____
11. Allowable Final Pressure		<b>1.42</b>	_____
Test Conducted by: <b>Brian Gan</b>	Test Company: <b>Gettler-Ryan Inc.</b>	Date of Test: <b>10/10/2011</b>	



## **ATTACHMENT C**

### **Wastewater Treatment Plant Flow Summary**

# East Bay Municipal Utility District MONTHLY/ANNUAL WASTEWATER SUMMARY 2011

STATION: WWTP EFFLUENT (EFF) E-001 (except designated influent TSS and CBOD values were collected at A-001)

## CONVENTIONAL POLLUTANTS & FLOW

EFFLUENT FLOW (mgd)	CBOD										TSS						Oil and Grease				
	Max		Min		3-mo		Inf (A-001) mg/L	Eff mg/L	Eff Max mg/L	# exc/ # of Analyses	% Removal	Inf (A-001) mg/L	Eff mg/L	Eff Max mg/L	# exc/ # of Analyses	% Removal	Eff mg/L	Eff mg/L	# exc/ # of Analyses		
	Avg	Daily	Avg	Daily	Avg	Avg														Month	Month
<b>Limits:</b>								<b>25</b>	<b>40</b>				<b>30</b>	<b>45</b>		<b>Min 85(a)</b>	<b>10</b>	<b>20</b>			
Jan	72	108	60	68	68	248	9	10	0/4	0/1	96%	288	13	15	0/4	0/1	95%	< 7	< 7		
Feb	89	181	57	75	75	279	14	20	0/4	0/1	95%	292	16	19	0/4	0/1	93%	< 7	< 7		
Mar	110	225	69	84	84	219	10	12	0/5	0/1	94%	230	15	15	0/5	0/1	91%				
Apr	69	82	59	89	89	314	12	14	0/4	0/1	96%	294	11	12	0/4	0/1	96%				
May	63	77	63	81	81	321	16	20	0/4	0/1	95%	290	14	17	0/4	0/1	95%				
Jun	63	108	53	65	65	287	9	19	0/4	0/1	97%	296	11	13	0/4	0/1	96%				
Jul	57	66	52	61	61	296	8	10	0/4	0/1	97%	286	11	13	0/4	0/1	96%				
Aug	57	62	52	59	59	344	9	9	0/4	0/1	97%	361	15	16	0/4	0/1	96%				
Sep	55	61	52	57	57	374	15	25	0/5	0/1	96%	365	18	23	0/5	0/1	95%				
Oct	57	79	39	56	56	328	11	16	0/4	0/1	97%	346	14	14	0/4	0/1	96%				
Nov	59	75	51	57	57	372	9	13	0/5	0/1	98%	329	11	16	0/5	0/1	97%				
Dec	54	57	48	57	57	388	11	18	0/4	0/1	97%	454	14	20	0/4	0/1	97%				
<b>Avg</b>	67	98	55	67	67	314	11	16			96%	319	14	16			95%	<7.0	<7.0		
<b>Max</b>	110	225	69	89	89	388	16	25			98%	454	18	23			97%	7.0	7.0		
<b>Min</b>	54	57	39	56	56	219	8	9			94%	230	11	12			91%	7.0	7.0		
<b>Exc/Analyses</b>							0/12	0/52			0/12		0/12	0/52			0/12	0/4	0/4		

V/A = number of exceedances/number of analyses

**ATTACHMENT D**  
**Hours of flare use**

# EBMUD Main Wastewater Plant Flare and Boiler Operation Summary

July 1 - December 31, 2011

Usage	Flare #1	Flare #2	Flare #3	Flare #4	Total	July	Aug	Sept	Oct	Nov	Dec	Semi-annual Totals
Run Time	Flare #1	Flare #2	Flare #3	Flare #4	Total	251	346	577	600	330	393	2,497
	hrs	hrs	hrs	hrs	hrs	333	510	532	630	375	578	2,958
	meter	meter	meter	meter	meter	340	476	572	547	387	544	2,866
	meter	meter	meter	meter	meter	274	91	372	473	207	430	1,847
	hrs	hrs	hrs	hrs	hrs	1,198	1,423	2,053	2,250	1,299	1,945	10,168
Heat Value	Average	Flare #1	Flare #2	Flare #3	Flare #4	6,763	6,309	6,874	6,339	6,151	6,041	10,168
	cf/hr	cf	cf	cf	cf	1,708,387	3,464,413	10,765,012	10,795,460	6,599,183	8,201,573	41,534,028
	meter	meter	meter	meter	meter	2,322,118	7,072,278	12,225,005	12,503,461	4,707,320	18,568,617	57,398,799
	meter	meter	meter	meter	meter	2,989,500	4,907,180	8,356,319	7,914,774	4,811,472	12,786,458	41,765,703
	cf	cf	cf	cf	cf	2,112,720	524,665	6,015,638	6,094,462	597,417	8,902,172	24,247,074
Digester Gas	Total	Flare #1	Flare #2	Flare #3	Flare #4	9,132,725	15,968,536	37,361,974	37,308,157	16,715,392	48,458,820	164,945,604
	cf	cf/hr	cf/hr	cf/hr	cf/hr	6,806	10,013	18,657	17,992	19,998	20,869	122,000
	meter	meter	meter	meter	meter	16,199,763	13,867,767	22,979,911	19,847,767	12,553,767	32,126,767	122,000
	meter	meter	meter	meter	meter	18,793,931	10,309,309	14,609,309	14,469,309	12,433,309	23,505,309	122,000
	cf/hr	cf/hr	cf/hr	cf/hr	cf/hr	4,6	6,3	12,8	11,5	12,3	12,6	X
Run Time	Flare #1	Flare #2	Flare #3	Flare #4	Total	4.6	8.7	15.8	12.7	7.7	19.4	X
	mmBTU/hr	mmBTU/hr	mmBTU/hr	mmBTU/hr	mmBTU/hr	4.7	6.5	10.0	9.3	7.6	14.2	X
	meter	meter	meter	meter	meter	5.2	3.6	11.1	8.2	1.8	12.5	X
	meter	meter	meter	meter	meter	283	264	619	302	193	541	2,200
	meter	meter	meter	meter	meter	4,153,302	4,074,186	9,789,832	3,872,568	2,892,934	8,138,919	32,921,741
Digester Gas	Boiler	Boiler										
	mmBTU/hr	mmBTU/hr	4	9.9	9.7	10.9	8.2	9.2	9.1	X		

(1) Calculated value: Monthly Total Flare Operation (hours) = Sum of individual meter readings (hours)  
 (2) Calculated value: Monthly Total Flare Usage (cf) = Sum of individual meter readings (cf)  
 (3) Calculated value: Average cf/hr = Monthly usage (cf) / Monthly Operation (hours)  
 (4) Calculated value: Digester gas thruput (mmBTU/hr) = digester gas thruput (cf/hr) x monthly gas sample (Btu/cf) / 1,000,000



Month:

July - 2011

SD1 Flare Burners

# Daily Data for Air Permit

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	214,118	236,427	145,686	176,904	773,135	23	23	23	23	93
2	116,874	179,170	102,645	113,196	511,885	12	20	18	16	66
3	0	7,378	4,698	0	12,076	0	1	1	0	3
4	8,650	44,047	22,992	16,790	92,479	2	8	7	4	21
5	1,320	62,212	74,511	72,804	210,847	0	10	10	5	25
6	179,031	104,630	917,997	847,831	2,049,489	12	13	24	24	72
7	106,100	100,724	199,910	160,458	567,192	15	15	24	24	77
8	119,644	127,064	97,852	58,363	402,923	20	23	21	14	78
9	0	55,375	118,965	84,725	259,065	0	10	15	14	38
10	0	12,036	10,435	0	22,471	0	3	4	0	7
11	136,959	138,059	106,908	74,232	456,158	16	13	8	8	45
12	42,101	40,265	44,441	25,372	152,179	15	10	9	11	46
13	18,222	35,639	62,949	45,511	162,321	4	10	9	9	33
14	126,990	132,836	102,750	64,047	426,623	21	22	21	22	86
15	115,475	136,655	98,503	40,938	391,571	16	19	16	13	63
16	0	0	75,193	50,688	125,881	0	0	7	11	18
17	69,900	74,006	76,801	34,394	255,101	13	13	14	12	52
18	0	39,513	33,447	7,635	80,595	0	5	9	2	16
19	2,518	10,704	5,769	0	18,991	0	2	2	0	4
20	33,520	46,143	25,464	5,491	110,618	7	9	7	2	25
21	0	5,699	2,220	0	7,919	0	1	1	0	2
22	0	46,919	152,391	83,787	283,097	0	5	12	11	29
23	0	0	37,388	18,287	55,675	0	0	5	4	9
24	8,111	110,754	103,450	44,131	266,446	1	15	14	12	41
25	125,891	159,247	128,658	49,413	463,209	16	18	18	15	67
26	45,748	121,914	93,006	21,575	282,243	7	16	14	7	44
27	35,833	39,049	13,459	3,853	92,194	7	7	2	1	17
28	20,692	24,775	2,185	0	47,652	6	6	0	0	12
29	77,512	90,448	51,678	4,848	224,486	14	14	11	4	44
30	85,555	100,414	54,373	5,304	245,646	16	16	11	4	47
31	17,623	40,016	22,776	2,143	82,558	7	6	4	2	19
Totals	1,708,387	2,322,118	2,989,500	2,112,720	9,132,725	251	333	340	274	1,197
			Sum of Flares	9,132,725			Sum of Flares	1,198		



Month: August - 2011

SD1 Flare Burners

# Daily Data for Air Permit

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	0	159,182	255,270	68,131	482,583	0	14	19	10	43
2	232,974	436,489	315,796	125,570	1,110,829	15	18	18	13	65
3	182,423	170,919	167,689	40,554	561,585	20	13	14	11	57
4	184,178	219,026	134,913	54,366	592,483	16	15	12	5	49
5	143,157	155,683	91,823	2,579	393,242	19	19	15	2	55
6	72,253	76,690	45,540	0	194,483	13	13	13	1	38
7	69,021	78,513	46,610	1,295	195,439	9	10	9	1	29
8	184,672	212,798	145,557	5,577	548,604	20	20	15	5	60
9	63,804	70,070	35,834	0	169,708	15	12	8	0	35
10	63,534	71,443	25,798	0	160,775	15	13	7	0	34
11	84,370	230,332	163,659	0	478,361	11	22	22	1	56
12	0	202,457	155,913	0	358,370	0	19	19	0	39
13	0	519,161	496,137	103,372	1,118,670	0	21	23	9	53
14	0	73,519	51,948	0	125,467	0	12	10	0	21
15	199,735	400,699	285,318	14,144	899,896	11	18	18	7	54
16	292,523	489,999	302,751	32,572	1,117,845	18	23	21	5	68
17	71,745	333,004	173,452	0	578,201	9	21	21	1	52
18	102,655	339,012	175,445	2,645	619,757	13	20	17	6	57
19	0	457,345	268,539	0	725,884	0	20	20	0	41
20	0	82,085	42,897	0	124,982	0	14	7	0	20
21	37,863	95,887	76,920	0	210,670	5	11	10	0	26
22	204,873	253,503	141,938	0	600,314	22	22	21	0	65
23	193,877	304,718	160,385	0	658,980	18	22	20	0	59
24	101,816	217,509	119,914	0	439,239	12	20	19	0	51
25	117,676	128,196	70,376	0	316,248	17	16	14	0	47
26	80,167	229,214	114,777	2,237	426,395	11	19	17	1	47
27	11,999	13,484	129,525	8,458	163,466	2	3	8	3	15
28	0	0	0	0	0	0	0	0	0	0
29	398,135	487,571	318,597	17,854	1,222,157	19	19	19	5	62
30	218,525	264,390	180,437	1,432	664,784	22	22	22	1	66
31	152,438	299,380	213,422	43,879	709,119	14	20	20	5	60
<b>Totals</b>	<b>3,464,413</b>	<b>7,072,278</b>	<b>4,907,180</b>	<b>524,665</b>	<b>15,968,536</b>	<b>346</b>	<b>510</b>	<b>476</b>	<b>91</b>	<b>1,424</b>

Sum of Flares 15,968,536

Sum of Flares 1,423



Month:

September - 2011

SD1 Flare Burners

# Daily Data for Air Permit

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	85,519	219,532	166,744	1,016	472,811	10	20	18	0	49
2	277,148	335,632	257,156	2,437	872,373	22	23	22	1	68
3	431,082	448,003	300,218	9,716	1,189,019	21	22	20	11	74
4	2,981	3,223	1,566	0	7,770	0	0	0	0	1
5	109,373	122,624	59,698	0	291,695	15	18	18	0	52
6	149,149	197,851	140,340	23,255	510,595	15	18	15	3	50
7	736,105	837,190	533,632	0	2,106,927	24	24	24	0	72
8	604,753	592,800	338,920	22,657	1,559,130	24	21	17	2	65
9	325,750	36,030	275,739	53,484	691,003	20	6	21	12	59
10	334,091	0	260,477	0	594,568	20	0	20	0	40
11	77,634	50,286	62,383	10,779	201,082	9	5	8	1	23
12	312,559	338,538	225,237	59,816	936,150	23	23	20	7	73
13	345,167	399,963	234,642	43,878	1,023,650	22	22	20	5	69
14	592,933	779,359	441,320	3,322	1,816,934	24	24	24	2	74
15	396,529	442,762	273,494	156,835	1,269,620	23	23	23	15	84
16	331,213	309,444	190,137	228,988	1,059,782	24	24	23	24	95
17	188,459	192,536	532,589	101,697	1,015,281	10	10	23	13	56
18	0	0	217,477	0	217,477	0	0	12	0	12
19	221,927	195,450	136,152	181,542	735,071	13	11	12	12	48
20	417,914	391,795	293,236	320,717	1,423,662	24	23	21	24	92
21	327,933	367,949	175,480	216,132	1,087,494	23	24	19	24	90
22	387,269	520,948	246,624	319,203	1,474,044	22	22	20	24	89
23	416,763	652,634	264,437	327,171	1,661,005	24	24	23	24	94
24	402,232	704,178	222,494	315,403	1,644,307	24	24	21	24	93
25	198,958	24,580	70,050	140,223	433,811	21	4	9	24	58
26	353,711	479,965	222,848	295,629	1,352,153	24	24	22	24	94
27	717,378	1,304,251	522,006	1,106,164	3,649,799	24	24	22	24	94
28	869,585	1,018,398	761,195	1,024,508	3,673,686	24	21	24	24	93
29	620,993	708,159	503,826	573,005	2,405,983	24	24	24	24	96
30	529,904	550,925	426,202	478,061	1,985,092	24	24	24	24	96
Totals	10,765,012	12,225,005	8,356,319	6,015,638	37,361,974	577	532	572	372	2,053

Sum of Flares 37,361,974

Sum of Flares 2,053



Month: October - 2011

# Daily Data for Air Permit

SD1 Flare Burners

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	422,335	430,473	330,962	388,416	1,572,186	24	24	23	24	95
2	205,535	170,862	18,659	147,416	542,472	23	23	7	24	77
3	258,187	230,924	150,822	253,787	893,720	21	21	13	23	78
4	469,312	557,841	382,397	597,961	2,007,511	24	24	24	24	96
5	783,607	1,183,463	640,620	1,309,843	3,917,533	24	24	24	24	96
6	744,963	1,085,138	658,620	1,042,343	3,531,064	24	24	24	24	96
7	484,357	627,779	460,246	537,406	2,109,788	24	24	23	24	95
8	291,652	324,693	227,313	271,262	1,114,920	22	22	16	24	85
9	138,337	123,499	14,657	111,757	388,250	19	17	4	23	63
10	227,661	220,124	109,903	221,530	779,218	23	22	14	24	84
11	318,000	338,986	207,824	312,860	1,177,670	24	24	20	24	92
12	252,127	260,134	54,902	241,497	808,660	24	24	8	24	80
13	391,179	441,274	261,148	387,602	1,481,203	22	17	15	23	78
14	740,091	374,233	529,633	32,479	1,676,436	24	16	24	11	75
15	186,131	158,320	162,797	22,598	529,846	15	17	17	10	60
16	0	77,059	117,513	1,228	195,800	0	12	14	2	28
17	156,156	153,307	252,983	1,358	563,804	12	15	21	4	53
18	977,750	990,273	511,284	0	2,479,307	24	24	24	2	74
19	669,512	668,289	427,336	0	1,765,137	24	24	24	0	72
20	216,956	183,726	134,259	0	534,941	20	19	16	1	56
21	437,131	386,487	280,808	0	1,104,426	23	23	20	0	65
22	330,689	335,630	182,021	0	848,340	19	20	16	0	54
23	150,335	172,636	103,393	0	426,364	17	16	12	0	45
24	290,034	577,367	186,383	13,850	1,067,634	17	21	16	12	65
25	150,498	678,620	395,095	34,883	1,259,096	12	22	22	23	80
26	242,643	415,318	183,408	33,982	875,351	21	23	21	24	88
27	361,030	489,570	253,891	59,218	1,163,709	20	23	19	23	84
28	361,343	326,631	281,408	30,553	999,935	18	16	18	17	69
29	124,817	127,636	109,968	13,710	376,131	11	16	15	11	53
30	61,769	73,287	60,353	11,408	206,817	8	11	10	10	39
31	351,323	319,882	224,168	15,515	910,888	20	22	20	13	75
<b>Totals</b>	<b>10,795,460</b>	<b>12,503,461</b>	<b>7,914,774</b>	<b>6,094,462</b>	<b>37,308,157</b>	<b>600</b>	<b>630</b>	<b>547</b>	<b>473</b>	<b>2,250</b>

Sum of Flares 37,308,157

Sum of Flares 2,250





Month: November - 2011

# Daily Data for Air Permit

SD1 Flare Burners

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	437,558	364,085	232,021	21,480	1,055,144	15	13	10	16	55
2	63,858	57,658	39,834	15,951	177,301	8	7	6	15	37
3	456,043	8,682	347,660	87,762	900,147	11	0	10	17	38
4	1,349,947	0	12,815	74,588	1,437,350	24	0	0	20	44
5	822,396	0	6,548	43,806	872,750	18	0	0	13	30
6	346,953	54,000	121,102	56,787	578,842	14	0	3	5	22
7	211,539	25,315	41,130	19,336	297,320	13	2	3	8	25
8	262,584	247,839	199,154	51,284	760,861	13	16	15	18	63
9	178,793	167,709	152,404	21,242	520,148	22	22	18	18	80
10	620,905	744,200	492,449	31,131	1,888,685	24	24	24	9	80
11	150,756	223,624	170,531	0	544,911	11	18	18	1	48
12	12,171	152,609	123,940	0	288,720	1	14	16	0	31
13	0	53,226	47,055	0	100,281	0	10	9	0	19
14	0	212,828	163,032	0	375,860	0	16	19	0	35
15	114,795	220,650	165,968	1,667	503,080	10	17	16	1	44
16	123,608	187,000	202,449	26,340	539,397	9	18	16	12	56
17	259,778	237,778	231,295	9,743	738,594	19	18	18	9	64
18	0	71,188	65,390	1,943	138,521	0	14	14	4	31
19	5,869	74,482	68,378	5,335	154,064	2	13	13	9	37
20	0	77,947	74,251	2,265	154,463	0	13	12	3	28
21	8,102	144,579	134,578	10,343	297,602	1	15	14	7	37
22	135,936	254,711	429,320	109,153	929,120	6	11	19	9	45
23	44,101	78,382	216,784	2,319	341,586	7	9	12	4	31
24	73,034	63,877	76,693	0	213,604	5	5	5	0	15
25	63,106	53,420	69,468	1,185	187,179	4	4	4	5	16
26	289,980	265,524	306,485	2,012	864,001	23	23	23	5	73
27	129,664	127,566	106,084	0	363,314	20	20	20	0	60
28	134,566	130,743	125,989	0	391,298	18	18	18	0	54
29	240,217	235,700	240,104	0	716,021	23	23	22	0	68
30	62,924	171,998	148,561	1,745	385,228	9	12	11	1	33
<b>Totals</b>	<b>6,599,183</b>	<b>4,707,320</b>	<b>4,811,472</b>	<b>597,417</b>	<b>16,715,392</b>	<b>330</b>	<b>375</b>	<b>387</b>	<b>207</b>	<b>1,299</b>
					Sum of Flares					Sum of Flares
					16,715,392					1,299



Month: December - 2011

# Daily Data for Air Permit

SD1 Flare Burners

Date	Biogas Used				Total Flow	Hours of Operation				Total Hrs
	Flare 1	Flare 2	Flare 3	Flare 4		Flare 1	Flare 2	Flare 3	Flare 4	
1	0	87,346	84,783	0	172,129	0	11	11	0	22
2	0	31,281	28,636	0	59,917	0	6	5	0	11
3	14,681	61,548	58,808	0	135,037	2	9	9	0	20
4	84,675	80,447	67,448	0	232,570	13	12	11	0	36
5	50,114	44,487	36,238	0	130,839	13	11	14	0	38
6	489,812	690,301	631,292	104,559	1,915,964	23	24	24	10	81
7	657,767	931,610	867,108	15,684	2,472,169	24	23	24	12	83
8	516,329	732,154	303,819	11,454	1,563,756	21	21	10	9	62
9	496,425	584,934	412,486	20,995	1,514,840	18	21	12	10	60
10	332,028	596,790	1,923	0	930,741	14	19	0	0	33
11	0	62,750	0	0	62,750	0	9	0	0	9
12	0	15,873	67,970	0	83,843	0	2	5	0	7
13	0	179,463	436,542	0	616,005	0	7	19	0	27
14	421,274	696,335	526,059	115,267	1,758,935	16	18	21	16	71
15	221,956	936,326	766,032	596,984	2,521,298	13	24	24	24	85
16	0	1,434,533	1,311,593	1,231,704	3,977,830	0	24	24	24	72
17	0	1,009,747	676,082	649,127	2,334,956	0	24	24	24	72
18	0	268,060	213,998	146,126	628,184	0	24	23	18	65
19	1,882	874,262	495,762	89,636	1,461,542	0	23	22	8	53
20	193,769	1,268,012	1,024,170	328,099	2,814,050	10	24	24	24	82
21	737,745	1,072,584	918,574	718,258	3,447,161	24	24	24	24	96
22	389,680	751,472	423,378	434,374	1,998,904	24	24	24	24	96
23	428,433	913,563	437,932	565,718	2,345,646	24	24	24	24	96
24	505,436	1,035,131	461,151	735,653	2,737,371	24	24	24	24	96
25	98,302	92,235	57,238	81,558	329,333	23	18	16	21	80
26	0	77,343	42,126	18,636	138,105	1	13	12	17	43
27	80,722	214,434	139,006	142,559	576,721	9	20	19	22	69
28	631,508	786,508	612,467	692,348	2,722,831	24	24	22	24	93
29	392,312	544,915	355,406	363,214	1,655,847	24	24	24	24	96
30	636,263	1,197,453	565,142	822,534	3,221,392	24	24	24	24	96
31	820,460	1,296,720	763,289	1,017,685	3,898,154	24	24	24	24	96
<b>Totals</b>	<b>8,201,573</b>	<b>18,568,617</b>	<b>12,786,458</b>	<b>8,902,172</b>	<b>48,458,820</b>	<b>393</b>	<b>578</b>	<b>544</b>	<b>430</b>	<b>1,944</b>
	Sum of Flares				<b>48,458,820</b>	Sum of Flares				<b>1,945</b>

**ATTACHMENT E**

**Response to NOV A75066 for Digester Gas Hydrogen Sulfide  
Exceedance on August 8, 2011**

August 22, 2011

Brian Bateman  
Director of Compliance and Enforcement  
Bay Area Air Quality Management District  
939 Ellis Street  
San Francisco, CA 94109

Dear Mr. Bateman:

RE: Response to Notice of Violation (NOV) No. A50766 and Follow-Up Report  
Regarding Compliance with Permit Condition #20651, Major Facility Review Permit  
for Facility #A0591 for RCA Reference Numbers 06B13

East Bay Municipal Utility District's (EBMUD) Main Wastewater Treatment Plant (Facility  
~~#0591) received a NOV (No. A50766) from Bay Area Air Quality Management District~~  
~~(BAAQMD) inspector Scott Applin on August 16, 2011 for non-compliance with permit~~  
condition #18860-3 of the Permit to Operate and Major Facility Review permit for Plant  
#A0591.

In accordance with Standard Condition I.F of East Bay Municipal Utility District's  
(EBMUD) Main Wastewater Treatment Plant (Facility #A0591) Major Facility Review  
Permit, EBMUD submits this report regarding compliance with permit condition #18860,  
part 3 of which limits total sulfur content of the gaseous feed to Engine S-38 of 340  
ppmv. Compliance with this permit condition is to be demonstrated by sampling the  
digester gas generated in S-180 Anaerobic Digesters for hydrogen sulfide (H<sub>2</sub>S).  
EBMUD controls the level of H<sub>2</sub>S in the digester gas by the addition of Ferric Chloride.

On Monday, August 8, 2011 at 1915 hours the H<sub>2</sub>S level in the digester gas common  
manifold was measured at 444 ppmv and returned to compliance on Tuesday August 9,  
2011 the digester gas was measured at approximately 276 ppmv. A Reportable  
Compliance Activity Form was faxed to your office on August 11, 2011 and was  
assigned Reference #06B13.

The root cause of the exceedance was insufficient addition Ferric Chloride during the  
transition to a new ferric chloride feed system at the primary sedimentation basins. The  
transition process involved increasing ferric flow to the new system and steadily  
decreasing flow to the old system. On Saturday August 6<sup>th</sup> ferric flow the District  
transitioned from the old system to supply ferric feed only using the new system. During  
the afternoon on August 8, 2011 the flow from the new system was not sufficient for the  
digester gas to meet the H<sub>2</sub>S permit limit. Upon discovery of the exceedance, Ferric flow


Brian Bateman  
August 22, 2011  
Page 2.

was re-established using the previous system, in addition to maintaining flow from the new system.

The District will continue to use both ferric systems until testing confirms the new system is meeting the permit limit.

If you need further information on this matter please contact Robert Newman at (510)-287-0509.

Sincerely,



DAVID R. WILLIAMS  
Director of Wastewater

DRW:RDN:kf

w:\ops\wtd - admin\regulatory compliance\wwtp\air compliance\2011\wrt11\_094.0.doc

---

August 12, 2011

Brian Bateman  
Director of Compliance and Enforcement  
Bay Area Air Quality Management District  
939 Ellis Street  
San Francisco, CA 94109

Dear Mr. Bateman:

RE: 10-Day and 30-Day Report Regarding Compliance with Permit Condition #20651,  
Major Facility Review Permit for Facility #A0591 for RCA Reference Numbers  
06B13

In accordance with Standard Condition I.F of East Bay Municipal Utility District's  
(EBMUD) Main Wastewater Treatment Plant (Facility #A0591) Major Facility Review  
Permit, EBMUD submits this report regarding compliance with permit condition #18860,  
part 3 of which limits total sulfur content of the gaseous feed to Engine S-38 of 340  
ppmv. Compliance with this permit condition is to be demonstrated by sampling the  
digester gas generated in S-180 Anaerobic Digesters for hydrogen sulfide (H<sub>2</sub>S).  
EBMUD controls the level of H<sub>2</sub>S in the digester gas by the addition of Ferric Chloride.


On Monday, August 8, 2011 at 1915 hours the H<sub>2</sub>S level in the digester gas common  
manifold was measured at 444 ppmv and returned to compliance on Tuesday August 9,  
2011 the digester gas was measured at approximately 276 ppmv. A Reportable  
Compliance Activity Form was faxed to your office on August 11, 2011 and was  
assigned Reference #06B13.

The root cause of the exceedance was insufficient addition Ferric Chloride during the  
transition to a new ferric chloride feed system at the primary sedimentation basins. The  
transition process involved increasing ferric flow to the new system and steadily  
decreasing flow to the old system. On Saturday August 6<sup>th</sup> ferric flow the District  
transitioned from the old system to supply ferric feed only using the new system. During  
the afternoon on August 8, 2011 the flow from the new system was not sufficient for the  
digester gas to meet the H<sub>2</sub>S permit limit. Upon discovery of the exceedance, Ferric flow  
was reestablished using the previous system, in addition to maintaining flow from the  
new system.

The District will continue to use both ferric systems until testing confirms the new system  
is meeting the permit limit.

If you need further information on this matter please contact Robert Newman at (510)-  
287-0509

Sincerely!




DAVID R. WILLIAMS  
Director of Wastewater

DRW:RDN:rdn

K:\WTD - Admin\Regulatory Compliance\MWWTP Air Compliance 2011\111\_0510.doc

---

Chart of Ferric Feed and H2S Common Digester Reading During Transition  
 From TWAS Fed Ferric to Primary Fed Ferric







BAY AREA AIR QUALITY MANAGEMENT DISTRICT  
 939 ELLIS STREET · SAN FRANCISCO, CA 94109  
 (415) 749-4795

**NOTICE OF VIOLATION**

No. 1537

ISSUED TO: REMEDIATION  P  G  H# 11  
 ADDRESS: 7000 ...  
 CITY: San Francisco STATE: CA ZIP: 94117  
 PHONE: (415) 327-...  
 H# Mailing Address on F51

**OCCURRENCE**  
 NAME: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  Same As Above  
 CITY: \_\_\_\_\_ ZIP: \_\_\_\_\_  
 SOURCE: S# 120 NAME: Industrial Dry Cleaning  
 EMISSION PT: P# \_\_\_\_\_ NAME: \_\_\_\_\_  
 DATE: 7/2/2011 TIME: 19:15 HRS

<input type="checkbox"/> REG 2 RULE 1 SEC 301 No Authority to Construct	<input type="checkbox"/> REG 2 RULE 1 SEC 301 No Permit to Operate
<input checked="" type="checkbox"/> REG 1 SEC 301 H & S CODE - 41700 Public Nuisance	<input type="checkbox"/> REG 2 RULE 1 SEC 307 Failure to Meet Permit Condition
<input type="checkbox"/> REG 5 SEC 301 Prohibited Open Burning	<input type="checkbox"/> REG 6 SEC 301 Excessive Visible Emissions
<input checked="" type="checkbox"/> REG <u>2</u> RULE <u>6</u> SECTION <u>307</u> CODE _____	<input type="checkbox"/> REG _____ RULE _____ SECTION _____ CODE _____

Details: RCA# 06B13 - PIC# 18260-3 - H2S 444 ppm

RECIPIENT NAME: Robert Newman  
 TITLE: Senior Env + Safety Specialist

SIGNING THIS NOTICE IS NOT AN ADMISSION OF GUILT  SIGNATURE [Signature]

→ WITHIN 10 DAYS, RETURN A COPY OF THIS NOTICE WITH A WRITTEN DESCRIPTION OF THE IMMEDIATE CORRECTIVE ACTION YOU HAVE TAKEN TO PREVENT CONTINUED OR RECURRENT VIOLATION. **THIS VIOLATION IS SUBJECT TO SUBSTANTIAL PENALTY.** YOUR RESPONSE DOES NOT PRECLUDE FURTHER LEGAL ACTION.

ISSUED BY: [Signature] INSP # 4300  
 DATE: 7/13/2011 TIME: 10:50 HRS  MAILED

PLEASE PRESS HARD

Continued On Reverse