



Certified Mail, Return Receipt Requested

RECEIVED

2012 JUL 31 AM 11 04

BAY AREA AIR QUALITY
MANAGEMENT DISTRICT

July 30, 2012

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

Attn: Title V Reports

Re: Semiannual Monitoring Report for Plant No. A0733

The City of Sunnyvale Water Pollution Control Plant (No. A0733) is submitting this semiannual report to meet Standard Condition F and provide a report for Permit Condition 10844 #4 and #6 and Permit Condition 19978 #2 as required by our Major Facility Review Permit.

The monitoring required by this permit and the monitoring results are summarized in the table below:

Condition 10844 (4, 6):

Major Facility Review Permit Monitoring Summary for the Period of 1/1/2012 through 6/30/2012				
Source	Date of Test	Requirement	Result	Compliant (Y/N)
S-14 Engine Generator (Engine Generator #1)	March 1, 2012 (BAAQMD Report #12124)	Source Test for Compliance	Met Emission Limits in Permit Condition #10844 and Regulation 9, Rule 8; Regulations: 8-2-301 8-34-301.4 9-8-302.1 9-8-302.3	Y
S-15 Engine Generator (Engine Generator #2)	February 28, 2012 (BAAQMD Report #12123)	Source Test for Compliance	Met Emission Limits in Permit Condition #10844 and Regulation 9, Rule 8; Regulations: 8-2-301 8-34-301.4 9-8-302.1 9-8-302.3	Y

During this reporting period engines S-14 and S-15 complied with the emissions limits of Condition #10844 and Regulation 9, Rule 8 and Regulations 8-2-301, 8-34-301.4, 9-8-302.1, and 9-8-302.3 as required in the Major Facility Review Permit. A copy of the Annual Source Tests Results was provided to Sr. Air Quality Engineer then assigned to our facility (Ms. Carol Lee) on March 28, 2012.

ADDRESS ALL MAIL TO: P.O. BOX 3707 SUNNYVALE, CALIFORNIA 94088-3707
TDD (408) 730-7501

Condition 19978 (2):


Information to show compliance with Permit Condition 19978 (2) for the first and second quarterly testing of total reduced sulfur compounds in digester gas used in Sources 16, 17, & 18 are provided in the table below:

Total Reduced Sulfur Compounds – Draeger Tube Test results				
Sources: S-16, 17 & 18	Date of Test	Requirement	Result ppmv (dry)	Compliant (Y/N)
First Quarter Sampling:				
Digester Gas	1/11/12	19978 (2)	850	Y
Second Quarter Sampling:				
Digester Gas	4/4/12	19978 (2)	1040	Y

I am the responsible person for the City of Sunnyvale Water Pollution Control Plant, and I certify that this report is true, accurate, and complete.

Please contact Melody Tovar at (408) 730-7808 if you have any questions or comments on this report.

Sincerely,



John Stufflebean
Director, Environmental Services Department

cc: Melody Tovar, Regulatory Programs Division Manager
Carol Lee, Senior Air Quality Inspector, BAAQMD
Director of the Air Division, US EPA, Region IX, Attn: Air-3