



REGISTERED MAIL

Certified Mail, Return Receipt Requested

2013 JUL 31 AM 10:27

BAY AREA AIR QUALITY
MANAGEMENT DISTRICT

July 30, 2013

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

Attn: Title V Reports

Re: Semiannual Monitoring Report for Plant No. A0733

The City of Sunnyvale Water Pollution Control Plant (No. A0733) is submitting this semiannual report to meet Standard Condition F and provide a report for Permit Condition 10844 #4 and #6 and Permit Condition 19978 #2 as required by our Major Facility Review Permit.

The monitoring required by this permit and the monitoring results are summarized in the table below:

Condition 10844 (4, 6):

Major Facility Review Permit Monitoring Summary for the Period of 1/1/2013 through 6/30/2013				
Source	Date of Test	Requirement	Result	Compliant (Y/N)
S-14 Engine Generator (Engine Generator #1)	February 20, 2013 (Blue Sky Environmental, Inc report dated March 8, 2013)	Source Test for Compliance	Met Emission Limits in Permit Condition #10844 and Regulation 9, Rule 8; Regulations: 8-2-301 8-34-301.4 9-8-302.1 9-8-302.3	Y
S-15 Engine Generator (Engine Generator #2)	February 20, 2013 (Blue Sky Environmental, Inc report dated March 8, 2013)	Source Test for Compliance	Met Emission Limits in Permit Condition #10844 and Regulation 9, Rule 8; Regulations: 8-2-301 8-34-301.4 9-8-302.1 9-8-302.3	Y

During this reporting period engines S-14 and S-15 complied with the emissions limits of Condition #10844 and Regulation 9, Rule 8 and Regulations 8-2-301, 8-34-301.4, 9-8-302.1, and 9-8-302.3 as required in the Major Facility Review Permit. A copy of the Annual Source Tests Results was provided to the Compliance & Enforcement Division on April 4, 2013.

**ADDRESS ALL MAIL TO: P.O. BOX 3707 SUNNYVALE, CALIFORNIA 94088-3707
TDD (408) 730-7501**