

**Monitoring Report
 Crockett Cogeneration #A8664
 Table 1**

S-201 – Gas Turbine

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-9-301.3	Y	9 ppmv @ 15% O ₂ , dry	BAAQMD 9-9-501	C	CEM	Continuous
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y	155.2 ppmv, @ 15% O ₂ , dry	NSPS, 40 CFR 60.334 (c)	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9a	Y	39.2 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9b	Y	5 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 21a	Y	160.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9c	Y	46.6 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9d	Y	10 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD condition #14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
SO2	BAAQMD 9-1-301	Y	GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		Continuous
SO2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO2	NSPS 40 CFR 60.333(a)	Y	0.015% (vol) @15% O ₂ (dry)	Exempt from monitoring requirement per NSPS 40 CFR 60.334(h)(3) for PUC quality natural gas.	N		Continuous
SO2	BAAQMD condition #14970, part 20e	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
SO2	BAAQMD condition #14970, part 21e	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for no more than 3 min/hr		N		Continuous
Filterable Particulate	BAAQMD 6-1-310	Y	0.15 grain/dscf @ 6% O ₂		N		Continuous
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
PM10	BAAQMD condition #14970, part 21d	Y	58.19 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
POC	BAAQMD condition #14970, part 21c	Y	48.45 ton/yr (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
NH3	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 25	P/E	Calculations or source test	Continuous
NH3	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Heat input limit	BAAQMD condition #14970, part 2	Y	1,780 mmbtu/hr, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 4	Y	2,129 mmbtu/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 5	Y	51,029 mmbtu/day for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 6	Y	15,613,000 mmbtu/yr for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 18	Y	57,544 mmbtu/day, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Heat input limit	BAAQMD condition #14970, part 19	Y	19,023,000 mmbtu/yr, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD condition #14970, part 9e	Y	550 degrees Fahrenheit	BAAQMD condition #14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration

S-202 – HEAT RECOVERY STEAM GENERATOR (HRSG)

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-3-303	N	125 ppm	BAAQMD 1-520.1	C	CEM	Continuous
NOx	NSPS 40 CFR 60.44Da (a)(1)	Y	0.2 lb/mmBtu except during startup, shutdown, or malfunction	Exempt from CEMS per NSPS 40 CFR 60.49Da(o)	N		Continuous
NOx	BAAQMD condition #14970, part 9a	Y	39.2 lb/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9b	Y	5.0 ppmv @ 15% O ₂ , for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 21a	Y	160.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9c		46.6 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9d		10 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD condition #14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
SO2	BAAQMD 9-1-301	Y	GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		Continuous
SO2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO2	NSPS 40 CFR 60.43Da (b)(2)		0.2 lb/mmbtu, 24 hr average except during startup, shutdown		N		Continuous
SO2	BAAQMD condition #14970, part 20e	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
SO2	BAAQMD condition #14970, part 21e	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for <3 min/hr		N		Continuous
Opacity	BAAQMD 6-1-304	Y	During tube cleaning, Ringelmann No. 2 for 3 min/hr and 6 min/billion btu/24 hours		N		Continuous
Opacity	NSPS 40 CFR 60.42a(b)	Y	< 20% opacity, 6 minute average, except one six minute period/hr up to 27% opacity		N		Continuous
Filterable Particulate	BAAQMD 6-310	Y	0.15 grain/dscf @ 6% O2		N		Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Filterable Particulate	NSPS 40 CFR 60.42a(a) (1)	Y	0.03 lb TSP/mmbtu except during startup, shutdown, or malfunction		N		Continuous
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
PM10	BAAQMD condition #14970, part 21d	Y	58.19 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
POC	BAAQMD condition #14970, part 21c	Y	48.45 ton/yr (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
NH3	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 25	P/E	Calculations or source test	Continuous
NH3	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Heat input limit	BAAQMD condition #14970, part 3	Y	288.9 mmbtu/hr, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 4	Y	2,129 mmbtu/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 5	Y	51,029 mmbtu/day for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Heat input limit	BAAQMD condition #14970, part 6	Y	15,613,000 mmbtu/yr for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 18	Y	57,544 mmbtu/day, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 19	Y	19,023,000 mmbtu/yr, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD condition #14970, part 9e	Y	550 degrees Fahrenheit	BAAQMD condition #14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration

S-203, S-204, and S-205 – Auxiliary Boilers

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-3-303	N	125 ppm	BAAQMD 1-520.1	C	CEM	Continuous
NOx	BAAQMD 9-7-301.1	Y	30 ppmv @3%O2, dry	BAAQMD 1-520.1	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 17a	Y	3.7 lb/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 17b	Y	8.2 ppmv @ 3% O2, dry, 3-hr average	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 21a	Y	160.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	NSPS 40 CFR 60.44b (a)(1)(i)	Y	0.1 lb/mmbtu	Monitoring requirement subsumed by monitoring for BACT limit. See Permit Shield.	N		Continuous
CO	BAAQMD 9-7-301.4	Y	400 ppmv @ 3% O2, dry	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 17c	Y	3.0 lb/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	CEM	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD cond# 14970, part 17d	Y	11.0 ppmv @ 3% O ₂ , dry, 3-hr average	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
SO ₂	BAAQMD 9-1-301	Y	GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		Continuous
SO ₂	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO ₂	BAAQMD cond# 14970, part 20e	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous
SO ₂	BAAQMD cond# 14970, part 21e	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for no more than 3 min/hr		N		Continuous
Opacity	BAAQMD 6-304	Y	During tube cleaning, Ringelmann No. 2 for 3 min/hr and 6 min/billion btu/24 hours		N		Continuous
Filterable Particulate	BAAQMD 6-1-310	Y	0.15 grain/dscf @ 6% O ₂		N		Continuous
PM ₁₀	BAAQMD cond# 14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
PM10	BAAQMD cond# 14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
PM10	BAAQMD cond# 14970, part 21d	Y	58.19 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD cond# 14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD cond# 14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
POC	BAAQMD cond# 14970, part 21c	Y	48.45 ton/yr (as CH4) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
NH3	BAAQMD cond# 14970, part 17f	N	20 ppmv, @ 3% O2, dry, averaged over 3 hrs	BAAQMD cond# 14970, part 25	P/E	Calculations or source test	Continuous
NH3	BAAQMD cond# 14970, part 17f	N	20 ppmv, @ 3% O2, dry, averaged over 3 hrs	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
Formaldehyde	BAAQMD cond# 14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD cond# 14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Specified PAH's	BAAQMD cond# 14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 11	Y	376 mmbtu/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 12	Y	18,048 mmbtu/day, for all 3 boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 13	Y	6,575,000 mmbtu/yr, for all 3 boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 18	Y	57,544 mmbtu/day, for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 19	Y	19,023,000 mmbtu/yr, for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD cond# 14970, part 17e	Y	430 degrees Fahrenheit	BAAQMD cond# 14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration