

CROCKETT COGENERATION, A California Limited Partnership

550 Loring Avenue
Crockett, California 94525
(510) 787-4100

RECEIVED

09 SEP 11 PM 2 09

BAY AREA AIR QUALITY
MANAGEMENT DISTRICT

September 7, 2012

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis St.
San Francisco, CA 94109
Attn: Title V Reports

Dear Sir,

Attached is the Title V Monitoring Report from Crockett Cogeneration, for the period from March 1, 2012 to August 31, 2012. During this period we have maintained continuous compliance with all monitoring requirements under the Title V monitoring program with the exception of one deviation that was reported to the BAAQMD on July 23, 2012 and is listed below.


Date & Times	Incident Number	Inoperative Monitor	Breakdown/ Exceedance	Source Affected
7/22/12	ID# 06G07	Gas Turbine CO Analyzer Failure	N/A	S-201 & S-202

In Table 1, we have provided a complete listing of all monitoring requirements as specified in our Title V Major Facility Operating Permit. The monitoring frequency indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, either annual (A), quarterly (Q), monthly (M), daily (D), or on an event basis (E). The letter (N) represents if no monitoring is required. The compliance status for each of these is indicated as either continuous or intermittent.

I certify that based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. If you have any questions, please contact Chris Sargent at (510) 787-4101.

Prepared for:

CROCKETT COGENERATION,
A California Limited Partnership



By: Dan Consie
Asset Manager

**Monitoring Report
Crockett Cogeneration #A8664
Table 1**

S-201 – Gas Turbine

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-9-301.3	Y	9 ppmv @ 15% O ₂ , dry	BAAQMD 9-9-501	C	CEM	Continuous
NOx	NSPS, 40 CFR 60.332 (d)(1)	Y	155.2 ppmv, @ 15% O ₂ , dry	NSPS, 40 CFR 60.334 (c)	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9a	Y	39.2 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9b	Y	5 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 21a	Y	169.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9c	Y	46.6 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Intermittent
CO	BAAQMD condition #14970, part 9d	Y	10 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Intermittent

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD condition #14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Intermittent
CO	BAAQMD condition #14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Intermittent
SO2	BAAQMD 9-1-301	Y	GLC ¹ of 0.5 ppm for 5 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		Continuous
SO2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO2	NSPS 40 CFR 60.333(a)	Y	0.015% (vol) @15% O ₂ (dry)	Exempt from monitoring requirement per NSPS 40 CFR 60.334(h)(3) for PUC quality natural gas.	N		Continuous
SO2	BAAQMD condition #14970, part 20c	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
SO2	BAAQMD condition #14970, part 21c	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for no more than 3 min/hr		N		Continuous
Filtrable Particulate	BAAQMD 6-1-310	Y	0.15 grain/dscf @ 6% O ₂		N		Continuous
PM10	BAAQMD condition #14970, part 20d	Y	139.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
PM10	BAAQMD condition #14970, part 21d	Y	58.19 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH ₄) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CO ₂) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
POC	BAAQMD condition #14970, part 21c	Y	48.45 ton/yr (as CH ₄) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
NEH	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O ₂ , dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 25	P/C	Calculations or source test	Continuous
NEH	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O ₂ , dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous

Type of Limit	Emission Limit Citation	BE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	Every 2 years	Source Test	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	Every 2 years	Source Test	Continuous
Heat input limit	BAAQMD condition #14970, part 2	Y	1,780 mmBtu/hr, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 4	Y	2,129 mmBtu/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 5	Y	51,029 mmBtu/day for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 6	Y	15,613,000 mmBtu/yr for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 18	Y	57,544 mmBtu/day, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Heat input limit	BAAQMD condition #14970, part 19	Y	19,023,000 mmBtu/yr. for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD condition #14970, part 9c	Y	550 degrees Fahrenheit	BAAQMD condition #14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration

S-202 – HEAT RECOVERY STEAM GENERATOR (HRSG)

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-3-303	N	125 ppco	BAAQMD 1-520.1	C	CEM	Continuous
NOx	NSPS 40 CFR 60.44Da (a)(1)	Y	0.2 lb/hr/btu except during startup, shutdown, or malfunction	Exempt from CEMS per NSPS 40 CFR 60.49Da(e)	N		Continuous
NOx	BAAQMD condition #14970, part 9a	Y	39.2 lb/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 9b	Y	5.0 ppmv @ 15% O ₂ , for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
NOx	BAAQMD condition #14970, part 21a	Y	160.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Continuous
CO	BAAQMD condition #14970, part 9c		46.6 lb/hr, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Intermittent
CO	BAAQMD condition #14970, part 9d		10 ppmv, @ 15% O ₂ , dry, for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	CEM	Intermittent
CO	BAAQMD condition #14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Intermittent

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (F/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD condition #14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	CEM	Intermittent
SO2	BAAQMD 9-1-301	Y	GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		Continuous
SO2	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO2	NSPS 40 CFR 60.430a (b)(2)		0.2 lb/minute, 24 hr average except during startup, shutdown		N		Continuous
SO2	BAAQMD condition #14970, part 20e	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
SO2	BAAQMD condition #14970, part 21c	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for <3 min/hr		N		Continuous
Opacity	BAAQMD 6-1-304	Y	During tube cleaning, Ringelmann No. 2 for 3 min/hr and 6 min/billion lbs/24 hours		N		Continuous
Opacity	NSPS 40 CFR 60.42a(b)	Y	< 20% opacity, 6 minute average, except one six minute period/hr up to 27% opacity		N		Continuous
Filterable Particulate	BAAQMD 6-310	Y	0.15 grain/dscf @ 6% O2		N		Continuous

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Filterable Particulate	NSPS 40 CFR 60.42a(a) (1)	Y	0.03 lb TSP/month except during startup, shutdown, or malfunction		N		Continuous
PM10	BAAQMD condition #14970, part 20c	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
PM10	BAAQMD condition #14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
PM10	BAAQMD condition #14970, part 21d	Y	58.19 tons/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH6) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD condition #14970, part 20c	Y	352.6 lb/day (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous
POC	BAAQMD condition #14970, part 21c	Y	48.45 mm/yr (as CH4) for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 24	P/A	Calculations	Continuous
NH3	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 25	P/E	Calculations or source test	Continuous
NOx	BAAQMD condition #14970, part 9f	N	20 ppmv, @ 15% O2, dry, averaged over 3 hrs for turbine and HRSG combined	BAAQMD condition #14970, part 27	P/A	Source test	Continuous

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Formaldehyde	BAAQMD condition #14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD condition #14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 26	P/A	Calculations	Continuous
Specified PAH's	BAAQMD condition #14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 29	P/every 2 years	Source Test	Continuous
Heat input limit	BAAQMD condition #14970, part 3	Y	288.9 mmBtu/hr, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 4	Y	2,129 mmBtu/hr for turbine and HRSG combined, 3-hr average	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 5	Y	51,029 mmBtu/day for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous

Type of limit	Emission Limit Citation	EE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (PIC/N)	Monitoring Type	Compliance Status
Heat input limit	BAAQMD condition #14970, part 6	Y	15,613,000 mmBtu/yr for turbine and HRSG combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 18	Y	57,541 mmBtu/day, for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD condition #14970, part 19	Y	19,023,000 mmBtu/yr. for turbine, HRSG, and boilers combined	BAAQMD condition #14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD condition #14970, part 9e	Y	550 degrees Fahrenheit	BAAQMD condition #14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration

S-203, S-204, and S-205 – Auxiliary Boilers

Type of limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
NOx	BAAQMD 9-3-303	N	1.25 ppm	BAAQMD 1-520.1	C	CEM	Continuous
NOx	BAAQMD 9-7-301.1	Y	30 ppmv @ 3% O ₂ , dry	BAAQMD 1-520.1	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 17a	Y	3.7 lb/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 17b	Y	8.2 ppmv @ 3% O ₂ , dry, 3-hr average	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 20a	Y	969.7 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	BAAQMD cond# 14970, part 21a	Y	160.85 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
NOx	NESHAP C1-R 60.44b (u)(1)(i)	Y	0.1 lb/mmbtu	Monitoring requirement subsumed by monitoring for BACT limit. See Permit Shield.	N		Continuous
CO	BAAQMD 9-7-301.1	Y	400 ppmv @ 3% O ₂ , dry	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 17c	Y	1.0 lb/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	CEM	Continuous

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
CO	BAAQMD cond# 14970, part 17d	Y	11.0 ppmv @ 3% O ₂ , dry, 3-hr average	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 20b	Y	745.0 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
CO	BAAQMD cond# 14970, part 21b	Y	73.27 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	CEM	Continuous
SO ₂	BAAQMD 9-1-301	Y	GL of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.65 ppm for 24 hours		N		Continuous
SO ₂	BAAQMD 9-1-302	Y	300 ppm (dry)		N		Continuous
SO ₂	BAAQMD cond# 14970, part 20c	Y	48.5 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous
SO ₂	BAAQMD cond# 14970, part 21c	Y	8.01 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
Opacity	BAAQMD 6-1-301	N	Ringelmann No. 1 for no more than 3 min/yr		N		Continuous
Opacity	BAAQMD 6-304	Y	During tube clearing, Ringelmann No. 2 for 3 min/yr and 6 min/billion btu/24 hours		N		Continuous
Filterable Particulate	BAAQMD 6-1-310	Y	0.15 grain/dscf @ 6% O ₂		N		Continuous
PM ₁₀	BAAQMD cond# 14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous

Type of Limit	Emission Limit Citation	FE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
PM10	BAAQMD cond# 14970, part 20d	Y	329.1 lb/day for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
PM10	BAAQMD cond# 14970, part 21d	Y	58.19 ton/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
POC	BAAQMD cond# 14970, part 20c	Y	352.6 lb/day (as CH ₄) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/D	Calculations	Continuous
POC	BAAQMD cond# 14970, part 20c	Y	352.6 lb/day (as CH ₄) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
POC	BAAQMD cond# 14970, part 21c	Y	48.45 ton/yr (as CO ₂) for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 24	P/A	Calculations	Continuous
NH ₃	BAAQMD cond# 14970, part 17f	N	20 ppmv, @ 3% O ₂ , dry, averaged over 3 hrs	BAAQMD cond# 14970, part 25	P/E	Calculations or source test	Continuous
NH ₃	BAAQMD cond# 14970, part 17f	N	20 ppmv, @ 3% O ₂ , dry, averaged over 3 hrs	BAAQMD cond# 14970, part 28	P/1-2 times per 5 years	Source Test	Continuous
Formaldehyde	BAAQMD cond# 14970, part 22a	N	4318.6 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous
Benzene	BAAQMD cond# 14970, part 22b	N	116.1 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous

Type of Limit	Emission Limit Citation	EE Y/N	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status
Specified PAH's	BAAQMD cond# 14970, part 22c	N	78.7 lb/yr for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 26	P/A	Calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 11	Y	376 mmBtu/hr, 3-hr average for each boiler	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 12	Y	18,048 mmBtu/day, for all 3 boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 13	Y	6,573,000 mmBtu/yr, for all 3 boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 18	Y	57,544 mmBtu/day, for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Heat input limit	BAAQMD cond# 14970, part 19	Y	19,023,000 mmBtu/yr, for turbine, HRSG, and boilers combined	BAAQMD cond# 14970, part 23	C	Fuel meter, calculations	Continuous
Firing hours and fuel flow rates	N/A	Y	N/A	BAAQMD condition #14970, part 23a	C	Fuel meter, calculations	Continuous
Oxygen	N/A	Y	N/A	BAAQMD condition #14970, part 23b	C	CEMS	Continuous
Oxidizing catalyst temp	BAAQMD cond# 14970, part 17c	Y	430 degrees Fahrenheit	BAAQMD cond# 14970, part 23	C	Temperature monitor	Continuous

¹ Ground Level Concentration