

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S-1, TURBINE #1
NOVEMBER 1, 2011 THROUGH APRIL 30, 2012

NOx	Limit	Applicable	Unit	Condition	Monitoring	Compliance	Reporting	Other
NOx	BAAQMD 9-9-301.1.3	N	9 ppmv @ 15% O2, dry	BAAQMD 9-9-501 and BAAQMD condition #20136, part 23c	C	CEM	X	
NOx	BAAQMD 9-9-301.1.3	N	9 ppmv @ 15% O2, dry	BAAQMD condition #20136, part 24a	P/A	Source Test	X	
NOx	BAAQMD 9-9-301.1.2	N	43 lbs/MWhr or 9 ppmv @ 15% O2, dry	BAAQMD 9-9-501 and BAAQMD condition #19684, part 23c	C	CEM	X	
NOx	SIP Regulation 9-9-301.3	Y	9 ppmv @ 15% O2, dry	SIP Regulation 9-9-501 and BAAQMD condition #19684, part 23c	C	CEM	X	
NOx	SIP Regulation 9-9-301.3	Y	9 ppmv @ 15% O2, dry	BAAQMD condition #19684, part 24a	P/A	Source Test	X	
NOx	NSPS, Subpart GG 40 CFR 60.332(a)(1)	Y	75 ppmv @ 15% O2, dry	NSPS 40CFR 60.334(c)	C	CEM	X	
NOx	None	Y	None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #20136, part 18.1	Y	2.5 ppm @ 15% O2, dry 3-hr rolling average except during turbine startup or shutdown	BAAQMD condition #20136, part 18.1	C	CEM	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Pollutant	Standard	Y/N	Unit	Limit	Condition	Method	Frequency	Compliance	Monitoring
NOx	BAAQMD condition #20136, part 18.1	Y		2.5 ppm @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20136, part 24a	P/A	Source Test	X	
NOx	BAAQMD condition #20136, part 21	Y		121 lb/day (as NO ₂)	BAAQMD condition #20136, part 23c	C	CEM	X	
NOx	BAAQMD condition #20136, part 21	Y		16.4 tons per year (as NO ₂)	BAAQMD condition #20136, part 23c	C	CEM	X	
CO	BAAQMD condition #20136, part 18.3	Y		6 ppmv. @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20136, parts 18.3 and 23c	C	CEM	X	
CO	BAAQMD condition #20136, part 18.3	Y		6 ppmv. @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20136, part 24c	P/A	Source Test	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Parameter	Standard	Y/N	Effective Date	Limit	Monitoring Requirement	Monitoring	Monitoring Method	Monitoring Frequency	Monitoring Location
CO	BAAQMD condition #20136, part 21	Y		163 lb/day	BAAQMD condition #20136, part 23c	C	CEM	X	
CO	BAAQMD condition #20136, part 21	Y		29.1 tons per year	BAAQMD condition #20136, part 23c	C	CEM	X	
CO2		Y		None	40 CFR 75.10	C	CEM (CO2) or CEM (O2) or fuel flow monitor	X	
SO2	BAAQMD 9-1-301	Y		61.0 ³ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO2	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20136, part 23f	N		X	
SO2	NSPS 40 CFR Subpart GG 60.333(a)	Y		0.013% (vol) @ 15% O ₂ (dry)	NSPS 40 CFR 60.334(h)(3)	NN	None	X	
SO2	None	Y		None	40 CFR 75.11(d)(2), 40 CFR 75, Appendix D, part 2.3		Fuel measurements, calculations	X	
SO2	BAAQMD condition #20136, part 18.6	Y		1.39 lb/hr excluding startup and shutdown of turbines	BAAQMD condition #20136, part 23e	PAQ	Total sulfur content analysis	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Pollutant	Applicable Limit	Mandatory	Future Effective Date	Limit	Monitoring Method	Monitoring Parameters	Compliance		
							Visual	Instrumental	
SO2	BAAQMD condition #20136, part 18.6	Y		1.39 lb/hr excluding startup and shutdown of the turbines	BAAQMD condition #20136, part 24f	P/A	Source test	X	
SO2	BAAQMD condition #20136, part 21	Y		3.3 lb/day	BAAQMD condition #20136, part 23e	P/Q	Total sulfur content analysis	X	
SO2	BAAQMD condition #20136, part 21	Y		6.0 tons/year	BAAQMD condition #20136, part 23e	P/Q	Total sulfur content analysis	X	
Opacity	BAAQMD 6-1-301	N		> Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP 6-301	Y		> Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
Opacity	BAAQMD condition #20136, part 17	Y		> Ringelmann No.1 for no more than 3 minutes in any hour or equivalent 20% opacity		N		X	
Filterable Particulate	BAAQMD 6-1-310	Y		0.15 grains/dscf		N		X	
Filterable Particulate	SIP 6-310	Y		0.15 grains/dscf		N		X	

VII. Applicable Limits and Compliance Monitoring Requirements

Parameter	Condition	Y/N	Unit	Limit	Condition	Frequency	Monitoring	Compliance	Notes
PM10	BAAQMD condition #20136, part 18.5	Y		3 lb/hr for S-1	BAAQMD condition #20136, part 24c	P/A	Source Test	X	
PM10	BAAQMD condition #20136, part 21	Y		72 lb/day	BAAQMD condition #20136, parts 24c	P/A	Source Test	X	
PM10	BAAQMD condition #20136, part 21	Y		13.3 tons/year	BAAQMD condition #20136, part 24c	P/A	Source Test	X	
POC	BAAQMD condition #20136, part 18.4	Y		2 ppmv @ 15% O ₂ , dry, except during turbine startup or shutdown	BAAQMD condition #20136, part 24d	P/A	Source Test	X	
POC	BAAQMD condition #20136, part 21	Y		30.0 lb/calendar day	BAAQMD condition #20136, part 24d	P/A	Source Test	X	
POC	BAAQMD condition #20136, part 21	Y		4.9 ton/year	BAAQMD condition #20136, part 24d	P/A	Source Test	X	
NH3	BAAQMD condition #20136, part 18.2	N		10 ppmv @ 15% O ₂ , dry, except during turbine startup or shutdown	BAAQMD condition #20136 parts 18.2 and 23b	C	District approved correct ammonia slip calculation and correction factor determined by source test	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Parameter	Creation of Limit	Effective	Limit	Monitoring Requirement	Units	Monitoring		
NH3	BAAQMD condition #20136, part 18.2	N	10ppmv @15% O2, dry, except during turbine startup or shutdown	BAAQMD condition #20136, part 24b	P/A	Source test	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	500 MMBTU/hr (HHV), 3-hr average	BAAQMD condition #20136, part 23d	C	Fuel meter,	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	500 MMBTU/hr (LHV), 3-hr average	BAAQMD condition #20136, part 23d	P/M	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	500 MMBTU/hr (LHV), 3-hr average	BAAQMD condition #20136, part 24g	P/A	Source test	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	12,000 MMBTU/day (HHV)	BAAQMD condition #20136, part 23d	C	Fuel meter, calculations	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	12,000 MMBTU/day (HHV)	BAAQMD condition #20136, part 31g	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	4,380,000 MMBTU/yr (LHV)	BAAQMD condition #20136, part 23d	C	Fuel meter, calculations	X	
Heat input limit	BAAQMD condition #20136, part 22	Y	4,380,000 MMBTU/yr (LHV)	BAAQMD condition #20136, part 31g	P/Q	Fuel composition analysis	X	
MW	N/A		Note	BAAQMD condition #20136, part 24h	P/A	Source test	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Standard	RE	Future Dates	Compliance Limit	Monitoring Method/Device	Monitoring Frequency	Monitoring	Compliance	
								Yes	No
Exhaust Gas temperature	N/A			None	BAAQMD condition #20136, part 24j	P/A	Source test	X	
Stack gas flow	N/A			None	BAAQMD condition #20136, part 24i	P/A	Source test	X	
NH3 injection rate	N/A			None	BAAQMD condition #20136, part 24k	P/A	Source test District approved correct ammonia slip calculation and correction factor determined by source test	X	
Start-up Period	BAAQMD condition #20136 part 19			60 minutes per start-up	BAAQMD condition #20057, part 32(b)	P/E	Records	X	
Shut-down period	BAAQMD condition #20136, part 20			30 minutes per shutdown	BAAQMD condition #20057, part 31(b)	P/E	Records	X	
Fuel Sulfur Content	40 CFR 60.333(b)	Y		0.8 percent by weight (8000ppmw) sulfur	40 CFR 60.334(h)(1)	P	Fuel Sulfur Content Testing	X	

VII. Applicable Limits and Compliance Monitoring Requirements

**Table VII - B
 Applicable Limits and Compliance Monitoring Requirements
 S2 - DIESEL FIREWATER PUMP**

Pollutant	Regulation	Enforceable	Emission Factor	Limit	Monitoring	Measurement	Compliance	Notes
					Method	Frequency		
SO2	BAAQMD 9-1-301 BAAQMD	N		Gf.C. of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		P/E	Fuel certification by vendor	X
	BAAQMD 9-1-301	Y		Sulfur content of fuel <0.5% by weight		P/E	Fuel certification by vendor	X
Opacity	BAAQMD Regulation 6-1-302	N		<Ringelman No 2 more than 3 min/hr		N		X
Opacity	SIP Regulation 6-1-302	Y		<Ringelman No 2 for more than 3 min/hr		N		X
FP	BAAQMD Regulation 6-1-310	N		0.15 grain/dscf		N		X
FP	SIP Regulation 6-310	Y		0.15 grain/dscf		N		X

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2 - DIESEL FIREWATER PUMP

Type of Permit	Emission of Pollutants	Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Hours of operation	BAAQMD 9-8-330.1 BAAQMD Condition #22850 Part 1	Y		Emergency use for an unlimited number of hours	BAAQMD 9-8-530 BAAQMD Condition #22850 Part 3	C P/E	Hour meter, recordkeeping	X	
Hours of operation	BAAQMD 9-8-330.2 BAAQMD Condition #22850 Part 1	Y		Reliability-related activities not to exceed 100 hours in any consecutive 12-month period	BAAQMD Regulation 9-8-530 BAAQMD Condition #22850 Part 3	C P/E	Hour meter, recordkeeping	X	

VIII. Applicable Limits and Compliance Monitoring Requirements

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3 - COOLING TOWER

Parameter	Standard	Enforce	Effective Date	Limit	Monitoring Location	Frequency	Monitoring	Compliance	
								Met	Not Met
Opacity	BAAQMD Regulation 6-1-301	N		<Ringelmann No 1 for more than 3 min/yr	N	N		X	
Opacity	SIP Regulation 6-301	Y		<Ringelmann No 1 for more than 3 min/yr	N	N		X	
Particulate Weight	BAAQMD Regulation 6-1-310	N		0.15 grains per dsol	N	N		X	
Particulate Weight	SIP Regulation 6-301	Y		0.15 grains per dsol	Y	N		X	
Particulate Weight	BAAQMD Regulation 6-1-311	Y		40 lb/yr	N	N		X	
Particulate Weight	SIP Regulation 6-311	Y		40 lb/yr	N	N		X	