

Gilroy Energy Center, LLC for Riverview Energy Center

795 Minaker Drive
Antioch, CA 94509

VIA EMAIL and FEDEX

Friday, January 26, 2024

Director of Compliance and Enforcement
Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105
Attn: Title V

TV Tracking #: 873

1. RECEIVED IN 01/31/2024
ENFORCEMENT: _____

Re: Gilroy Energy Center, LLC for Riverview Energy Center
Semi-Annual Title V Monitoring and Excess Emissions Report
Facility #B4512
Reporting Period: July 1, 2023 through December 31, 2023.

Dear Ben,

Enclosed is the Title V CEMS Semi-Annual Monitoring Report for the Gilroy Energy Center, LLC for Riverview Energy Center (REC) for the reporting period of July 1, 2023 through December 31, 2023.

REC is currently in compliance with the District CEMS regulations. REC maintained compliance with the monitoring requirements listed in the Title V permit for REC during this reporting period.

By signing this report I am certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the attached report are true, accurate, and complete.

If you have any questions or require additional information, please contact me at (707) 399-4393 or Ehab Aqleem, EHS Specialist, at (707) 399-4395.

Sincerely,

DocuSigned by:

Andrew Gundershaug

5E549D8EAC8C4C3...

Andrew Gundershaug
Plant Manager and Responsible Official

cc:	Sadegh Sadeghipour	Permit Engineer	BAAQMD
	Jamie Wright	O&M Manager	Calpine Corporation
	EHS Walnut Creek	EHS Department	Calpine Corporation

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-1 – COMBUSTION GAS TURBINE
July 1, 2023 through December 31, 2023

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O2, dry	BAAQMD 9-9-501 and BAAQMD condition #20010, part 23c	C	CEM	X	
NOx	SIP 9-9-301.3	Y		9 ppmv @ 15% O2, dry	SIP 9-9-501 and BAAQMD condition #20010, part 23c	C	CEM	X	
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O2, dry	BAAQMD condition #20010, part 4a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	SIP Regulation 9-9-301.3	Y		9 ppmv @ 15% O2, dry	SIP Regulation condition #20010, part 24a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y		75 ppmv @ 15% O2, dry	NSPS 40 CFR 60.334(b)	C	CEM	X	
NOx	None	Y		None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #20010, part 18(a)	Y		2.5 ppmv @ 15% O2, dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 18(a), 23c	C	CEM	X	
NOx	BAAQMD condition #20010, part 18(a)	Y		2.5 ppmv @ 15% O2, dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	BAAQMD condition #20010, part 21	Y		121 lb/ day (as NO2)	BAAQMD condition #20010, part 23c	C	CEM	X	
NOx	BAAQMD condition #20010, part 21	Y		14.7 tons per year (as NO2)	BAAQMD condition #20010, part 23c	C	CEM	X	

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
CO	BAAQMD condition #20010, part 18(c)	Y		6 ppmv @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, parts 18(c) and 23c	C	CEM	X	
CO	BAAQMD condition #20010, part 18(c)	Y		6 ppmv @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24c	P/ Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
CO	BAAQMD condition #20010, part 21	Y		163 lb/ day	BAAQMD condition #20010, part 23c	C	CEM	X	
CO	BAAQMD condition #20010, part 21	Y		21.5 tons per year	BAAQMD condition #20010, part 23c	C	CEM	X	
CO ₂		Y		None	40 CFR 75.10	C	CEM (CO ₂) or CEM (O ₂) or fuel flow monitor	X	
SO ₂	BAAQMD 9-1-301	Y		GLC ₁ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO ₂	SIP 9-1-301	Y		GLC ₁ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO ₂	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20010, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	
SO ₂	SIP 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20010, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	
SO ₂	NSPS 40 CFR 60.333(a)	Y		0.015% (vol.) @15% O ₂ (dry)	NSPS 40 CFR 60.334(h)(3), 40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3, and BAAQMD Condition 20010, Part 23e	P/Q	Fuel Gas Total sulfur content analysis, Fuel measurements, calculations	X	
SO ₂	None	Y		None	40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3		Fuel measurements, calculations	X	

Facility Name: Riverview Energy Center
 Permit for Facility #: B4512

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO2	BAAQMD condition #20010, part 18(f)	Y		1.38 lb/hr	BAAQMD condition #20010, part 23e	P/Q	Fuel gas Total sulfur content analysis	X	
SO2	BAAQMD condition #20010, part 18(f)	Y		1.38 lb/hr	BAAQMD condition #20010, part 24f	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
SO2	BAAQMD condition #20010, part 21	Y		32 lb/ day	BAAQMD	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
					condition			X	
					#20010, part 24f			X	
SO2	BAAQMD condition #20010, part 21	Y		4.5 tons/year	BAAQMD	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
					condition			X	
					#20010, part 24f			X	
Opacity	BAAQMD 6-1-301	N		≥ Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP Regulation 6-301	Y		> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	BAAQMD condition #20010, part 18	Y		≥ Ringelmann No. 1 for no more than 3 minutes in any hour or equivalent 20% opacity		N		X	
FP	BAAQMD 6-1-310	N		0.15 grain/dscf		N		X	
FP	SIP Regulation 6-310	Y		0.15 grain/dscf		N		X	
PM10	BAAQMD condition #20010, part 18(e)	Y		3 lb/ hr	BAAQMD condition #20010, part 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
PM10	BAAQMD condition #20010, part 21	Y		72 lb/day	BAAQMD condition #20010, parts 23d, 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source Test	X	
PM10	BAAQMD condition #20010, part 21	Y		9.8 tons/year	BAAQMD condition #20010, part 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source Test	X	
POC	BAAQMD condition #20010, part 18(d)	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 18(d)	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 21	Y		31 lb/calendar day	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 21	Y		4.1 ton/year	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NH3	BAAQMD condition #20010, Part 18(b)	N		10 ppmv @ 15% O ₂ , dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #20010, parts 18.2 and 23b	C	District approved correct ammonia slip calculation and correction factor determined by source test	X	

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NH3	BAAQMD condition #20010, Part 18(b)	N		10 ppmv @ 15% O2, dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #20010, part 24b	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 23d	C	Fuel meter, firing monitor	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 23d	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 24g	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		12,000 MM BTU/day (HHV)	BAAQMD condition #20010, part 23d	C	fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		12,000 MM BTU/day (HHV)	BAAQMD condition #20010, part 23d	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		3,250,000 MM BTU/yr (HHV)	BAAQMD condition #20010, part 23d	C	fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		3,250,000 MM BTU/yr (HHV)	BAAQMD condition #20010, part 31g	P/Q	Fuel composition analysis	X	
MW				None	BAAQMD condition #20010, part 24h	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Exhaust Gas temperature				None	BAAQMD condition #20010, part 24j	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Stack gas flow rate				None	BAAQMD condition #20010, part 24i	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NH3 injection rate				None	BAAQMD condition #20010, part 24k	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Start-up Period	BAAQMD condition #20010, part 19			60 minutes per start-up	BAAQMD condition #20010, part 29(b)	P/E	Records	X	
Shutdown Period	BAAQMD condition #20010, part 20			30 minutes per shutdown	BAAQMD condition #20010, part 29(b)	P/E	Records	X	
Fuel Sulfur Content	40 CFR 60.333(b)	Y		0.8 percent by weight (8000 ppmw) sulfur	40 CFR 60.334(h)(1)	P	Fuel Sulfur Content Testing	X	

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S-2 – COOLING TOWER

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Opacity	BAAQMD Regulation 6-1-301	N		≥ Ringelmann 1 for no more than 3 min/hr		N		X	
Opacity	SIP Regulation 6-301	Y		> Ringelmann 1 for no more than 3 min/hr		N		X	
Particulate Weight	BAAQMD Regulation 6-1-310	N		0.15 grains per dscf		N		X	
Particulate Weight	SIP Regulation 6-310	Y		0.15 grains per dscf		N		X	
Particulate Weight	BAAQMD Regulation 6-1-311	Y		40 lb/hr	N	N		X	
Particulate Weight	SIP Regulation 6-311	Y		40 lb/hr	N	N		X	

Certificate Of Completion

Envelope Id: 07AAF79D3DF348A09069DD3D7C8D5D96	Status: Completed
Subject: DOCUSIGN REQUESTED: BAAQMD Semi-Annual Title V Monitoring Report for CD, LA, RP, WS- 2H 2024	
Source Envelope:	
Document Pages: 32	Signatures: 4
Certificate Pages: 4	Initials: 0
AutoNav: Enabled	Envelope Originator:
Envelope Stamping: Disabled	Ehab Aqleem
Time Zone: (UTC-06:00) Central Time (US & Canada)	717 Texas Ave.
	Houston, TX 77002
	Ehab.Aqleem@calpine.com
	IP Address: 12.248.171.66


Record Tracking

Status: Original	Holder: Ehab Aqleem	Location: DocuSign
1/29/2024 1:14:14 PM	Ehab.Aqleem@calpine.com	

Signer Events

Andrew Gundershaug
 andrew.gundershaug@calpine.com
 Security Level: Email, Account Authentication (None)

Signature

DocuSigned by:

 5E549D8EAC8C4C3...
 Signature Adoption: Pre-selected Style
 Using IP Address: 12.76.38.154

Timestamp

Sent: 1/29/2024 1:58:47 PM
 Resent: 1/29/2024 6:43:16 PM
 Viewed: 1/29/2024 6:51:55 PM
 Signed: 1/29/2024 6:52:07 PM

Electronic Record and Signature Disclosure:
 Accepted: 1/29/2024 6:51:55 PM
 ID: 1f10a592-3c9d-4e08-9961-d81c505bdb8f

In Person Signer Events	Signature	Timestamp
Editor Delivery Events	Status	Timestamp
Agent Delivery Events	Status	Timestamp
Intermediary Delivery Events	Status	Timestamp
Certified Delivery Events	Status	Timestamp
Carbon Copy Events	Status	Timestamp
Witness Events	Signature	Timestamp
Notary Events	Signature	Timestamp
Envelope Summary Events	Status	Timestamps
Envelope Sent	Hashed/Encrypted	1/29/2024 1:58:47 PM
Certified Delivered	Security Checked	1/29/2024 6:51:55 PM
Signing Complete	Security Checked	1/29/2024 6:52:07 PM
Completed	Security Checked	1/29/2024 6:52:07 PM

Payment Events	Status	Timestamps
----------------	--------	------------

Electronic Record and Signature Disclosure

ELECTRONIC RECORD AND SIGNATURE DISCLOSURE

From time to time, Calpine Corporation (we, us or Company) may be required by law to provide to you certain written notices or disclosures. Described below are the terms and conditions for providing to you such notices and disclosures electronically through the DocuSign system. Please read the information below carefully and thoroughly, and if you can access this information electronically to your satisfaction and agree to this Electronic Record and Signature Disclosure (ERSD), please confirm your agreement by selecting the check-box next to 'I agree to use electronic records and signatures' before clicking 'CONTINUE' within the DocuSign system.

Getting paper copies

At any time, you may request from us a paper copy of any record provided or made available electronically to you by us. You will have the ability to download and print documents we send to you through the DocuSign system during and immediately after the signing session and, if you elect to create a DocuSign account, you may access the documents for a limited period of time (usually 30 days) after such documents are first sent to you. After such time, if you wish for us to send you paper copies of any such documents from our office to you, you will be charged a \$0.00 per-page fee. You may request delivery of such paper copies from us by following the procedure described below.

Withdrawing your consent

If you decide to receive notices and disclosures from us electronically, you may at any time change your mind and tell us that thereafter you want to receive required notices and disclosures only in paper format. How you must inform us of your decision to receive future notices and disclosure in paper format and withdraw your consent to receive notices and disclosures electronically is described below.

Consequences of changing your mind

If you elect to receive required notices and disclosures only in paper format, it will slow the speed at which we can complete certain steps in transactions with you and delivering services to you because we will need first to send the required notices or disclosures to you in paper format, and then wait until we receive back from you your acknowledgment of your receipt of such paper notices or disclosures. Further, you will no longer be able to use the DocuSign system to receive required notices and consents electronically from us or to sign electronically documents from us.

All notices and disclosures will be sent to you electronically

Unless you tell us otherwise in accordance with the procedures described herein, we will provide electronically to you through the DocuSign system all required notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you during the course of our relationship with you. To reduce the chance of you inadvertently not receiving any notice or disclosure, we prefer to provide all of the required notices and disclosures to you by the same method and to the same address that you have given us. Thus, you can receive all the disclosures and notices electronically or in paper format through the paper mail delivery system. If you do not agree with this process, please let us know as described below. Please also see the paragraph immediately above that describes the consequences of your electing not to receive delivery of the notices and disclosures electronically from us.

How to contact Calpine Corporation:

You may contact us to let us know of your changes as to how we may contact you electronically, to request paper copies of certain information from us, and to withdraw your prior consent to receive notices and disclosures electronically as follows:

To contact us by email send messages to: gus.dahu@calpine.com

To advise Calpine Corporation of your new email address

To let us know of a change in your email address where we should send notices and disclosures electronically to you, you must send an email message to us at gus.dahu@calpine.com and in the body of such request you must state: your previous email address, your new email address. We do not require any other information from you to change your email address.

If you created a DocuSign account, you may update it with your new email address through your account preferences.

To request paper copies from Calpine Corporation

To request delivery from us of paper copies of the notices and disclosures previously provided by us to you electronically, you must send us an email to gus.dahu@calpine.com and in the body of such request you must state your email address, full name, mailing address, and telephone number. We will bill you for any fees at that time, if any.

To withdraw your consent with Calpine Corporation

To inform us that you no longer wish to receive future notices and disclosures in electronic format you may:

- i. decline to sign a document from within your signing session, and on the subsequent page, select the check-box indicating you wish to withdraw your consent, or you may;
- ii. send us an email to gus.dahu@calpine.com and in the body of such request you must state your email, full name, mailing address, and telephone number. We do not need any other information from you to withdraw consent.. The consequences of your withdrawing consent for online documents will be that transactions may take a longer time to process..

Required hardware and software

The minimum system requirements for using the DocuSign system may change over time. The current system requirements are found here: <https://support.docusign.com/guides/signer-guide-signing-system-requirements>.

Acknowledging your access and consent to receive and sign documents electronically

To confirm to us that you can access this information electronically, which will be similar to other electronic notices and disclosures that we will provide to you, please confirm that you have read this ERSD, and (i) that you are able to print on paper or electronically save this ERSD for your future reference and access; or (ii) that you are able to email this ERSD to an email address where you will be able to print on paper or save it for your future reference and access. Further, if you consent to receiving notices and disclosures exclusively in electronic format as described herein, then select the check-box next to ‘I agree to use electronic records and signatures’ before clicking ‘CONTINUE’ within the DocuSign system.

By selecting the check-box next to ‘I agree to use electronic records and signatures’, you confirm that:

- You can access and read this Electronic Record and Signature Disclosure; and
- You can print on paper this Electronic Record and Signature Disclosure, or save or send this Electronic Record and Disclosure to a location where you can print it, for future reference and access; and
- Until or unless you notify Calpine Corporation as described above, you consent to receive exclusively through electronic means all notices, disclosures, authorizations, acknowledgements, and other documents that are required to be provided or made available to you by Calpine Corporation during the course of your relationship with Calpine Corporation.